

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2021年12月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	17.86	5.82	80.36	0.94	16.35	11.41	1.40	70036.00
2	17.01	12.97	88.03	1.07	16.24	11.69	1.44	67526.00
3	17.97	8.73	83.38	1.12	15.87	11.69	1.44	68106.00
4	17.90	9.45	82.16	1.40	15.93	11.48	1.44	69677.00
5	17.68	8.96	83.71	1.19	17.01	11.27	1.43	69989.00
6	19.15	9.92	90.49	1.12	16.72	11.57	1.45	67729.00
7	19.48	9.86	85.82	1.49	17.43	11.20	1.43	70308.00
8	18.54	9.56	87.73	1.69	16.72	11.47	1.40	68964.00
9	18.87	7.05	102.75	1.57	16.74	11.58	1.40	67604.00
10	18.00	5.35	86.56	1.31	16.75	11.67	1.41	66899.00
11	17.76	8.53	85.79	0.89	17.14	11.45	1.36	67927.00
12	16.97	3.78	81.33	1.07	17.92	11.24	1.34	67783.00
13	18.68	7.46	89.63	1.50	16.19	11.61	1.35	66635.00
14	17.36	6.86	90.42	2.30	14.95	12.01	1.39	65361.00
15	18.35	7.63	81.43	2.14	16.62	11.64	1.40	66639.00
16	17.06	5.46	94.07	1.95	15.99	11.99	1.35	64835.00
17	16.41	5.08	98.13	2.22	15.93	11.91	1.33	66307.00
18	16.86	12.66	83.15	2.33	15.51	11.69	1.35	67849.00
19	10.40	6.73	94.93	1.59	14.61	12.50	1.40	62359.00
20	17.12	5.93	82.23	2.58	15.91	11.36	1.33	68800.00
21	17.41	9.93	75.73	1.88	16.92	11.15	1.32	69399.00
22	15.07	9.21	84.79	1.29	16.80	11.62	1.24	66671.00
23	17.46	10.38	92.87	1.92	15.59	11.79	1.26	66282.00
24	17.12	6.86	90.65	1.53	16.74	11.28	1.24	67104.00
25	18.04	14.15	88.03	1.66	15.63	11.63	1.20	65476.00
26	17.52	14.36	74.50	1.45	15.86	11.38	1.19	66987.00
27	16.96	6.26	85.16	2.35	14.69	11.82	1.27	65247.00
28	16.43	11.02	83.66	1.58	15.27	11.41	1.32	66888.00
29	17.26	9.42	72.11	2.16	14.59	11.65	1.34	65590.00
30	19.53	23.80	63.19	2.44	14.47	11.82	1.31	65678.00
31	16.86	9.23	55.30	1.90	14.34	12.04	1.33	64393.00
平均值	17.39	9.11	84.45	1.67	16.05	11.61	1.35	67130.58
最大值	19.53	23.80	102.75	2.58	17.92	12.50	1.45	70308.00
最小值	10.40	3.78	55.30	0.89	14.34	11.15	1.19	62359.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2021年12月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	16.31	15.31	83.93	0.50	16.82	10.72	1.50	60692.00
2	17.05	11.27	76.75	0.52	17.69	10.36	1.50	62159.00
3	17.46	18.04	80.18	0.64	17.38	10.42	1.49	62238.00
4	17.52	20.58	74.87	1.20	16.97	10.22	1.45	62542.00
5	15.73	10.80	76.04	0.55	18.26	10.12	1.46	62764.00
6	13.64	12.48	83.80	0.55	17.87	10.51	1.46	63312.00
7	9.74	14.77	65.41	0.48	17.97	10.64	1.42	61687.00
8	15.83	10.27	69.40	0.91	18.03	10.38	1.39	62063.00
9	14.91	8.72	69.36	0.51	18.04	18.04	1.40	61181.00
10	18.11	9.46	62.60	0.84	18.20	10.36	1.41	60545.00
11	19.11	10.88	59.98	0.84	17.49	10.70	1.42	60717.00
12	20.07	8.52	59.79	1.19	17.77	10.51	1.45	61849.00
13	19.65	10.51	59.95	0.47	17.86	10.51	1.45	60904.00
14	18.04	10.15	57.51	0.59	17.46	10.61	1.43	60357.00
15	21.79	14.76	55.34	1.32	17.80	10.59	1.43	61343.00
16	17.70	16.63	57.44	0.88	17.89	10.66	1.40	60171.00
17	18.79	15.71	57.11	1.19	17.45	10.85	1.33	61616.00
18	21.12	10.50	62.81	1.60	16.29	10.97	1.35	61444.00
19	19.17	9.20	53.76	1.02	17.01	10.33	1.36	60812.00
20	18.00	20.67	56.66	0.70	17.70	10.31	1.34	60684.00
21	19.05	17.02	60.68	1.17	17.65	10.41	1.41	61085.00
22	17.14	19.13	61.05	0.91	18.00	10.57	1.40	60812.00
23	23.37	21.47	63.05	1.08	16.12	10.75	1.43	59773.00
24	17.33	28.76	61.04	0.65	16.75	10.32	1.46	58770.00
25	18.12	22.79	64.85	0.87	15.90	10.64	1.47	57501.00
26	17.89	13.06	64.99	0.99	15.82	10.50	1.44	59777.00
27	15.66	10.84	65.01	0.64	16.40	10.67	1.48	61795.00
28	17.84	5.00	66.92	0.59	16.54	10.68	1.48	61269.00
29	22.56	10.39	78.69	1.88	16.53	11.43	1.44	60464.00
30	15.18	16.40	76.34	0.58	15.26	10.98	1.51	60262.00
31	16.11	9.86	55.89	0.58	15.18	10.85	1.48	60862.00
平均值	17.74	14.00	65.85	0.85	17.16	10.83	1.43	61014.52
最大值	23.37	28.76	83.93	1.88	18.26	18.04	1.51	63312.00
最小值	9.74	5.00	53.76	0.47	15.18	10.12	1.33	57501.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2021年12月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	15.68	8.67	81.03	2.57	15.77	10.40	1.39	78268.00
2	15.77	6.87	85.63	2.31	16.21	10.72	1.41	79575.00
3	18.24	12.33	88.73	3.12	15.44	10.93	1.39	80267.00
4	17.29	11.39	93.25	2.98	15.38	10.77	1.40	80900.00
5	17.02	9.54	80.39	4.38	16.03	10.33	1.31	81186.00
6	18.62	6.51	77.46	3.49	16.15	10.32	1.31	78778.00
7	15.71	8.61	65.45	3.05	16.11	10.64	1.31	80100.00
8	15.99	7.71	62.67	3.28	15.92	10.47	1.32	76851.00
9	15.25	8.59	61.01	3.39	16.47	10.23	1.33	75542.00
10	15.77	4.58	60.11	2.71	15.77	10.98	1.34	73363.00
11	17.05	7.41	61.77	2.47	15.63	11.11	1.36	73870.00
12	18.05	5.35	62.50	3.02	15.87	10.95	1.36	76474.00
13	19.41	5.15	63.97	3.24	15.53	11.00	1.33	75794.00
14	17.15	11.51	69.00	3.25	15.59	11.26	1.32	76153.00
15	18.44	6.59	57.99	3.07	17.46	10.62	1.32	76606.00
16	17.17	8.14	61.06	2.85	16.56	10.88	1.35	75675.00
17	16.54	5.90	62.75	3.37	15.94	11.02	1.33	75092.00
18	17.95	10.29	63.90	3.50	14.87	11.31	1.35	76373.00
19	18.19	4.33	60.03	2.97	16.14	10.74	1.37	81548.00
20	17.11	4.78	58.46	2.96	16.21	10.61	1.40	76992.00
21	20.40	7.96	57.42	3.20	16.81	10.47	1.38	79086.00
22	21.11	12.11	56.29	3.32	16.58	10.78	1.35	77154.00
23	17.45	10.57	59.63	3.04	15.16	10.80	1.38	75483.00
24	18.67	14.46	58.91	3.31	14.98	10.86	1.44	73547.00
25	12.99	15.22	60.24	3.06	14.92	10.80	1.44	74754.00
26	16.54	6.70	57.60	2.90	15.50	10.71	1.49	75042.00
27	15.68	8.00	58.85	2.89	14.67	10.93	1.49	72751.00
28	16.56	6.83	63.21	3.34	14.75	10.81	1.51	73156.00
29	17.71	6.44	65.53	3.41	14.70	10.62	1.49	72926.00
30	17.01	15.27	65.27	3.21	14.24	10.80	1.46	73318.00
31	16.99	10.23	55.57	2.98	13.95	10.86	1.41	78268.00
平均值	17.21	8.65	65.67	3.12	15.66	10.77	1.38	76609.42
最大值	21.11	15.27	93.25	4.38	17.46	11.31	1.51	81548.00
最小值	12.99	4.33	55.57	2.31	13.95	10.23	1.31	72751.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。