

P001_樹林焚化廠CEMS系統月報表

報表日期: 2021年6月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	6.49	9.17	70.59	2.66	13.73	13.93	1.41	69684.00
2	15.50	16.27	69.17	3.63	13.03	13.99	1.55	67134.00
3	11.58	14.50	72.46	2.89	13.47	13.89	1.54	68142.00
4	8.46	26.89	62.17	3.47	13.88	13.73	1.49	69824.00
5	5.89	25.81	53.66	2.55	14.71	13.35	1.44	73723.00
6	8.62	25.21	47.93	2.24	15.90	13.12	1.54	75063.00
7	8.30	22.57	50.25	1.43	16.58	13.57	1.55	71101.00
8	**	**	**	**	**	**	**	**
9	29.72	27.40	47.30	5.81	12.37	13.93	1.84	75140.00
10	20.01	13.52	62.97	3.77	12.89	14.08	1.65	73388.00
11	13.37	11.48	86.06	5.00	11.61	14.64	1.67	68010.00
12	12.72	20.76	61.19	4.04	13.19	13.53	1.67	79140.00
13	8.96	14.59	69.60	4.14	13.39	13.66	1.60	76387.00
14	6.37	9.23	84.82	3.73	13.69	13.89	1.74	73392.00
15	4.29	12.98	70.86	3.94	13.59	13.94	1.70	72297.00
16	9.01	15.57	67.34	4.27	13.62	13.79	1.65	73727.00
17	9.78	14.59	71.20	3.88	14.00	13.75	1.56	73087.00
18	6.21	13.70	72.66	4.20	13.15	14.05	1.62	69740.00
19	7.58	9.56	91.13	5.32	11.90	14.90	1.63	61415.00
20	3.75	4.82	94.06	5.31	11.98	15.05	1.67	59063.00
21	8.58	6.40	83.16	3.69	13.37	13.84	1.64	69570.00
22	5.54	4.03	85.90	3.50	13.37	14.22	1.59	65294.00
23	7.35	9.32	77.57	2.73	13.93	13.69	1.51	69786.00
24	5.51	12.63	79.68	2.63	14.23	13.83	1.52	67458.00
25	3.09	10.80	63.55	1.82	14.98	13.58	1.54	66461.00
26	3.13	4.44	80.86	2.42	13.73	14.02	1.52	65143.00
27	2.54	5.62	93.42	2.73	13.74	14.18	1.57	61444.00
28	3.43	3.31	87.38	3.30	13.18	14.23	1.55	59005.00
29	2.85	3.29	90.18	4.00	12.69	14.49	1.47	56408.00
30	4.11	3.29	88.22	3.59	13.43	14.17	1.45	57249.00
平均值	8.37	12.82	73.63	3.54	13.56	13.97	1.58	68526.72
最大值	29.72	27.40	94.06	5.81	16.58	15.05	1.84	79140.00
最小值	2.54	3.29	47.30	1.43	11.61	13.12	1.41	56408.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2021年6月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.95	12.43	84.40	1.03	16.57	11.50	1.37	62701.00
2	21.78	13.24	85.68	2.19	17.07	11.50	1.36	62835.00
3	13.46	7.43	80.51	0.97	17.65	11.17	1.37	62269.00
4	7.21	7.01	97.21	0.29	17.77	11.27	1.35	62648.00
5	6.85	4.97	108.16	0.29	17.85	11.01	1.35	64804.00
6	10.14	2.46	113.33	0.30	18.93	10.93	1.40	64654.00
7	8.44	5.35	105.15	0.27	18.26	10.99	1.41	64500.00
8	8.53	4.87	105.13	0.39	17.33	11.18	1.40	63603.00
9	10.35	13.10	99.36	0.66	16.97	11.40	1.43	62137.00
10	12.61	7.74	71.88	0.40	19.37	11.14	1.39	63675.00
11	12.93	10.45	74.75	0.69	18.91	10.99	1.37	65266.00
12	9.19	12.64	79.62	0.78	17.09	11.24	1.41	63370.00
13	6.02	5.67	82.17	0.34	17.60	11.28	1.42	63136.00
14	5.47	8.83	86.79	0.20	18.25	11.26	1.40	63064.00
15	4.02	13.41	81.01	0.18	17.86	11.49	1.39	61487.00
16	5.90	5.37	73.99	0.14	18.43	10.94	1.39	64869.00
17	6.40	6.30	73.25	0.18	18.07	11.00	1.35	64421.00
18	7.55	12.23	71.61	0.34	17.39	11.36	1.34	62287.00
19	6.77	21.72	90.26	0.63	15.37	12.56	1.36	54884.00
20	6.10	26.01	85.69	0.37	15.44	12.57	1.39	54291.00
21	5.79	7.81	71.55	0.16	17.96	11.02	1.39	63418.00
22	4.82	7.91	69.43	0.19	18.29	10.96	1.40	63984.00
23	9.32	14.68	67.76	0.28	18.33	10.99	1.39	64316.00
24	6.25	9.75	70.02	0.14	18.63	10.96	1.41	64760.00
25	4.37	15.35	73.04	0.26	18.00	11.54	1.44	60989.00
26	3.36	12.64	71.44	0.14	17.91	11.53	1.44	60888.00
27	1.38	20.85	85.39	0.25	17.22	12.21	1.49	56804.00
28	5.24	12.21	79.33	0.19	17.40	11.56	1.45	61354.00
29	4.48	11.85	72.74	0.18	17.21	11.48	1.40	61651.00
30	5.59	13.99	72.86	0.37	17.78	11.49	1.38	61511.00
平均值	7.68	10.94	82.78	0.43	17.70	11.35	1.39	62352.53
最大值	21.78	26.01	113.33	2.19	19.37	12.57	1.49	65266.00
最小值	1.38	2.46	67.76	0.14	15.37	10.93	1.34	54291.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2021年6月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.92	15.87	50.91	2.42	17.76	10.29	1.44	79005.00
2	17.79	10.83	54.73	2.44	17.69	10.43	1.44	76225.00
3	15.90	12.23	58.97	2.49	17.62	10.43	1.45	76449.00
4	11.85	11.25	63.87	2.54	17.20	10.72	1.44	78101.00
5	19.59	10.70	74.18	3.18	17.25	10.43	1.45	80332.00
6	16.26	7.25	78.23	2.98	17.89	10.61	1.47	82309.00
7	14.24	9.33	73.56	2.48	17.17	10.55	1.49	77795.00
8	10.34	11.32	68.71	2.10	16.95	10.39	1.49	80192.00
9	19.39	8.13	71.47	2.50	16.77	10.66	1.48	75638.00
10	13.89	11.60	59.39	2.65	16.57	11.33	1.47	72415.00
11	8.04	8.80	56.92	2.80	16.66	10.78	1.47	76994.00
12	9.03	5.08	73.18	3.35	16.47	10.91	1.47	78481.00
13	7.71	11.53	57.21	3.77	16.88	10.34	1.45	79699.00
14	6.54	10.15	67.34	3.31	17.53	11.03	1.45	80402.00
15	5.61	14.06	62.26	3.36	17.78	10.70	1.44	79860.00
16	8.18	8.78	58.40	4.10	17.57	10.38	1.47	77766.00
17	7.82	8.69	68.72	3.69	16.99	10.60	1.48	76448.00
18	6.34	9.84	74.34	3.46	16.47	10.73	1.48	75031.00
19	6.19	19.96	55.13	3.74	3.74	11.75	1.47	66198.00
20	2.98	13.50	62.13	3.80	13.91	12.45	1.45	60368.00
21	6.50	7.59	51.46	2.77	17.25	10.54	1.44	76643.00
22	5.84	11.94	47.06	2.64	18.09	10.00	1.43	82070.00
23	9.01	10.62	51.23	2.89	18.23	10.10	1.43	82423.00
24	8.71	15.49	51.41	2.74	18.10	10.26	1.42	79748.00
25	5.79	17.87	55.22	2.28	17.63	10.78	1.45	79223.00
26	5.18	8.96	56.95	2.05	17.33	10.91	1.45	78386.00
27	2.51	11.67	68.69	2.60	17.52	11.47	1.50	74482.00
28	6.59	8.12	66.23	2.36	16.50	11.51	1.47	76090.00
29	5.06	7.62	57.41	2.63	16.69	11.00	1.44	76657.00
30	6.71	6.77	56.05	2.86	17.47	10.56	1.44	80196.00
平均值	9.32	10.85	61.71	2.90	16.72	10.75	1.46	77187.53
最大值	19.59	19.96	78.23	4.10	18.23	12.45	1.50	82423.00
最小值	2.51	5.08	47.06	2.05	3.74	10.00	1.42	60368.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。