

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2021年5月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.13	18.11	53.16	1.94	13.51	13.53	1.38	76456.00
2	4.63	19.86	52.65	1.94	14.07	13.41	1.36	77161.00
3	4.18	15.48	55.64	1.59	14.04	13.40	1.38	76599.00
4	4.98	31.78	52.77	1.94	13.71	13.52	1.35	75697.00
5	6.15	23.47	54.35	2.19	13.38	13.55	1.31	76836.00
6	5.31	10.82	63.86	1.79	13.63	13.57	1.33	75532.00
7	4.57	21.48	51.77	2.09	13.46	13.49	1.34	75626.00
8	4.83	29.24	46.77	1.46	14.10	13.34	1.43	76587.00
9	6.80	24.75	47.63	1.10	14.14	13.28	1.42	73988.00
10	8.80	19.18	52.16	2.55	13.59	13.25	1.50	74114.00
11	2.99	14.19	72.80	3.02	13.74	14.03	1.35	71422.00
12	11.90	10.05	67.76	2.86	13.12	13.80	1.38	71544.00
13	17.57	20.61	60.11	3.70	12.55	13.69	1.46	72502.00
14	14.82	20.82	58.86	3.28	13.33	13.46	1.46	73394.00
15	19.18	30.75	55.93	4.39	12.16	13.83	1.52	70306.00
16	10.56	18.58	61.74	3.53	13.04	13.74	1.50	69207.00
17	10.06	18.45	62.00	3.37	12.88	13.87	1.59	66594.00
18	8.09	19.08	55.76	3.00	13.04	13.78	1.54	72014.00
19	15.25	18.00	60.17	3.38	12.98	13.72	1.54	72124.00
20	20.05	25.71	63.18	4.21	12.51	13.85	1.59	71564.00
21	7.63	21.51	64.14	3.57	13.18	13.86	1.48	72077.00
22	5.82	10.77	70.06	3.17	13.93	13.86	1.34	73787.00
23	3.56	9.77	70.74	3.35	13.75	14.09	1.26	71532.00
24	11.55	14.51	66.52	3.62	14.28	13.60	1.48	75891.00
25	7.93	25.30	60.77	3.68	13.30	13.82	1.43	74182.00
26	7.73	14.74	77.43	3.94	12.62	14.33	1.37	70200.00
27	8.61	16.71	79.95	3.74	12.81	14.20	1.39	71093.00
28	5.35	17.56	73.21	3.61	13.03	14.34	1.34	70164.00
29	4.37	14.41	64.97	3.26	13.46	13.87	1.29	75143.00
30	2.58	9.39	73.90	2.72	13.85	14.06	1.32	72604.00
31	3.98	10.31	76.84	2.78	13.77	13.88	1.32	73798.00
平均值	8.29	18.56	62.18	2.93	13.39	13.74	1.41	73217.35
最大值	20.05	31.78	79.95	4.39	14.28	14.34	1.59	77161.00
最小值	2.58	9.39	46.77	1.10	12.16	13.25	1.26	66594.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2021年5月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	13.27	21.39	65.13	0.88	16.96	11.17	1.33	65163.00
2	12.56	16.71	68.87	0.44	18.72	10.86	1.32	66238.00
3	12.08	22.64	66.42	0.27	19.60	10.75	1.27	65964.00
4	11.15	23.22	65.96	0.32	19.20	10.75	1.29	66021.00
5	14.23	28.78	70.66	0.59	18.65	11.00	1.30	65145.00
6	10.78	15.25	90.25	0.17	19.05	10.88	1.32	65182.00
7	15.80	12.83	102.44	0.48	18.64	10.61	1.35	67301.00
8	**	**	**	**	**	**	**	**
9	10.60	17.81	92.63	0.71	17.05	11.75	1.27	62155.00
10	9.11	10.04	68.51	0.30	19.50	10.59	1.28	66844.00
11	10.16	15.59	81.98	0.86	17.91	11.31	1.28	64038.00
12	11.85	18.98	78.90	1.40	15.76	11.76	1.29	60411.00
13	16.80	20.65	78.84	2.58	15.41	11.73	1.29	60886.00
14	19.53	10.89	89.88	1.33	16.40	11.26	1.34	63642.00
15	12.87	10.53	115.48	1.35	15.50	11.54	1.35	62473.00
16	18.32	3.91	117.29	0.71	17.90	11.26	1.34	62590.00
17	23.97	3.30	113.86	0.59	18.79	11.18	1.29	60654.00
18	16.51	3.35	111.55	1.11	17.68	11.38	1.29	61380.00
19	18.30	4.76	110.42	1.86	16.17	11.30	1.34	63757.00
20	18.48	9.18	115.22	1.41	15.50	11.61	1.36	61936.00
21	16.68	10.95	119.05	1.56	15.15	11.68	1.36	61747.00
22	15.77	3.56	119.66	3.09	16.16	11.44	1.38	62881.00
23	12.21	2.38	121.05	1.21	15.87	11.72	1.41	60673.00
24	17.48	7.76	108.72	4.45	16.86	11.66	1.38	60473.00
25	10.50	14.61	92.64	1.37	16.05	11.66	1.38	61950.00
26	16.05	22.96	83.96	1.40	15.54	11.78	1.40	60957.00
27	19.76	20.90	85.40	1.92	15.02	11.92	1.40	59933.00
28	16.07	23.12	91.96	1.59	15.05	12.10	1.41	58672.00
29	11.59	17.08	86.89	1.33	15.49	11.65	1.35	62313.00
30	8.93	9.34	82.12	0.90	16.51	11.26	1.36	61490.00
31	13.12	11.11	88.17	1.20	16.17	11.47	1.35	63603.00
平均值	14.48	13.79	92.80	1.25	16.94	11.37	1.34	62882.40
最大值	23.97	28.78	121.05	4.45	19.60	12.10	1.41	67301.00
最小值	8.93	2.38	65.13	0.17	15.02	10.59	1.27	58672.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2021年5月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	16.31	10.07	59.49	1.77	17.77	10.20	1.47	81742.00
2	13.64	9.70	54.74	1.61	17.92	10.38	1.47	82233.00
3	11.57	9.12	56.59	1.30	17.84	10.35	1.45	79692.00
4	16.29	15.89	53.40	1.66	17.63	10.10	1.45	81680.00
5	20.68	20.37	54.62	2.01	17.44	10.23	1.43	80594.00
6	20.67	13.35	58.11	2.23	17.60	10.25	1.46	81116.00
7	17.81	18.59	51.05	1.49	17.22	10.29	1.45	80594.00
8	21.73	15.17	47.98	1.07	17.69	10.22	1.43	81658.00
9	17.79	19.50	44.37	0.53	19.42	9.87	1.39	85411.00
10	17.43	13.15	49.45	1.91	18.53	10.05	1.41	82577.00
11	13.97	22.41	51.49	2.61	18.29	10.14	1.38	81276.00
12	11.97	16.48	50.78	1.92	17.83	10.42	1.40	78979.00
13	20.81	15.83	51.96	2.66	17.40	10.48	1.36	78703.00
14	23.73	12.53	56.95	3.05	18.08	9.99	1.54	81874.00
15	22.15	18.33	63.17	4.26	16.82	10.41	2.01	78131.00
16	10.56	7.19	56.17	2.25	18.28	10.56	2.18	79273.00
17	5.86	14.70	48.19	1.65	17.87	10.71	1.72	75816.00
18	8.12	11.48	65.99	2.07	17.81	10.58	1.33	78758.00
19	18.45	9.93	72.60	4.48	17.53	10.18	1.36	78670.00
20	20.31	10.61	73.39	3.21	16.98	10.45	1.38	77495.00
21	13.72	17.19	55.12	2.94	17.65	10.14	1.40	76980.00
22	16.44	9.29	53.93	4.82	18.01	10.11	1.38	78205.00
23	14.65	5.60	56.13	3.27	17.95	10.51	1.41	80899.00
24	17.06	8.32	56.88	4.03	17.60	10.66	1.40	78623.00
25	14.12	8.87	55.22	3.24	16.90	10.96	1.40	78049.00
26	18.48	14.49	50.87	2.96	17.03	10.52	1.43	79795.00
27	21.84	16.34	54.25	3.80	16.72	10.72	1.45	77838.00
28	17.05	16.87	51.54	3.29	16.77	10.60	1.43	78596.00
29	9.79	12.81	52.63	2.87	17.42	10.21	1.40	81910.00
30	15.44	10.28	52.69	3.24	17.77	10.43	1.41	81590.00
31	14.00	14.27	54.87	2.72	17.36	10.36	1.41	81742.00
平均值	16.21	13.51	55.31	2.61	17.65	10.36	1.47	80016.10
最大值	23.73	22.41	73.39	4.82	19.42	10.96	2.18	85411.00
最小值	5.86	5.60	44.37	0.53	16.72	9.87	1.33	75816.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。