

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月26日

| 項目      | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 13.56    | 3.12     | 53.55    | 0.32     | 19.54    | 11.29    | 1.55     | 84286.20  |
| 1       | 13.08    | 3.35     | 53.36    | 0.42     | 20.82    | 10.69    | 1.54     | 88183.41  |
| 2       | 15.63    | 1.97     | 49.56    | 0.62     | 19.81    | 11.02    | 1.55     | 86411.19  |
| 3       | 13.57    | 2.00     | 50.75    | 0.63     | 19.22    | 11.17    | 1.53     | 85719.03  |
| 4       | 13.19    | 2.00     | 53.84    | 0.72     | 18.18    | 11.64    | 1.50     | 82272.04  |
| 5       | 16.61    | 5.90     | 61.16    | 0.54     | 18.79    | 11.52    | 1.49     | 82275.23  |
| 6       | 14.42    | 5.04     | 45.11    | 0.83     | 17.62    | 11.54    | 1.50     | 84018.58  |
| 7       | 12.65    | 3.34     | 47.80    | 0.89     | 17.43    | 11.49    | 1.53     | 84545.99  |
| 8       | 15.74    | 5.36     | 61.50    | 0.85     | 18.20    | 11.76    | 1.57     | 81123.78  |
| 9       | 13.27    | 2.90     | 53.59    | 0.98     | 17.52    | 11.67    | 1.54     | 81812.65  |
| 10      | 16.53    | 2.57     | 59.20    | 0.74     | 18.52    | 11.50    | 1.54     | 83252.32  |
| 11      | 12.59    | 3.45     | 46.86    | 0.76     | 18.64    | 11.23    | 1.52     | 84916.36  |
| 12      | 14.31    | 2.65     | 49.97    | 0.90     | 18.05    | 11.58    | 1.57     | 82424.69  |
| 13      | 13.84    | 5.56     | 54.63    | 0.71     | 18.89    | 11.47    | 1.57     | 82435.76  |
| 14      | 13.32    | 6.52     | 44.60    | 0.84     | 18.21    | 11.40    | 1.57     | 83678.78  |
| 15      | 12.31    | 2.58     | 51.63    | 0.57     | 19.03    | 11.36    | 1.54     | 83751.21  |
| 16      | 15.09    | 7.23     | 51.74    | 0.75     | 18.29    | 11.67    | 1.51     | 81419.81  |
| 17      | 12.84    | 5.44     | 52.79    | 0.55     | 18.58    | 11.77    | 1.53     | 80713.24  |
| 18      | 13.38    | 9.45     | 52.61    | 0.41     | 19.98    | 10.77    | 1.51     | 87866.64  |
| 19      | 11.48    | 8.98     | 50.78    | 0.94     | 17.05    | 11.68    | 1.50     | 82642.71  |
| 20      | 15.79    | 12.80    | 40.36    | 1.62     | 16.50    | 11.76    | 1.49     | 83553.43  |
| 21      | 14.79    | 9.58     | 43.69    | 1.60     | 15.96    | 12.06    | 1.49     | 80998.92  |
| 22      | 16.23    | 16.27    | 41.99    | 2.49     | 15.40    | 12.02    | 1.51     | 80999.14  |
| 23      | 15.04    | 12.83    | 42.47    | 2.30     | 15.51    | 12.01    | 1.51     | 81753.75  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 14.14    | 5.87     | 50.56    | 0.92     | 18.16    | 11.50    | 1.53     | 83377.29  |
| 最大值     | 16.61    | 16.27    | 61.50    | 2.49     | 20.82    | 12.06    | 1.57     | 88183.41  |
| 發生時間    | 5        | 22       | 8        | 22       | 1        | 21       |          | 1         |
| 最小值     | 11.48    | 1.97     | 40.36    | 0.32     | 15.40    | 10.69    | 1.47     | 80713.24  |
| 發生時間    | 19       | 2        | 20       | 0        | 22       | 1        |          | 17        |
| 零點偏移(率) | -0.01 %  | -0.01 %  | -0.01 %  | -0.01 %  |          | 0.02     | 0.00     | 0.00 %    |
| 全幅偏移(率) | 0.78 %   | 0.29 %   | -0.14 %  | 0.14 %   |          | 0.25     | -0.03    | 0.40 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月26日

| 項目      | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 13.91    | 2.21     | 60.87    | 0.12     | 17.80    | 11.02    | 1.38     | 83312.31  |
| 1       | 11.87    | 2.66     | 61.65    | 0.20     | 19.15    | 11.59    | 1.38     | 78662.39  |
| 2       | 13.18    | 6.18     | 57.43    | 0.16     | 19.51    | 10.67    | 1.39     | 84694.63  |
| 3       | 14.69    | 5.36     | 43.06    | 0.24     | 17.36    | 10.62    | 1.42     | 87997.04  |
| 4       | 13.94    | 8.63     | 54.55    | 0.24     | 17.44    | 11.13    | 1.43     | 84384.04  |
| 5       | 13.64    | 3.22     | 46.23    | 0.23     | 17.32    | 10.59    | 1.43     | 87131.99  |
| 6       | 11.50    | 3.00     | 51.06    | 0.18     | 17.23    | 10.79    | 1.45     | 82663.41  |
| 7       | 16.20    | 8.07     | 54.43    | 0.78     | 17.55    | 10.62    | 1.43     | 86636.04  |
| 8       | 13.98    | 3.24     | 64.84    | 0.88     | 15.53    | 11.17    | 1.42     | 85891.37  |
| 9       | 14.01    | 4.16     | 64.22    | 0.28     | 17.95    | 10.79    | 1.46     | 86842.72  |
| 10      | 14.07    | 4.57     | 61.40    | 0.14     | 18.35    | 10.76    | 1.46     | 86843.14  |
| 11      | 14.11    | 2.23     | 51.54    | 0.20     | 18.40    | 10.65    | 1.46     | 87002.44  |
| 12      | 11.96    | 0.59     | 64.13    | 0.30     | 18.19    | 10.59    | 1.45     | 88276.95  |
| 13      | 12.80    | 2.03     | 49.25    | 0.21     | 17.89    | 10.68    | 1.45     | 86355.19  |
| 14      | 13.78    | 2.17     | 56.88    | 0.30     | 17.30    | 10.82    | 1.45     | 87791.98  |
| 15      | 12.86    | 1.80     | 59.15    | 0.23     | 17.57    | 11.00    | 1.44     | 86206.06  |
| 16      | 11.82    | 3.06     | 58.64    | 0.23     | 18.48    | 10.62    | 1.45     | 85756.82  |
| 17      | 15.24    | 5.01     | 47.95    | 0.29     | 17.91    | 10.38    | 1.45     | 87191.94  |
| 18      | 13.11    | 4.84     | 55.71    | 0.14     | 18.53    | 10.49    | 1.44     | 89033.90  |
| 19      | 13.48    | 3.32     | 56.77    | 0.15     | 18.61    | 10.62    | 1.44     | 88628.65  |
| 20      | 13.62    | 7.89     | 49.44    | 0.74     | 16.18    | 10.97    | 1.44     | 86323.52  |
| 21      | 13.46    | 13.10    | 48.42    | 0.95     | 15.62    | 10.78    | 1.43     | 83769.54  |
| 22      | 11.43    | 8.48     | 45.91    | 2.32     | 15.75    | 10.38    | 1.41     | 79775.92  |
| 23      | 14.00    | 3.88     | 47.55    | 1.14     | 15.49    | 10.29    | 1.41     | 82786.04  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 13.44    | 4.57     | 54.63    | 0.44     | 17.55    | 10.75    | 1.43     | 85581.58  |
| 最大值     | 16.20    | 13.10    | 64.84    | 2.32     | 19.51    | 11.59    | 1.47     | 89033.90  |
| 發生時間    | 7        | 21       | 8        | 22       | 2        | 1        |          | 18        |
| 最小值     | 11.43    | 0.59     | 43.06    | 0.12     | 15.49    | 10.29    | 1.38     | 78662.39  |
| 發生時間    | 22       | 12       | 3        | 0        | 23       | 23       |          | 1         |
| 零點偏移(率) | -0.01 %  | 0.00 %   | -0.01 %  | -0.02 %  |          | -0.07    | 0.00     | 0.00 %    |
| 全幅偏移(率) | 1.26 %   | 0.45 %   | -0.07 %  | 0.18 %   |          | 0.33     | -0.03    | 0.10 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月26日

| 項目      | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 13.62    | 3.38     | 57.35    | 1.78     | 18.02    | 10.12    | 1.38     | 73665.70  |
| 1       | 13.51    | 4.19     | 52.99    | 1.75     | 19.07    | 10.05    | 1.41     | 74717.74  |
| 2       | 14.96    | 3.57     | 51.73    | 2.12     | 17.87    | 9.80     | 1.41     | 75131.87  |
| 3       | 14.28    | 10.00    | 49.73    | 2.36     | 17.64    | 9.66     | 1.41     | 75805.49  |
| 4       | 13.65    | 3.37     | 50.26    | 2.30     | 16.91    | 9.81     | 1.40     | 74726.62  |
| 5       | 14.27    | 1.68     | 51.54    | 2.55     | 16.53    | 10.27    | 1.38     | 71700.09  |
| 6       | 14.01    | 2.71     | 47.16    | 2.18     | 16.07    | 9.98     | 1.40     | 72457.99  |
| 7       | 14.79    | 9.79     | 50.63    | 2.32     | 16.22    | 10.17    | 1.40     | 76282.96  |
| 8       | 12.78    | 7.84     | 52.56    | 2.36     | 15.81    | 10.85    | 1.41     | 72781.53  |
| 9       | 14.75    | 10.92    | 52.36    | 2.94     | 14.81    | 10.83    | 1.41     | 71852.43  |
| 10      | 14.91    | 3.80     | 50.28    | 2.42     | 15.79    | 10.41    | 1.41     | 72973.68  |
| 11      | 12.18    | 2.93     | 57.96    | 2.33     | 16.86    | 10.27    | 1.45     | 71418.50  |
| 12      | 13.06    | 3.47     | 56.76    | 2.07     | 18.78    | 9.65     | 1.41     | 75066.92  |
| 13      | 13.60    | 11.36    | 51.39    | 2.08     | 17.36    | 9.69     | 1.38     | 76020.30  |
| 14      | 12.90    | 1.54     | 49.93    | 1.99     | 17.36    | 10.22    | 1.40     | 72738.91  |
| 15      | 13.41    | 4.50     | 46.15    | 2.20     | 15.87    | 10.51    | 1.41     | 68893.22  |
| 16      | 14.88    | 11.25    | 55.64    | 2.30     | 17.21    | 10.45    | 1.39     | 68709.38  |
| 17      | 13.35    | 6.18     | 71.07    | 2.30     | 18.05    | 10.34    | 1.40     | 76152.56  |
| 18      | 15.05    | 8.19     | 61.99    | 2.50     | 17.60    | 9.93     | 1.40     | 73940.08  |
| 19      | 17.33    | 14.71    | 55.50    | 2.60     | 15.63    | 10.45    | 1.41     | 76349.23  |
| 20      | 15.05    | 10.56    | 58.70    | 3.12     | 14.19    | 10.93    | 1.43     | 73460.79  |
| 21      | 16.57    | 19.76    | 56.35    | 3.39     | 14.67    | 10.63    | 1.41     | 73666.01  |
| 22      | 14.73    | 3.87     | 71.59    | 3.27     | 14.28    | 10.75    | 1.41     | 73559.73  |
| 23      | 14.71    | 2.31     | 60.87    | 3.13     | 13.65    | 11.00    | 1.39     | 73048.00  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 14.26    | 6.75     | 55.02    | 2.43     | 16.51    | 10.28    | 1.40     | 73546.66  |
| 最大值     | 17.33    | 19.76    | 71.59    | 3.39     | 19.07    | 11.00    | 1.46     | 76349.23  |
| 發生時間    | 19       | 21       | 22       | 21       | 1        | 23       |          | 19        |
| 最小值     | 12.18    | 1.54     | 46.15    | 1.75     | 13.65    | 9.65     | 1.38     | 68709.38  |
| 發生時間    | 11       | 14       | 15       | 1        | 23       | 12       |          | 16        |
| 零點偏移(率) | -0.02 %  | -0.02 %  | -0.02 %  | 0.00 %   |          | 0.00     | 0.00     | 0.00 %    |
| 全幅偏移(率) | 1.54 %   | 0.47 %   | -0.39 %  | 0.16 %   |          | 0.19     | 0.02     | 0.20 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |