

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.15	5.22	47.60	0.80	18.07	11.15	1.70	69053.74
1	13.12	2.48	47.42	0.62	18.34	11.32	1.70	67048.25
2	12.55	1.85	47.81	0.25	20.21	10.74	1.70	69334.21
3	13.32	1.55	41.17	0.43	19.22	10.96	1.67	67720.49
4	13.59	3.73	38.44	0.86	17.91	11.09	1.66	67446.55
5	14.27	9.12	42.77	1.46	17.53	11.34	1.67	69309.40
6	12.57	6.07	46.99	1.06	17.59	11.47	1.68	66052.07
7	13.52	2.97	56.82	0.56	19.39	10.97	1.68	69194.96
8	10.02	8.83	49.75	0.68	17.51	11.68	1.70	65171.91
9	14.41	1.44	51.44	1.33	17.40	11.21	1.68	68876.03
10	11.82	1.98	56.67	0.66	18.37	11.25	1.70	68484.97
11	11.30	3.03	61.07	0.26	19.05	11.54	1.71	65766.32
12	13.68	3.13	59.83	0.44	19.67	11.16	1.67	67676.67
13	12.08	4.91	52.46	0.35	19.87	11.06	1.68	68996.39
14	13.02	3.24	51.25	0.36	20.53	10.61	1.70	70974.05
15	12.85	2.61	56.75	0.25	20.62	10.60	1.70	71660.04
16	12.04	4.23	50.94	0.25	19.64	10.93	1.70	69279.56
17	14.36	5.95	55.50	0.70	19.16	11.06	1.70	68599.85
18	11.89	6.04	47.39	0.70	18.88	11.05	1.70	69090.45
19	13.75	7.09	43.71	0.61	19.15	10.78	1.71	71145.09
20	11.19	6.07	44.31	0.84	17.46	11.38	1.70	67432.68
21	10.87	2.74	52.24	0.45	19.92	10.89	1.69	69740.70
22	12.49	12.13	42.50	0.56	19.76	10.67	1.67	70873.84
23	10.91	9.27	46.24	0.71	18.54	11.52	1.70	65476.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.57	4.82	49.63	0.63	18.91	11.10	1.69	68516.87
最大值	14.41	12.13	61.07	1.46	20.62	11.68	1.72	71660.04
發生時間	9	22	11	5	15	8		15
最小值	10.02	1.44	38.44	0.25	17.40	10.60	1.65	65171.91
發生時間	8	9	4	2	9	15		8
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	-1.12 %	1.12 %	-0.55 %	0.46 %		0.06	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.10	1.96	55.90	0.43	17.76	10.64	1.50	87579.97
1	13.50	1.82	57.47	0.56	15.94	11.22	1.49	85776.40
2	11.58	2.54	54.56	0.44	18.53	11.00	1.47	83315.24
3	12.68	1.82	58.22	0.62	17.31	10.96	1.47	85239.77
4	13.27	5.19	52.18	0.87	15.95	11.56	1.47	82885.75
5	13.20	3.81	52.99	0.87	16.13	11.67	1.47	79770.18
6	9.20	5.13	55.20	0.14	17.05	11.31	1.48	77870.76
7	13.32	2.27	58.73	0.48	17.82	10.77	1.49	87549.21
8	13.11	2.79	65.71	0.50	16.48	10.94	1.51	86186.43
9	4.87	5.83	49.71	0.26	15.93	11.31	1.50	83497.20
10	12.29	1.36	57.11	0.57	16.59	11.10	1.50	83912.59
11	11.72	1.74	58.55	0.80	14.92	11.74	1.52	81364.11
12	3.92	7.50	66.24	0.15	14.85	13.90	1.54	58923.23
13	0.59	2.80	50.33	0.11	16.51	13.28	1.53	66091.59
14	4.64	1.78	41.13	0.12	16.83	12.35	1.51	73436.73
15	13.64	10.72	37.44	0.31	19.31	10.30	1.51	89534.98
16	13.04	2.42	49.47	0.39	17.44	11.17	1.51	82545.48
17	8.65	0.67	73.43	0.11	17.01	12.39	1.51	71788.76
18	8.65	1.07	60.94	0.11	17.64	11.50	1.51	82117.56
19	13.27	4.08	54.14	0.25	17.64	10.56	1.49	89739.16
20	13.48	9.61	54.04	0.60	16.87	10.80	1.50	88028.35
21	10.71	3.18	56.57	0.26	18.18	10.78	1.49	86644.82
22	12.57	6.97	52.58	0.53	17.19	10.66	1.50	88697.72
23	12.69	1.76	46.73	0.56	17.51	10.66	1.50	88938.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.74	3.70	54.97	0.42	16.97	11.36	1.50	82143.10
最大值	13.64	10.72	73.43	0.87	19.31	13.90	1.57	89739.16
發生時間	15	15	17	4	15	12		19
最小值	0.59	0.67	37.44	0.11	14.85	10.30	1.46	58923.23
發生時間	13	17	15	13	12	15		12
零點偏移(率)	-0.05 %	-0.04 %	-0.02 %	-0.03 %		-0.04	0.00	0.00 %
全幅偏移(率)	1.56 %	0.83 %	-0.74 %	0.23 %		-0.07	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.98	12.88	50.55	2.71	15.03	10.63	1.50	67953.02
1	12.03	3.30	45.57	2.24	16.53	9.98	1.50	70850.58
2	12.43	3.40	43.77	2.01	16.90	10.19	1.52	70503.86
3	16.44	9.64	43.36	2.35	16.83	10.12	1.54	74787.97
4	9.63	8.19	42.38	1.86	16.06	10.08	1.52	72565.06
5	14.49	7.08	44.10	2.93	15.48	10.17	1.49	73759.52
6	12.54	2.56	47.58	2.67	15.95	10.37	1.50	72484.21
7	13.37	2.98	46.98	3.38	16.08	10.24	1.49	78958.00
8	12.29	3.74	46.28	2.72	15.87	10.20	1.51	71931.39
9	10.67	6.14	47.50	2.79	14.72	10.43	1.45	73774.18
10	11.70	3.35	49.59	2.61	15.70	10.33	1.46	72469.39
11	11.14	3.94	57.25	2.21	16.90	10.52	1.50	69532.65
12	11.02	5.06	68.34	2.31	16.38	12.06	1.49	58701.61
13	13.30	3.55	56.58	2.78	17.83	10.68	1.44	68135.29
14	12.21	12.50	56.97	2.96	17.56	9.96	1.44	74933.71
15	14.69	11.63	57.59	2.87	17.70	9.77	1.43	76138.15
16	11.18	4.31	57.19	2.65	16.41	9.89	1.43	71975.01
17	9.98	1.33	70.25	2.42	18.02	10.30	1.44	67625.45
18	12.75	7.08	47.69	2.81	16.97	9.56	1.52	74246.04
19	13.11	11.66	52.15	2.88	16.77	9.82	1.52	74211.19
20	11.23	2.33	66.85	3.34	16.59	9.85	1.49	75299.85
21	13.68	5.28	60.33	3.90	15.57	10.15	1.53	73096.76
22	12.72	4.24	62.73	3.15	17.30	9.80	1.49	78652.23
23	8.91	6.85	55.76	2.56	17.51	9.80	1.43	71953.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.19	5.96	53.22	2.71	16.53	10.20	1.49	72272.43
最大值	16.44	12.88	70.25	3.90	18.02	12.06	1.56	78958.00
發生時間	3	0	17	21	17	12		7
最小值	8.91	1.33	42.38	1.86	14.72	9.56	1.39	58701.61
發生時間	23	17	4	4	9	18		12
零點偏移(率)	-0.02 %	-0.01 %	-0.00 %	-0.01 %		0.02	0.00	0.00 %
全幅偏移(率)	1.95 %	0.83 %	-0.59 %	0.07 %		0.29	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								