

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.08	6.31	65.88	0.08	20.02	11.36	1.60	81549.54
1	12.84	4.88	57.75	0.12	20.18	11.19	1.62	82787.96
2	13.92	4.22	66.28	0.07	19.39	11.45	1.62	81252.43
3	12.88	8.72	62.92	0.19	18.70	11.58	1.63	80685.33
4	13.68	3.50	52.48	0.20	20.23	10.76	1.63	86426.96
5	7.43	5.95	50.65	0.08	17.93	11.74	1.59	85421.25
6	14.02	7.75	59.76	0.10	18.68	11.57	1.59	80866.93
7	15.19	10.53	59.56	0.12	18.64	11.66	1.59	80635.94
8	14.25	8.29	61.58	0.13	20.04	11.23	1.59	83135.84
9	16.12	30.58	50.40	0.49	17.66	11.62	1.59	79706.92
10	15.17	3.74	52.12	0.43	17.39	11.38	1.60	79491.93
11	13.39	12.44	44.96	0.82	16.39	11.17	1.61	80514.15
12	15.12	7.93	53.23	0.23	17.00	12.12	1.61	73067.74
13	18.12	3.06	55.09	0.41	17.66	11.89	1.57	79567.63
14	17.73	11.28	47.05	0.48	16.66	11.89	1.59	80135.86
15	12.97	10.13	51.58	0.33	17.42	11.95	1.56	77870.13
16	16.67	10.26	50.22	0.32	18.05	11.53	1.51	80443.37
17	14.27	6.66	56.08	0.13	18.66	11.42	1.51	81723.02
18	18.17	10.98	47.46	2.19	17.93	11.57	1.52	80431.54
19	14.31	10.52	57.78	0.98	18.02	11.66	1.56	82131.83
20	16.21	10.26	51.26	0.32	17.94	11.65	1.58	82215.36
21	12.38	11.58	50.35	1.82	18.32	11.52	1.58	82197.95
22	15.09	7.67	47.42	0.39	17.35	11.64	1.57	79603.27
23	13.00	8.81	48.59	0.16	17.70	11.51	1.57	81342.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.33	9.00	54.19	0.44	18.25	11.54	1.58	80966.88
最大值	18.17	30.58	66.28	2.19	20.23	12.12	1.64	86426.96
發生時間	18	9	2	18	4	12		4
最小值	7.43	3.06	44.96	0.07	16.39	10.76	1.51	73067.74
發生時間	5	13	11	2	11	4		12
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	-0.11 %		-0.48	0.00	0.00 %
全幅偏移(率)	0.91 %	0.01 %	0.17 %	1.07 %		-0.09	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.85	1.85	48.29	0.16	19.90	10.28	1.40	89891.93
1	14.11	3.54	44.83	0.16	21.63	9.95	1.41	96029.51
2	14.13	5.73	50.98	0.19	19.28	10.00	1.41	96185.03
3	12.23	9.82	44.81	3.21	17.84	10.06	1.40	90697.82
4	14.56	3.47	43.38	0.83	17.05	10.23	1.40	90598.10
5	14.32	22.81	51.26	0.71	16.14	10.59	1.42	87720.50
6	14.45	12.28	50.98	0.15	19.45	10.00	1.41	80122.50
7	13.47	0.86	51.24	0.19	18.48	10.62	1.42	88744.80
8	14.73	1.32	46.21	0.50	19.37	10.35	1.43	91737.04
9	12.60	5.25	57.15	0.27	19.81	10.10	1.43	94678.48
10	14.96	19.15	57.23	1.10	17.60	10.02	1.41	90112.02
11	15.21	2.05	64.29	0.80	17.63	10.15	1.41	90819.98
12	15.05	3.29	64.92	0.24	17.74	10.24	1.42	91007.69
13	22.61	7.52	66.13	1.14	16.79	10.94	1.44	87101.56
14	15.25	14.18	51.35	0.24	16.16	11.19	1.41	80146.61
15	14.93	1.33	59.33	0.25	17.14	10.50	1.44	91069.25
16	15.22	11.46	59.86	0.68	17.16	10.49	1.46	89820.30
17	15.68	7.69	45.13	6.14	15.41	11.39	1.45	86575.82
18	14.70	5.47	48.08	2.88	17.98	10.35	1.43	86409.94
19	14.95	3.09	56.27	0.33	17.65	10.83	1.44	87808.45
20	14.51	0.78	63.40	0.11	18.51	10.56	1.44	86074.97
21	16.89	0.88	55.86	0.16	17.91	10.44	1.45	93439.33
22	13.81	2.19	51.56	0.64	16.20	11.10	1.45	91780.60
23	8.45	4.49	52.43	0.14	17.37	10.98	1.46	90973.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.53	6.27	53.54	0.88	17.93	10.47	1.43	89564.39
最大值	22.61	22.81	66.13	6.14	21.63	11.39	1.48	96185.03
發生時間	13	5	13	17	1	17		2
最小值	8.45	0.78	43.38	0.11	15.41	9.95	1.38	80122.50
發生時間	23	20	4	20	17	1		6
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	-0.13 %		-0.09	0.00	0.00 %
全幅偏移(率)	0.39 %	-0.29 %	-0.53 %	0.12 %		0.08	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.89	6.61	45.12	1.41	18.31	9.65	1.49	72708.83
1	14.86	13.07	47.62	1.95	18.64	9.42	1.49	78426.08
2	13.56	5.18	45.34	1.71	18.79	9.80	1.49	74230.66
3	13.90	5.14	53.96	2.09	17.49	9.76	1.49	77364.09
4	15.39	6.58	47.48	2.22	16.65	10.00	1.49	75714.13
5	12.77	25.69	57.29	2.52	16.39	9.60	1.49	75210.80
6	14.61	3.02	52.60	2.38	17.01	10.35	1.49	73620.61
7	10.97	2.34	57.82	2.07	19.19	9.92	1.48	72855.25
8	14.83	5.65	49.14	2.37	19.64	9.40	1.47	78016.25
9	12.99	2.46	53.43	2.26	17.91	9.68	1.47	79265.06
10	15.35	6.93	52.71	3.51	16.10	10.27	1.46	75402.12
11	15.84	14.09	56.29	3.41	15.64	10.35	1.46	72662.54
12	13.46	18.08	52.48	2.50	16.36	10.24	1.46	73439.00
13	15.00	6.83	59.08	2.45	17.17	10.13	1.46	73413.22
14	13.83	18.74	64.51	2.50	16.63	10.42	1.45	71668.16
15	14.65	2.30	71.29	2.33	17.98	9.74	1.45	73878.34
16	20.87	15.14	61.87	3.78	17.34	9.76	1.47	78620.47
17	14.63	8.08	64.50	3.20	18.03	9.68	1.47	76115.14
18	11.30	8.56	51.20	2.41	16.66	9.82	1.47	71916.04
19	15.00	12.86	49.65	3.57	19.18	8.77	1.47	78847.70
20	20.41	1.95	68.88	5.40	17.79	9.63	1.47	79476.61
21	15.16	1.35	68.20	3.06	17.07	9.73	1.47	74746.41
22	15.20	1.57	65.07	2.27	17.03	9.85	1.48	76346.51
23	14.53	4.15	52.93	1.92	17.48	9.82	1.47	79897.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.71	8.18	56.19	2.64	17.52	9.82	1.47	75576.72
最大值	20.87	25.69	71.29	5.40	19.64	10.42	1.54	79897.37
發生時間	16	5	15	20	8	14		23
最小值	10.97	1.35	45.12	1.41	15.64	8.77	1.43	71668.16
發生時間	7	21	0	0	11	19		14
零點偏移(率)	-0.09 %	0.00 %	-0.02 %	-0.14 %		-0.17	0.00	0.00 %
全幅偏移(率)	1.37 %	-0.12 %	-0.64 %	0.36 %		-0.11	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								