

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.67	4.53	64.07	1.23	19.26	12.33	1.41	70376.53
1	2.59	3.83	49.03	0.89	20.78	11.70	1.41	73911.09
2	4.19	2.95	46.06	0.64	20.82	11.21	1.42	77968.22
3	1.95	14.80	70.47	1.58	17.94	13.08	1.77	65414.65
4	0.20	4.48	50.11	1.45	18.44	12.80	1.62	67194.57
5	1.32	5.62	61.51	1.30	19.16	11.49	1.46	72434.38
6	1.98	5.45	54.51	1.28	19.35	11.25	1.44	78304.23
7	4.42	9.83	52.11	1.80	16.95	12.01	1.43	74589.82
8	10.23	4.25	54.80	2.05	17.10	11.85	1.44	75291.27
9	10.62	2.27	53.22	1.92	17.21	11.77	1.44	74211.32
10	9.08	1.23	66.30	1.57	18.83	11.44	1.41	75335.33
11	12.14	9.91	48.57	2.11	17.76	11.75	1.39	74593.85
12	9.68	1.28	62.45	1.75	18.50	11.81	1.39	73543.62
13	11.12	4.64	52.09	1.85	18.01	11.72	1.39	75500.25
14	3.09	4.79	47.45	1.91	16.26	12.07	1.39	72401.42
15	5.99	5.98	58.79	2.05	16.78	12.22	1.40	70622.92
16	8.44	0.74	67.99	1.54	18.84	12.20	1.42	70911.69
17	9.54	0.84	46.44	1.55	18.74	11.75	1.41	74897.25
18	9.64	1.13	50.83	1.52	18.44	11.72	1.41	75918.61
19	8.63	1.98	69.61	1.46	18.97	12.27	1.41	70860.97
20	9.97	1.75	58.62	1.46	19.50	11.58	1.42	75743.54
21	9.84	1.59	56.44	1.41	18.97	11.48	1.43	77249.34
22	10.43	2.64	56.09	1.67	17.99	12.00	1.48	73579.17
23	7.08	3.18	65.83	1.40	19.44	12.21	1.46	70735.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.91	4.15	56.81	1.56	18.50	11.90	1.44	73399.58
最大值	12.14	14.80	70.47	2.11	20.82	13.08	2.56	78304.23
發生時間	11	3	3	11	2	3		6
最小值	0.20	0.74	46.06	0.64	16.26	11.21	1.37	65414.65
發生時間	4	16	2	2	14	2		3
零點偏移(率)	-0.11 %	-0.01 %	-0.01 %	-0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	1.06 %	0.22 %	-0.23 %	-0.02 %		0.13	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.41	6.93	65.00	1.75	19.30	10.10	1.30	69250.32
1	8.26	4.98	53.35	1.37	20.17	10.07	1.30	68923.37
2	5.43	3.03	67.64	1.20	19.87	11.19	1.30	61774.80
3	7.98	5.24	59.83	1.26	20.79	9.91	1.28	69560.43
4	6.89	7.92	62.52	1.27	20.44	10.34	1.30	66794.66
5	7.50	6.53	62.64	1.25	21.53	9.72	1.29	69894.28
6	7.46	2.13	57.72	1.36	20.07	10.35	1.35	71831.53
7	7.94	6.07	41.53	2.89	20.76	9.63	1.35	70282.09
8	8.59	2.85	61.06	2.13	17.07	11.16	1.35	62659.71
9	9.92	2.66	64.37	2.38	16.73	11.04	1.36	65427.61
10	13.77	8.16	59.18	3.34	14.54	11.44	1.38	64213.19
11	10.60	1.54	56.85	2.86	15.46	11.27	1.38	60328.21
12	8.92	2.67	56.87	2.67	14.75	11.61	1.38	61580.70
13	10.12	8.79	59.01	3.20	13.74	11.89	1.38	60481.12
14	10.32	0.71	66.67	3.03	16.44	11.61	1.38	60986.74
15	10.07	0.83	58.90	2.77	17.77	10.96	1.38	65008.03
16	10.13	3.55	65.48	2.62	16.24	11.31	1.38	63961.03
17	9.29	1.11	60.92	2.35	17.87	11.18	1.38	63864.99
18	9.35	0.91	69.29	2.05	18.10	11.01	1.40	64627.23
19	9.71	2.36	60.20	2.00	17.40	11.37	1.41	62827.59
20	11.83	4.36	58.82	2.33	16.53	11.24	1.42	64409.24
21	10.37	1.68	59.72	2.23	16.56	11.23	1.42	64103.67
22	8.37	1.58	68.66	1.97	17.34	11.40	1.41	61665.65
23	11.24	1.96	61.78	1.97	18.38	10.51	1.38	67143.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.31	3.69	60.75	2.18	17.83	10.90	1.36	65066.64
最大值	13.77	8.79	69.29	3.34	21.53	11.89	1.43	71831.53
發生時間	10	13	18	10	5	13		6
最小值	5.43	0.71	41.53	1.20	13.74	9.63	1.28	60328.21
發生時間	2	14	7	2	13	7		11
零點偏移(率)	-0.20 %	-0.00 %	-0.15 %	0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	2.14 %	-0.09 %	-0.05 %	0.09 %		0.13	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.65	3.82	62.49	1.90	17.23	10.54	1.33	86903.48
1	7.14	4.77	59.05	1.87	17.91	10.38	1.33	90652.78
2	5.44	8.53	61.89	1.97	19.09	10.27	1.33	89918.50
3	7.39	9.93	59.62	2.12	18.20	10.04	1.33	92868.07
4	7.59	1.60	63.67	2.07	17.60	10.53	1.34	89889.27
5	6.51	1.92	64.25	2.02	17.70	10.68	1.36	87912.68
6	5.45	10.93	68.06	2.25	17.76	10.88	1.36	84973.09
7	6.32	8.69	49.30	2.06	18.16	9.71	1.36	89109.44
8	7.81	2.53	62.70	2.39	16.59	10.79	1.37	83091.41
9	8.22	5.29	60.81	2.43	16.05	10.88	1.38	84019.56
10	15.32	13.71	59.70	4.10	13.94	11.00	1.37	79822.47
11	9.35	6.63	60.38	10.69	10.25	12.43	1.37	74216.15
12	11.29	2.70	56.28	4.93	12.96	11.33	1.35	77860.04
13	8.87	4.41	56.49	3.35	13.03	11.08	1.36	78451.92
14	10.75	7.84	58.61	3.95	13.85	11.00	1.35	80696.82
15	17.42	2.64	67.76	4.78	15.70	10.98	1.37	83769.48
16	11.57	2.25	60.64	2.43	15.88	11.20	1.38	80414.38
17	9.24	2.86	66.12	2.57	15.20	11.37	1.38	80697.95
18	7.92	1.98	63.37	2.16	15.90	11.29	1.41	80795.22
19	9.13	9.62	71.98	2.72	14.75	12.13	1.38	74228.26
20	6.75	4.15	60.18	2.33	14.73	11.21	1.38	80451.10
21	8.32	2.68	60.56	2.27	15.20	11.09	1.39	81162.96
22	7.26	3.01	67.28	2.51	15.15	11.48	1.38	77020.92
23	7.51	2.34	60.77	2.03	16.19	10.90	1.39	81125.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.63	5.20	61.75	3.00	15.79	10.97	1.36	82918.83
最大值	17.42	13.71	71.98	10.69	19.09	12.43	1.45	92868.07
發生時間	15	10	19	11	2	11		3
最小值	4.65	1.60	49.30	1.87	10.25	9.71	1.31	74216.15
發生時間	0	4	7	1	11	7		11
零點偏移(率)	-0.06 %	0.00 %	-0.00 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	2.00 %	0.44 %	-0.37 %	0.10 %		0.27	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								