

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.71	8.07	61.10	0.14	18.32	12.45	1.36	63896.08
1	12.63	7.87	46.78	0.14	18.53	11.67	1.35	69646.93
2	12.52	6.82	43.50	0.11	17.74	11.70	1.34	70335.97
3	11.94	7.85	44.48	0.10	17.52	11.82	1.35	69506.90
4	11.48	5.26	46.84	0.12	17.50	11.79	1.34	69299.48
5	13.01	6.80	57.17	0.13	18.14	12.17	1.33	65238.72
6	11.42	1.19	54.57	0.15	18.14	12.44	1.33	64260.18
7	12.25	3.70	50.47	0.13	17.89	11.95	1.33	67861.47
8	11.33	8.33	48.65	0.14	17.77	12.08	1.36	67137.13
9	12.98	14.19	44.96	0.14	18.02	11.94	1.32	66781.31
10	12.52	9.18	39.85	0.11	17.23	11.86	1.33	68139.51
11	10.86	3.81	57.60	0.16	19.04	11.91	1.32	66332.83
12	12.31	8.77	47.04	0.11	17.73	12.07	1.30	66317.23
13	11.66	2.89	52.22	0.16	19.22	11.70	1.32	67557.80
14	11.17	1.41	44.47	0.14	19.82	11.07	1.32	70772.63
15	12.99	2.72	38.88	0.11	17.60	11.49	1.33	69976.21
16	11.48	11.78	39.45	0.12	16.56	12.02	1.30	67483.93
17	13.99	2.22	57.18	0.12	17.62	11.92	1.31	67284.72
18	12.14	1.54	40.29	0.08	17.49	11.49	1.33	70953.55
19	10.39	1.64	48.39	0.10	17.56	11.96	1.30	67554.24
20	12.28	1.82	50.45	0.09	17.33	12.07	1.29	66646.45
21	12.52	2.21	48.84	0.61	17.40	11.75	1.28	69308.48
22	10.61	1.43	58.57	0.14	18.89	11.66	1.30	68740.73
23	11.43	1.81	59.39	0.14	17.96	11.90	1.32	68236.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.94	5.14	49.21	0.15	17.96	11.87	1.32	67886.20
最大值	13.99	14.19	61.10	0.61	19.82	12.45	1.38	70953.55
發生時間	17	9	0	21	14	0		18
最小值	10.39	1.19	38.88	0.08	16.56	11.07	1.28	63896.08
發生時間	19	6	15	18	16	14		0
零點偏移(率)	-0.06 %	0.00 %	-0.02 %	0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	0.02 %	0.02 %	-0.07 %	0.02 %		0.19	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.77	7.80	48.67	0.12	18.07	11.10	1.45	85459.65
1	13.05	8.24	51.60	0.17	18.44	10.90	1.45	86371.04
2	12.09	3.88	52.44	0.29	17.05	11.24	1.46	85022.91
3	13.11	4.76	53.44	0.62	16.30	11.56	1.44	83143.18
4	12.00	3.67	58.46	0.20	17.72	11.49	1.44	82668.41
5	11.55	10.57	64.45	0.15	15.98	12.44	1.44	75719.84
6	16.84	6.04	46.34	0.31	17.57	11.09	1.45	89626.98
7	12.27	4.62	43.59	0.14	17.56	11.12	1.46	84838.16
8	13.19	9.38	47.54	0.48	16.48	11.41	1.48	83801.78
9	11.33	14.82	43.66	0.36	16.49	11.33	1.48	82639.21
10	12.08	12.24	40.57	0.26	15.78	11.46	1.49	82983.47
11	14.30	2.84	44.44	0.39	17.25	11.32	1.48	84206.52
12	11.19	11.68	42.24	0.35	18.45	10.63	1.50	88158.71
13	12.73	3.62	31.61	0.32	16.75	10.85	1.50	87140.64
14	15.16	9.75	37.04	0.66	15.71	11.39	1.50	84006.54
15	11.55	6.93	51.02	0.46	15.25	11.38	1.50	85430.89
16	11.36	4.43	39.27	0.21	14.74	12.28	1.49	77561.00
17	11.43	4.26	41.80	0.10	16.10	11.50	1.46	83345.06
18	12.91	2.00	46.09	0.12	16.58	11.49	1.45	82941.95
19	10.83	1.09	44.87	0.13	17.75	11.01	1.45	85829.43
20	11.51	4.69	50.14	0.31	19.56	10.44	1.44	89107.62
21	13.74	5.41	48.58	0.89	18.51	10.57	1.45	88441.25
22	12.59	1.48	56.91	0.16	18.14	10.82	1.46	86973.37
23	11.35	1.14	54.57	0.15	18.48	11.47	1.46	81819.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.50	6.06	47.47	0.31	17.11	11.26	1.47	84468.19
最大值	16.84	14.82	64.45	0.89	19.56	12.44	1.51	89626.98
發生時間	6	9	5	21	20	5		6
最小值	10.83	1.09	31.61	0.10	14.74	10.44	1.43	75719.84
發生時間	19	19	13	17	16	20		5
零點偏移(率)	-0.05 %	-0.03 %	-0.43 %	0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	0.75 %	-1.06 %	0.32 %	-0.20 %		-0.16	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.90	6.90	60.86	0.90	15.79	12.06	1.20	66440.48
1	11.82	5.02	49.61	0.53	17.41	11.33	1.19	71198.87
2	11.95	4.36	46.21	1.21	16.22	10.91	1.19	74546.80
3	11.82	4.63	48.23	1.32	16.07	10.78	1.27	75709.91
4	12.77	1.19	54.28	1.31	15.92	11.12	1.24	74831.09
5	11.92	1.52	51.87	1.45	15.23	11.28	1.23	74105.18
6	11.95	1.66	54.96	1.00	16.61	10.97	1.21	74760.03
7	10.83	1.85	50.62	0.27	18.65	10.27	1.21	74830.68
8	12.05	2.52	47.61	0.22	18.00	10.46	1.21	79210.30
9	11.99	4.35	40.91	0.37	17.04	10.48	1.20	78540.31
10	11.19	4.61	50.59	0.45	16.62	11.02	1.25	71111.25
11	12.71	3.98	45.21	0.34	16.48	10.61	1.20	74719.83
12	11.75	2.94	46.49	0.53	16.25	10.63	1.24	75667.70
13	12.69	4.21	45.01	0.33	16.56	10.69	1.25	75000.29
14	12.37	5.95	45.08	0.55	16.42	10.38	1.25	79493.85
15	12.57	5.47	58.24	0.76	15.51	10.95	1.24	76054.76
16	12.37	2.71	62.16	0.84	15.57	10.72	1.19	76412.33
17	11.66	3.21	64.20	0.73	15.35	10.93	1.21	75671.81
18	12.06	4.35	60.09	0.67	15.40	10.93	1.23	76566.78
19	11.58	4.24	55.07	0.44	15.85	10.96	1.18	74927.62
20	13.17	4.00	52.04	0.84	15.76	10.93	1.18	75411.44
21	11.26	6.38	46.91	0.40	16.06	11.12	1.18	74315.14
22	13.33	3.15	43.08	1.10	15.76	11.25	1.18	72901.36
23	10.35	1.24	50.96	0.58	16.28	11.15	1.19	73185.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.96	3.77	51.26	0.71	16.28	10.91	1.21	74817.23
最大值	13.33	6.90	64.20	1.45	18.65	12.06	1.36	79493.85
發生時間	22	0	17	5	7	0		14
最小值	10.35	1.19	40.91	0.22	15.23	10.27	1.18	66440.48
發生時間	23	4	9	8	5	7		0
零點偏移(率)	-0.01 %	-0.01 %	-0.29 %	0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	-0.38 %	-0.13 %	0.22 %	-0.04 %		0.21	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								