

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.94	6.24	47.11	0.63	17.28	11.84	1.56	81716.67
1	16.84	13.87	46.79	0.66	17.52	11.84	1.55	83058.51
2	12.83	3.26	48.47	0.46	17.78	11.72	1.55	83229.47
3	14.59	2.19	48.67	0.76	17.78	11.41	1.53	85505.64
4	13.42	2.92	49.58	0.58	18.22	11.32	1.52	85824.39
5	17.31	10.29	52.75	0.83	16.81	11.81	1.51	82459.98
6	14.83	13.07	46.17	0.87	16.66	11.65	1.51	83600.20
7	13.50	4.90	45.76	0.89	16.71	11.75	1.52	82028.80
8	15.81	13.13	40.45	1.38	18.38	10.69	1.51	85044.87
9	14.53	5.70	34.38	1.14	16.02	11.44	1.50	79616.61
10	14.68	4.42	40.50	0.82	16.11	11.81	1.49	80357.78
11	14.14	3.28	46.75	0.69	17.08	11.57	1.52	81733.11
12	13.76	3.10	55.19	0.61	17.40	11.58	1.53	82502.70
13	11.13	8.87	59.36	0.53	17.11	12.25	1.54	77785.92
14	13.01	3.10	49.77	0.80	17.40	11.62	1.54	82798.21
15	15.64	8.78	48.54	2.14	15.83	12.04	1.55	80100.91
16	13.13	6.96	56.70	1.09	16.27	12.20	1.54	79021.70
17	17.22	8.22	56.21	1.47	16.67	11.85	1.53	81612.28
18	12.89	13.35	51.34	1.61	15.93	11.93	1.50	80353.52
19	13.45	1.45	56.17	0.61	16.85	12.00	1.48	77907.20
20	13.12	2.52	57.81	0.48	17.15	11.82	1.49	81576.16
21	13.51	2.42	56.92	0.52	17.64	11.65	1.51	83884.51
22	18.20	10.91	51.67	13.71	17.78	11.55	1.51	83970.68
23	14.39	7.18	45.40	5.08	16.47	11.81	1.51	82193.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.33	6.67	49.69	1.60	17.04	11.71	1.52	81995.15
最大值	18.20	13.87	59.36	13.71	18.38	12.25	1.57	85824.39
發生時間	22	1	13	22	8	13		4
最小值	11.13	1.45	34.38	0.46	15.83	10.69	1.46	77785.92
發生時間	13	19	9	2	15	8		13
零點偏移(率)	0.00 %	-0.05 %	-0.01 %	-0.01 %		-0.08	0.00	0.00 %
全幅偏移(率)	4.02 %	0.34 %	-0.78 %	0.54 %		0.09	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.41	5.90	61.80	0.38	15.96	10.90	1.40	82449.83
1	15.00	9.34	56.85	0.89	16.72	11.14	1.40	82518.08
2	14.08	2.99	54.84	0.38	17.65	10.58	1.40	84284.33
3	13.06	1.46	41.38	0.69	16.66	10.41	1.40	85439.64
4	14.38	2.70	51.81	0.88	15.81	10.94	1.42	85504.54
5	15.78	1.17	59.74	0.51	17.37	10.71	1.42	88948.78
6	15.03	7.61	62.11	0.71	15.81	11.44	1.42	78225.56
7	16.93	7.75	58.31	2.03	15.07	11.38	1.42	85054.66
8	12.13	12.80	62.73	1.07	15.31	11.17	1.46	83999.78
9	13.90	8.24	58.98	0.85	15.28	11.14	1.46	83095.28
10	15.48	1.29	62.54	0.59	15.56	11.21	1.46	84191.10
11	12.09	0.83	65.02	0.16	17.12	10.80	1.46	86366.95
12	10.46	2.91	67.71	0.13	17.48	11.04	1.44	82251.05
13	12.11	11.01	59.29	0.12	18.22	10.77	1.44	83422.87
14	12.37	3.43	60.06	0.33	16.64	10.77	1.44	85832.43
15	13.10	8.14	61.38	0.47	15.63	11.14	1.43	83823.58
16	12.24	9.71	54.38	0.60	14.92	11.15	1.44	81258.36
17	14.00	5.24	47.43	0.56	16.21	11.09	1.44	81366.57
18	12.42	3.54	49.91	0.22	17.32	11.18	1.43	77764.54
19	12.09	9.41	46.23	0.12	17.83	10.72	1.45	83254.53
20	12.11	7.54	53.50	0.11	16.31	11.89	1.45	75631.35
21	13.77	8.98	52.19	0.23	16.82	10.97	1.45	84305.62
22	10.88	2.95	57.99	0.12	17.57	11.45	1.46	77484.09
23	11.27	9.65	57.57	0.23	17.54	11.23	1.45	79643.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	13.30	6.02	56.82	0.52	16.53	11.05	1.44	82754.87
最大值	16.93	12.80	67.71	2.03	18.22	11.89	1.48	88948.78
發生時間	7	8	12	7	13	20		5
最小值	10.46	0.83	41.38	0.11	14.92	10.41	1.38	75631.35
發生時間	12	11	3	20	16	3		20
零點偏移(率)	-0.03 %	-0.04 %	-0.01 %	0.00 %		-0.15	0.00	0.00 %
全幅偏移(率)	-0.87 %	-0.04 %	0.20 %	0.07 %		0.23	-0.03	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.38	10.00	52.35	2.40	14.98	10.84	1.39	76262.14
1	14.55	9.91	52.35	1.83	18.06	9.61	1.39	77250.09
2	17.66	4.22	47.22	2.74	15.40	10.75	1.38	75255.09
3	16.50	1.24	47.24	2.13	16.74	10.85	1.39	79187.47
4	16.37	3.24	46.35	2.76	16.52	10.07	1.40	78379.35
5	15.77	3.85	45.74	2.88	14.56	10.31	1.38	74280.20
6	19.38	8.74	48.41	3.13	14.24	10.56	1.39	73634.78
7	16.65	6.64	53.09	2.27	15.57	10.36	1.42	77201.75
8	16.42	13.14	48.71	2.59	14.85	10.23	1.43	72612.99
9	19.28	8.13	56.20	2.51	15.17	10.62	1.44	74246.03
10	15.29	2.91	66.69	2.30	16.27	9.69	1.45	79950.65
11	10.00	3.53	65.51	2.27	14.38	10.78	1.43	74939.68
12	12.20	9.25	59.31	2.01	15.14	11.17	1.38	68151.59
13	11.19	7.12	54.14	1.74	15.95	11.29	1.38	63316.45
14	16.76	10.43	55.70	1.84	17.53	9.93	1.39	73853.23
15	12.82	5.96	56.88	2.24	16.16	9.91	1.39	73701.03
16	12.57	9.67	57.95	2.74	16.48	9.93	1.42	76499.43
17	15.93	8.51	50.20	1.97	17.10	9.75	1.43	74977.11
18	16.07	4.59	65.71	2.54	15.39	10.30	1.41	74404.23
19	16.43	6.60	50.49	1.93	16.17	10.23	1.38	72723.77
20	14.99	12.15	47.24	1.93	15.62	10.43	1.39	72407.70
21	14.73	2.66	56.00	2.98	14.88	11.27	1.39	70471.22
22	14.91	5.15	57.37	2.89	17.14	10.14	1.41	70704.87
23	14.06	3.91	65.46	2.41	16.86	9.92	1.41	74795.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	15.25	6.73	54.43	2.38	15.88	10.37	1.40	74133.60
最大值	19.38	13.14	66.69	3.13	18.06	11.29	1.48	79950.65
發生時間	6	8	10	6	1	13		10
最小值	10.00	1.24	45.74	1.74	14.24	9.61	1.37	63316.45
發生時間	11	3	5	13	6	1		13
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.01 %		-0.10	0.00	0.00 %
全幅偏移(率)	2.19 %	0.39 %	-0.33 %	0.04 %		0.13	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								