

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.04	5.83	66.77	0.13	18.44	11.81	1.56	78969.93
1	15.98	10.51	57.04	0.20	18.47	11.69	1.56	80236.46
2	15.23	12.01	56.75	0.44	17.07	12.29	1.56	75957.73
3	12.91	2.35	60.41	0.31	18.51	11.81	1.56	78902.57
4	15.87	3.51	60.49	0.40	18.02	11.61	1.56	80783.13
5	11.92	4.79	61.66	0.10	18.28	11.64	1.52	80667.25
6	15.60	7.31	56.36	0.20	17.99	11.75	1.52	79784.19
7	13.99	9.53	58.03	0.36	17.16	12.15	1.51	76887.19
8	13.33	9.26	68.43	0.11	18.62	12.09	1.53	76674.41
9	13.67	9.54	60.12	0.08	18.56	12.02	1.53	77261.94
10	15.82	15.62	47.97	0.29	18.49	11.50	1.55	81169.97
11	16.57	11.35	53.01	0.40	17.77	11.63	1.58	79700.24
12	13.95	11.50	49.40	0.17	18.07	11.72	1.61	78887.30
13	12.54	2.76	58.86	0.11	17.94	11.84	1.58	79149.69
14	13.75	4.20	51.44	0.09	18.00	11.45	1.58	81871.39
15	13.31	18.29	45.11	0.33	18.17	11.49	1.59	77947.44
16	13.86	8.60	47.11	0.43	16.74	11.89	1.59	76355.00
17	13.76	7.32	50.26	0.24	18.39	11.32	1.58	80964.36
18	13.26	3.18	63.47	0.09	18.84	11.62	1.57	79961.60
19	15.87	2.12	63.78	0.12	19.96	10.99	1.57	84622.34
20	14.37	7.40	59.08	0.32	17.98	11.27	1.58	83734.18
21	13.98	3.74	59.37	0.17	18.57	11.46	1.61	81940.01
22	12.93	4.29	57.79	0.16	17.77	11.83	1.62	79784.86
23	14.19	5.20	73.40	0.06	18.54	12.18	1.62	76211.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.24	7.51	57.75	0.22	18.18	11.71	1.57	79517.70
最大值	16.57	18.29	73.40	0.44	19.96	12.29	1.66	84622.34
發生時間	11	15	23	2	19	2		19
最小值	11.92	2.12	45.11	0.06	16.74	10.99	1.51	75957.73
發生時間	5	19	15	23	16	19		2
零點偏移(率)	-0.01 %	-0.05 %	-0.00 %	-0.01 %		-0.33	0.00	0.00 %
全幅偏移(率)	3.14 %	0.64 %	-0.04 %	0.57 %		-0.14	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.86	4.42	66.03	0.12	18.70	11.04	1.46	86688.26
1	12.77	14.13	64.00	0.14	21.31	10.31	1.46	92555.62
2	13.32	2.58	62.90	0.15	20.14	10.22	1.46	94673.98
3	15.12	1.80	65.21	0.18	20.37	10.22	1.46	94883.35
4	14.37	3.90	54.04	0.16	18.80	10.81	1.45	90377.19
5	13.49	3.45	60.38	0.16	19.75	10.55	1.45	92861.52
6	14.00	2.97	56.99	0.15	20.01	10.64	1.44	93954.66
7	14.83	4.79	54.67	0.15	19.21	10.85	1.43	90607.69
8	13.56	6.26	60.15	0.14	19.08	11.10	1.44	87227.64
9	14.19	3.22	63.13	0.13	20.53	10.28	1.45	94015.63
10	15.61	4.72	56.61	0.14	18.01	10.60	1.49	93395.32
11	14.67	2.43	58.84	0.09	18.38	10.57	1.50	93948.79
12	12.87	1.74	63.72	0.12	18.19	10.91	1.46	90240.98
13	15.94	18.01	66.37	0.23	17.96	10.68	1.46	92332.52
14	11.78	9.23	61.46	0.27	17.24	10.80	1.49	91340.75
15	16.08	6.41	53.64	0.36	17.07	10.95	1.48	88653.80
16	12.68	3.16	53.66	0.12	17.70	10.60	1.47	91193.39
17	14.40	2.15	55.22	0.17	18.78	10.41	1.48	91824.67
18	14.46	3.19	47.74	0.10	19.29	10.13	1.46	92647.64
19	15.37	11.21	50.71	0.18	19.05	10.21	1.45	93534.65
20	14.52	8.56	58.92	0.14	18.15	10.19	1.44	93416.70
21	15.27	3.00	52.22	0.15	17.99	10.73	1.45	89711.46
22	14.63	6.14	52.38	0.21	19.56	10.29	1.45	93124.41
23	14.58	11.99	58.11	0.11	19.57	10.40	1.46	92922.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.22	5.81	58.21	0.16	18.95	10.56	1.46	91922.21
最大值	16.08	18.01	66.37	0.36	21.31	11.10	1.50	94883.35
發生時間	15	13	13	15	1	8		3
最小值	11.78	1.74	47.74	0.09	17.07	10.13	1.43	86688.26
發生時間	14	12	18	11	15	18		0
零點偏移(率)	-0.02 %	0.00 %	-0.05 %	-0.04 %		0.00	0.00	0.00 %
全幅偏移(率)	3.15 %	0.75 %	-0.05 %	0.29 %		-0.01	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.28	16.23	43.87	2.02	16.97	10.60	1.35	77931.73
1	18.73	10.67	46.04	2.63	16.98	11.09	1.35	74289.81
2	15.38	6.76	45.48	2.61	15.22	11.38	1.33	69869.03
3	14.88	3.21	47.65	2.32	15.86	11.17	1.35	70892.61
4	15.10	1.79	51.22	2.34	16.69	10.97	1.36	72649.15
5	15.19	4.72	51.10	2.45	16.74	10.78	1.36	74766.46
6	13.74	6.86	53.53	2.21	15.35	11.76	1.35	67961.33
7	19.04	7.02	51.86	2.45	16.15	11.11	1.36	64186.95
8	12.18	9.86	49.12	1.86	17.07	10.62	1.36	68471.58
9	14.71	6.46	47.87	1.83	18.88	9.70	1.37	75039.85
10	14.65	12.21	43.46	1.50	17.45	9.71	1.38	75581.31
11	13.74	9.90	47.30	1.59	16.25	10.31	1.38	73091.72
12	15.94	7.19	43.22	1.42	17.80	9.77	1.38	74362.25
13	12.58	1.61	46.99	1.21	17.90	10.13	1.38	74249.44
14	15.83	13.37	52.97	2.12	16.14	10.02	1.39	75599.20
15	17.63	16.41	47.44	2.28	16.12	10.10	1.38	71997.38
16	13.67	4.79	47.08	1.67	17.49	9.69	1.38	71720.17
17	15.54	3.99	44.44	1.62	16.40	9.98	1.38	71475.75
18	13.97	1.63	53.42	1.42	18.00	9.97	1.38	71918.23
19	14.08	2.93	45.08	1.33	17.83	9.78	1.38	73217.00
20	15.42	2.67	48.44	1.57	17.77	9.92	1.36	72491.97
21	17.93	8.31	48.05	2.19	16.47	10.21	1.38	72620.06
22	13.99	4.99	49.78	1.48	17.27	10.27	1.38	70667.15
23	14.39	3.83	43.36	1.48	17.95	9.64	1.38	75423.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	15.15	6.98	47.87	1.90	16.95	10.36	1.37	72519.75
最大值	19.04	16.41	53.53	2.63	18.88	11.76	1.41	77931.73
發生時間	7	15	6	1	9	6		0
最小值	12.18	1.61	43.22	1.21	15.22	9.64	1.33	64186.95
發生時間	8	13	12	13	2	23		7
零點偏移(率)	0.00 %	0.00 %	-0.05 %	-0.05 %		-0.16	0.00	0.00 %
全幅偏移(率)	0.83 %	0.04 %	-0.04 %	0.04 %		-0.08	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								