

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.59	6.17	60.04	0.50	19.73	11.73	1.36	60440.69
1	15.39	9.33	59.03	0.55	20.27	10.36	1.36	69112.05
2	14.71	20.22	43.39	0.91	17.93	11.44	1.36	62596.63
3	14.83	19.94	46.77	0.94	18.44	11.36	1.37	63401.27
4	14.48	10.72	44.32	1.24	17.82	11.46	1.37	63196.05
5	14.74	16.53	43.85	0.98	17.57	11.53	1.41	61195.70
6	13.77	10.73	49.66	0.85	17.84	11.58	1.41	62308.05
7	15.46	35.02	45.25	0.93	17.27	11.12	1.41	65981.14
8	14.44	3.55	51.93	0.73	17.99	11.69	1.39	60944.08
9	14.72	5.81	57.92	0.74	17.92	11.35	1.43	64278.96
10	16.06	3.20	53.51	0.75	17.42	11.42	1.44	64162.10
11	13.41	27.31	52.84	1.00	16.78	11.85	1.41	60419.75
12	15.66	6.03	61.85	1.04	17.31	11.79	1.43	60219.05
13	12.69	12.05	47.37	0.62	17.44	11.50	1.44	63627.06
14	12.29	6.88	72.87	0.34	17.66	12.01	1.42	60027.12
15	14.31	3.66	73.83	0.20	19.03	11.05	1.45	64876.20
16	16.16	6.10	53.38	0.70	17.29	11.49	1.41	64116.24
17	13.48	11.43	77.45	0.89	16.41	12.84	1.42	56346.90
18	13.57	6.35	67.93	0.89	16.40	11.78	1.38	63921.18
19	15.41	5.16	54.48	0.98	16.49	11.63	1.41	64493.86
20	14.98	6.04	53.49	0.89	16.49	11.61	1.42	65316.23
21	14.47	3.75	72.38	0.96	15.98	11.87	1.42	64148.63
22	14.17	4.11	70.77	1.02	16.20	11.72	1.41	64277.08
23	15.74	4.50	70.10	0.76	16.61	11.35	1.41	66302.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.48	10.19	57.68	0.81	17.51	11.56	1.40	63154.51
最大值	16.16	35.02	77.45	1.24	20.27	12.84	1.46	69112.05
發生時間	16	7	17	4	1	17		1
最小值	12.29	3.20	43.39	0.20	15.98	10.36	1.36	56346.90
發生時間	14	10	2	15	21	1		17
零點偏移(率)	-0.01 %	-0.03 %	-0.11 %	-0.06 %		0.03	0.00	0.00 %
全幅偏移(率)	0.00 %	0.78 %	-0.03 %	0.95 %		0.01	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.05	5.19	44.98	0.12	18.16	10.59	1.39	66899.75
1	13.71	11.32	64.99	0.12	19.22	10.64	1.38	66195.32
2	14.56	4.60	69.25	0.19	18.41	10.65	1.38	65622.75
3	14.35	4.54	57.73	0.35	17.92	10.67	1.38	66411.65
4	14.26	2.41	60.08	0.18	18.41	10.53	1.38	67778.56
5	14.42	2.57	53.66	0.21	18.52	10.09	1.36	70248.11
6	15.43	4.60	59.00	0.11	19.59	10.35	1.38	67898.66
7	13.36	5.11	52.31	0.24	17.61	10.72	1.39	67356.43
8	13.95	3.52	61.69	0.15	19.14	10.53	1.42	66829.42
9	14.79	1.19	63.12	0.12	18.78	10.00	1.38	70369.95
10	18.41	5.09	59.18	0.83	16.95	10.64	1.40	68055.72
11	13.36	4.29	60.29	0.42	17.27	10.67	1.40	67425.61
12	14.86	4.45	50.60	0.45	17.25	10.70	1.40	66260.30
13	13.94	3.46	50.69	0.21	18.03	10.34	1.40	69415.70
14	13.85	3.97	52.36	0.15	18.25	10.65	1.38	67322.57
15	14.83	3.58	54.19	0.09	18.45	10.17	1.37	69701.79
16	14.25	6.35	53.50	0.12	18.56	10.64	1.40	66786.63
17	14.91	1.90	60.50	0.12	19.19	10.27	1.36	68797.82
18	13.80	3.74	51.25	0.10	18.42	10.53	1.38	67332.88
19	14.57	2.73	50.37	0.13	19.62	9.90	1.34	71254.83
20	15.03	16.21	50.86	0.15	17.24	10.61	1.33	68320.19
21	14.49	12.95	50.87	0.40	16.69	10.82	1.35	65953.55
22	14.71	6.99	61.56	0.16	18.67	10.66	1.38	66564.29
23	14.64	5.50	52.42	0.09	18.08	10.52	1.38	68765.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.48	5.26	56.06	0.22	18.27	10.50	1.38	67815.31
最大值	18.41	16.21	69.25	0.83	19.62	10.82	1.44	71254.83
發生時間	10	20	2	10	19	21		19
最小值	13.05	1.19	44.98	0.09	16.69	9.90	1.33	65622.75
發生時間	0	9	0	15	21	19		2
零點偏移(率)	-0.31 %	-0.04 %	-0.01 %	-0.06 %		0.01	0.00	-0.10 %
全幅偏移(率)	1.73 %	0.04 %	0.08 %	0.77 %		0.06	-0.03	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.57	10.52	50.00	3.04	18.38	9.87	1.42	80375.50
1	14.10	8.84	53.69	2.95	18.82	10.40	1.43	74946.42
2	14.54	7.06	54.53	3.14	17.35	9.98	1.43	75502.84
3	13.98	7.66	53.12	3.46	16.49	10.15	1.43	74092.37
4	15.20	5.97	58.12	3.62	16.88	10.13	1.43	74310.50
5	14.60	13.91	57.22	4.37	16.42	10.22	1.42	77997.48
6	13.82	6.83	60.37	3.48	17.06	10.36	1.46	72902.32
7	15.56	4.90	55.83	3.69	15.91	10.32	1.46	77148.89
8	14.03	15.18	55.96	4.75	15.13	10.59	1.44	73945.73
9	13.08	10.26	57.72	4.34	15.26	11.41	1.43	73765.83
10	10.26	9.24	50.59	3.53	14.86	11.06	1.43	75376.17
11	10.60	7.47	54.19	3.00	15.78	11.13	1.43	76582.68
12	9.63	10.96	52.80	3.58	14.87	11.27	1.43	73803.15
13	9.54	3.65	53.23	2.50	16.62	11.17	1.42	72506.56
14	9.79	4.63	51.61	2.28	16.77	10.73	1.41	78584.16
15	11.47	7.79	49.61	2.43	16.97	10.70	1.41	78406.19
16	9.23	7.70	49.85	2.54	16.07	11.06	1.38	77385.98
17	9.85	19.23	51.22	3.36	14.77	11.37	1.38	69917.20
18	9.68	5.51	55.25	2.39	17.55	10.61	1.38	78913.96
19	10.01	27.99	46.94	2.43	15.67	10.87	1.38	77382.94
20	9.92	3.59	50.32	2.46	16.68	10.42	1.37	74408.26
21	14.36	28.64	43.36	3.47	14.73	10.49	1.38	73642.09
22	13.80	11.91	42.32	2.72	15.46	10.03	1.38	72247.77
23	14.80	6.86	46.29	2.13	17.11	9.74	1.38	69627.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.35	10.26	52.26	3.15	16.32	10.59	1.41	75157.17
最大值	15.56	28.64	60.37	4.75	18.82	11.41	1.50	80375.50
發生時間	7	21	6	8	1	9		0
最小值	9.23	3.59	42.32	2.13	14.73	9.74	1.36	69627.00
發生時間	16	20	22	23	21	23		23
零點偏移(率)	0.00 %	-0.03 %	-0.11 %	-0.06 %		0.01	0.00	0.00 %
全幅偏移(率)	-1.60 %	0.16 %	-0.14 %	0.81 %		0.13	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								