

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年11月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.56	2.39	60.61	0.36	21.30	11.32	1.35	75505.41
1	2.58	3.47	61.65	0.60	21.02	11.20	1.38	76118.02
2	4.83	4.32	57.74	0.87	20.16	11.61	1.41	73725.19
3	6.17	4.72	54.89	1.20	19.71	11.81	1.41	73037.20
4	15.81	7.32	53.63	1.59	18.62	11.36	1.40	77184.03
5	7.46	6.06	59.34	1.52	17.24	11.81	1.34	71475.60
6	8.62	5.30	61.21	1.45	17.85	12.01	1.37	73423.95
7	1.47	3.06	62.73	1.04	18.93	11.57	1.39	75651.23
8	0.61	1.71	62.14	1.17	18.42	11.67	1.38	75010.16
9	2.54	2.48	60.25	1.33	18.71	11.71	1.38	74711.50
10	9.75	4.18	61.27	1.55	17.86	12.01	1.37	74351.83
11	10.54	13.69	50.14	1.87	16.98	11.84	1.37	75277.08
12	11.16	5.29	56.47	1.70	17.20	12.12	1.37	71531.66
13	5.24	5.20	53.76	1.34	17.55	11.78	1.37	76008.70
14	13.06	13.65	48.31	1.51	16.02	12.15	1.36	78300.56
15	13.04	8.23	60.00	1.84	16.83	11.90	1.33	75830.52
16	14.05	4.92	48.78	1.29	17.49	11.77	1.31	73444.80
17	16.69	4.44	49.86	1.21	17.30	11.86	1.32	74248.60
18	7.55	9.03	49.48	1.48	15.92	12.39	1.33	73362.51
19	10.12	4.69	55.47	0.78	18.70	11.42	1.35	77816.67
20	4.37	3.82	60.37	1.09	17.54	12.41	1.36	74180.61
21	0.27	2.98	62.35	0.60	18.95	12.29	1.33	74250.77
22	0.06	3.96	50.14	0.84	17.36	12.22	1.33	75612.93
23	0.06	5.16	59.55	0.73	18.08	12.16	1.33	74055.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.94	5.42	56.67	1.21	18.16	11.85	1.36	74754.79
最大值	16.69	13.69	62.73	1.87	21.30	12.41	1.42	78300.56
發生時間	17	11	7	11	0	20		14
最小值	0.06	1.71	48.31	0.36	15.92	11.20	1.30	71475.60
發生時間	22	8	14	0	18	1		5
零點偏移(率)	-0.28 %	-0.00 %	-0.18 %	-0.00 %		0.02	0.00	0.00 %
全幅偏移(率)	-1.37 %	-0.45 %	0.32 %	0.21 %		0.31	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年11月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.63	6.41	65.08	1.55	18.97	10.91	1.37	63715.18
1	9.50	1.43	59.04	1.19	20.59	10.10	1.35	67811.46
2	9.08	5.13	59.31	1.80	18.86	10.63	1.34	65990.29
3	11.23	11.99	60.99	4.28	15.36	11.43	1.33	63560.85
4	9.25	3.08	65.25	5.13	15.30	11.50	1.33	63078.07
5	4.55	2.36	69.44	3.39	18.31	11.25	1.36	62745.20
6	9.57	3.03	64.05	1.75	21.58	9.28	1.32	69936.86
7	11.01	2.99	55.82	2.05	19.77	9.90	1.28	69948.34
8	11.05	2.51	65.51	2.22	18.48	10.46	1.27	67574.21
9	11.70	2.60	56.58	3.25	16.36	10.85	1.28	64927.12
10	10.85	10.75	63.76	4.13	14.44	11.10	1.29	64392.18
11	9.24	2.08	67.48	3.66	16.45	11.56	1.30	61007.22
12	10.92	2.82	60.77	2.59	17.09	10.93	1.32	65719.41
13	16.37	10.15	60.17	3.67	15.53	11.20	1.31	62235.24
14	9.54	0.23	61.46	2.29	16.95	10.76	1.31	63681.69
15	12.54	6.75	52.30	3.13	15.32	10.91	1.30	61755.15
16	11.76	3.75	61.20	2.65	16.29	10.75	1.28	64786.46
17	9.27	0.75	69.10	1.96	17.41	10.92	1.28	65436.89
18	9.61	3.79	64.14	2.39	17.14	10.90	1.25	64762.18
19	11.23	10.03	60.87	3.12	16.03	10.99	1.25	64889.86
20	10.63	0.45	66.30	2.16	17.95	10.77	1.25	65495.38
21	11.08	1.29	60.17	2.10	17.73	10.50	1.27	67132.91
22	9.23	0.67	69.70	1.89	17.80	10.92	1.31	65018.20
23	10.90	2.35	46.89	2.15	17.68	10.59	1.32	66435.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.36	4.06	61.89	2.69	17.39	10.80	1.30	65084.81
最大值	16.37	11.99	69.70	5.13	21.58	11.56	1.38	69948.34
發生時間	13	3	22	4	6	11		7
最小值	4.55	0.23	46.89	1.19	14.44	9.28	1.25	61007.22
發生時間	5	14	23	1	10	6		11
零點偏移(率)	0.00 %	-0.01 %	-0.01 %	-0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	4.07 %	-0.82 %	-0.06 %	0.25 %		0.15	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年11月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.57	1.50	61.71	2.38	17.64	10.04	1.38	83923.14
1	8.57	2.75	61.13	2.30	17.98	10.51	1.37	82897.26
2	10.99	1.22	59.66	2.79	18.11	10.22	1.38	86662.72
3	9.90	2.53	61.08	2.96	16.27	10.76	1.38	86227.40
4	12.58	7.09	61.33	3.40	14.39	10.92	1.38	86250.04
5	12.46	2.61	68.20	3.27	17.06	10.57	1.38	89218.99
6	5.52	1.33	70.87	2.56	16.46	11.65	1.37	76551.16
7	10.80	2.86	59.94	3.28	14.32	10.71	1.33	77012.18
8	8.87	1.33	61.10	3.14	15.54	10.55	1.30	82400.26
9	6.08	1.50	57.60	2.58	15.29	10.74	1.35	81626.84
10	7.47	2.20	60.79	3.11	14.45	11.09	1.34	79072.89
11	8.96	7.58	58.04	3.11	14.07	10.84	1.33	80040.47
12	5.27	4.64	57.45	3.09	13.40	11.04	1.35	77986.15
13	2.21	1.86	62.11	2.89	13.35	11.04	1.33	76069.11
14	2.75	7.27	57.60	2.95	13.33	10.89	1.33	78980.09
15	10.24	5.95	66.66	3.06	15.04	11.11	1.33	76683.66
16	14.77	3.63	65.83	2.43	16.73	10.31	1.35	85531.93
17	15.44	6.80	59.39	2.81	15.00	10.89	1.33	83930.49
18	5.99	1.44	58.57	2.55	15.05	10.91	1.30	84347.18
19	5.86	1.11	60.21	2.51	16.04	10.86	1.31	84328.79
20	4.09	0.74	63.42	1.98	17.44	10.32	1.33	88852.01
21	7.00	0.92	61.95	2.19	16.02	10.69	1.33	84994.36
22	3.08	2.70	61.31	1.98	17.47	10.34	1.34	86814.97
23	9.11	3.97	54.36	2.16	18.40	9.70	1.35	88251.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.19	3.15	61.26	2.73	15.79	10.70	1.35	82860.57
最大值	15.44	7.58	70.87	3.40	18.40	11.65	1.38	89218.99
發生時間	17	11	6	4	23	6		5
最小值	2.21	0.74	54.36	1.98	13.33	9.70	1.30	76069.11
發生時間	13	20	23	20	14	23		13
零點偏移(率)	-0.01 %	-0.01 %	-0.14 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	2.42 %	-1.07 %	-0.36 %	0.26 %		0.43	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								