

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.39	1.66	50.51	0.13	18.33	11.65	1.33	68878.72
1	12.69	2.42	41.43	0.14	19.19	11.28	1.33	71017.96
2	12.23	3.11	51.88	0.21	19.15	11.31	1.33	71431.16
3	11.63	5.91	45.89	0.14	17.46	11.87	1.35	68056.34
4	11.71	7.53	53.52	0.09	17.86	11.50	1.34	70541.83
5	4.38	5.63	49.00	0.13	16.93	12.14	1.34	67881.60
6	13.45	5.77	53.73	0.09	17.51	12.16	1.33	66522.52
7	11.58	6.15	49.25	0.09	17.65	12.07	1.33	66938.62
8	10.78	6.76	52.56	0.11	17.87	11.90	1.36	67474.12
9	10.16	1.77	64.79	0.16	18.17	12.36	1.33	64070.75
10	12.71	1.42	49.86	0.15	18.59	12.04	1.34	66393.60
11	11.65	1.17	47.58	0.15	19.37	11.57	1.32	68201.97
12	16.29	0.99	42.85	0.15	20.23	10.82	1.32	72955.13
13	13.77	1.37	41.41	0.12	18.67	11.19	1.33	71827.88
14	12.12	1.11	54.45	0.16	19.10	11.60	1.33	68473.88
15	9.45	0.98	42.84	0.15	19.35	11.08	1.32	71641.87
16	10.35	1.41	48.96	0.14	18.47	11.69	1.33	67882.42
17	9.73	1.63	46.63	0.14	18.31	11.58	1.34	69582.23
18	9.42	1.31	51.90	0.16	18.91	11.66	1.34	68066.20
19	10.80	1.54	47.36	0.13	18.21	11.28	1.33	71531.41
20	12.23	4.84	44.44	0.09	16.49	11.90	1.34	68625.89
21	12.39	4.96	43.20	0.10	16.76	11.91	1.30	68547.26
22	14.81	2.29	46.50	0.13	18.38	11.54	1.31	70337.55
23	9.96	4.46	55.32	0.17	18.60	11.91	1.34	67350.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.49	3.17	48.99	0.13	18.32	11.67	1.33	68926.32
最大值	16.29	7.53	64.79	0.21	20.23	12.36	1.38	72955.13
發生時間	12	4	9	2	12	9		12
最小值	4.38	0.98	41.41	0.09	16.49	10.82	1.29	64070.75
發生時間	5	15	13	4	20	12		9
零點偏移(率)	-0.08 %	-0.01 %	-0.01 %	-0.01 %		0.03	0.00	0.00 %
全幅偏移(率)	0.03 %	0.02 %	-0.25 %	0.02 %		0.30	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.00	3.02	45.92	0.18	19.27	10.94	1.46	84443.86
1	12.66	4.90	38.57	0.13	20.50	10.10	1.46	89850.00
2	11.68	2.43	45.33	0.13	16.80	11.22	1.47	85145.48
3	11.55	2.66	43.51	0.13	17.13	11.29	1.45	83643.75
4	10.75	5.52	62.62	0.16	16.02	12.51	1.46	74268.37
5	12.86	2.00	47.71	0.54	18.83	10.80	1.46	86493.15
6	11.64	5.37	37.64	0.11	18.48	10.81	1.44	79172.08
7	13.00	9.23	40.44	1.98	17.45	11.05	1.44	84900.95
8	11.40	1.25	47.69	0.37	17.71	11.42	1.46	81811.14
9	12.59	1.51	41.21	0.11	19.42	10.45	1.46	87745.50
10	11.41	1.26	37.30	0.11	18.06	11.18	1.45	82515.76
11	12.15	1.42	50.77	0.12	17.52	11.83	1.45	78107.33
12	11.73	3.37	43.97	0.25	18.89	10.34	1.46	89284.92
13	12.95	0.64	54.15	0.12	18.49	11.11	1.45	84010.72
14	9.00	1.62	44.90	0.13	17.86	11.27	1.45	82878.38
15	8.90	5.14	52.02	0.13	17.97	11.18	1.44	82934.14
16	11.73	1.25	52.03	0.12	18.12	11.11	1.44	83666.93
17	9.96	1.32	61.55	0.17	18.06	11.72	1.45	79352.51
18	10.38	8.77	51.52	0.22	18.48	10.76	1.45	86915.12
19	11.21	2.50	48.67	0.13	17.80	10.91	1.44	86877.10
20	10.13	6.60	50.78	0.15	17.00	11.06	1.43	86551.62
21	11.37	0.82	53.33	0.17	18.72	10.91	1.43	86572.67
22	11.22	2.31	52.45	0.17	19.56	10.31	1.44	90258.23
23	9.33	3.79	53.12	0.19	19.73	10.97	1.44	84666.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.32	3.28	48.22	0.25	18.24	11.05	1.45	84252.74
最大值	13.00	9.23	62.62	1.98	20.50	12.51	1.49	90258.23
發生時間	7	7	4	7	1	4		22
最小值	8.90	0.64	37.30	0.11	16.02	10.10	1.42	74268.37
發生時間	15	13	10	6	4	1		4
零點偏移(率)	-0.10 %	-0.02 %	-0.01 %	0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	0.39 %	-0.32 %	-0.01 %	0.13 %		-0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.88	1.38	50.73	0.50	16.46	11.15	1.20	74439.99
1	9.84	3.45	58.12	0.42	15.86	12.22	1.21	66569.37
2	11.15	2.22	57.34	0.22	16.41	11.59	1.20	68508.33
3	12.75	1.49	54.41	0.82	17.42	10.18	1.19	76599.53
4	11.10	2.31	54.58	1.04	14.74	11.50	1.18	69776.87
5	12.07	3.63	47.68	0.48	16.00	11.54	1.18	69203.18
6	11.93	2.65	51.48	0.77	17.40	10.93	1.18	74462.70
7	12.58	6.15	68.40	0.81	17.65	10.03	1.20	80712.89
8	12.04	1.28	61.41	1.03	16.74	10.12	1.21	78489.56
9	11.53	3.59	50.33	0.99	16.17	10.61	1.20	79501.35
10	17.56	2.78	46.06	1.70	18.47	9.75	1.24	84925.21
11	11.46	1.97	51.17	2.05	18.08	9.51	1.19	79877.25
12	13.68	4.79	54.84	0.61	16.91	9.82	1.23	78843.11
13	11.30	3.92	52.15	0.20	16.42	11.03	1.24	72626.32
14	11.01	8.19	46.73	0.19	16.31	10.98	1.22	71933.47
15	11.95	14.02	48.02	0.47	15.63	11.22	1.20	74526.97
16	17.06	10.95	58.09	0.62	15.88	11.04	1.18	79528.13
17	3.75	3.48	54.50	0.21	16.06	11.15	1.18	78640.95
18	9.94	4.12	55.42	0.22	16.42	11.24	1.18	77832.53
19	12.01	2.98	62.73	0.29	17.27	10.47	1.22	82823.63
20	9.70	4.05	51.82	0.30	15.91	11.32	1.18	74683.47
21	9.02	4.53	59.60	0.06	17.02	11.56	1.18	68496.55
22	11.31	4.32	45.46	0.07	17.04	10.92	1.18	74797.78
23	10.02	2.96	61.89	0.03	17.78	11.36	1.18	70493.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.53	4.22	54.29	0.59	16.67	10.89	1.20	75345.54
最大值	17.56	14.02	68.40	2.05	18.47	12.22	1.25	84925.21
發生時間	10	15	7	11	10	1		10
最小值	3.75	1.28	45.46	0.03	14.74	9.51	1.15	66569.37
發生時間	17	8	22	23	4	11		1
零點偏移(率)	0.00 %	-0.03 %	-0.07 %	-0.01 %		0.02	0.00	0.00 %
全幅偏移(率)	0.32 %	0.33 %	-0.01 %	0.07 %		0.19	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								