

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.78	5.34	44.87	1.70	20.54	10.75	1.70	68259.77
1	13.37	1.74	39.46	0.14	20.94	10.32	1.68	70754.23
2	10.96	2.65	48.10	0.29	17.93	11.80	1.69	62612.63
3	13.34	1.68	52.67	0.12	19.47	11.44	1.70	65509.77
4	11.81	2.75	57.56	0.10	19.03	11.92	1.70	62281.08
5	12.73	2.63	55.76	0.08	20.16	11.21	1.62	65948.88
6	12.53	9.96	67.49	0.07	17.31	12.86	1.63	56562.53
7	10.77	8.26	66.26	0.09	19.60	12.09	1.62	61396.19
8	13.12	4.20	47.25	0.17	19.22	10.95	1.61	69148.82
9	13.10	4.89	44.76	0.16	20.45	10.36	1.65	71423.67
10	12.68	2.23	48.77	0.43	19.45	11.12	1.65	65792.34
11	12.91	1.68	47.36	0.17	19.51	10.86	1.65	67017.05
12	12.43	2.68	48.15	0.13	19.11	11.30	1.65	64447.21
13	13.29	1.48	53.23	0.08	19.40	11.52	1.65	64074.02
14	12.60	2.37	56.69	0.12	18.34	11.92	1.65	61917.47
15	10.75	2.97	59.31	0.10	18.96	12.20	1.66	60796.56
16	12.31	1.93	57.51	0.09	19.82	11.62	1.67	63632.50
17	12.03	1.88	42.56	0.14	21.52	10.56	1.68	69374.57
18	11.95	1.97	50.50	0.11	20.10	11.23	1.68	66418.45
19	12.32	1.36	47.19	0.10	19.90	11.22	1.65	66603.40
20	10.98	2.07	48.97	0.13	18.83	11.64	1.65	64199.83
21	9.78	4.23	55.87	0.17	18.27	12.19	1.65	60340.56
22	13.01	1.59	53.17	0.09	19.74	11.39	1.65	64780.98
23	13.57	2.15	45.07	0.19	20.19	10.70	1.65	69434.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.17	3.11	51.61	0.21	19.49	11.38	1.66	65113.65
最大值	13.57	9.96	67.49	1.70	21.52	12.86	1.71	71423.67
發生時間	23	6	6	0	17	6		9
最小值	9.78	1.36	39.46	0.07	17.31	10.32	1.59	56562.53
發生時間	0	19	1	6	6	1		6
零點偏移(率)	-0.02 %	0.00 %	0.00 %	-0.04 %		0.01	0.00	0.00 %
全幅偏移(率)	0.09 %	0.31 %	-0.06 %	0.39 %		0.14	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.80	3.86	53.60	0.25	15.81	12.28	1.53	75554.19
1	10.81	1.95	58.22	0.09	16.65	12.13	1.53	75541.95
2	6.94	7.25	47.27	0.14	17.94	10.93	1.52	77372.64
3	11.66	1.64	61.34	0.12	19.38	10.28	1.54	86719.20
4	11.75	6.39	45.66	0.13	18.75	10.74	1.55	85234.79
5	11.80	12.14	65.18	0.14	18.49	11.84	1.54	76245.82
6	8.87	1.64	68.07	0.16	19.35	10.87	1.61	81510.68
7	10.36	3.20	62.07	0.12	17.13	11.76	1.62	77815.18
8	13.38	2.30	45.05	0.10	18.32	10.90	1.62	84905.97
9	12.90	0.87	46.41	0.28	19.16	10.51	1.62	87667.75
10	13.18	0.58	52.14	0.20	19.30	10.31	1.62	89851.74
11	13.06	1.53	50.91	0.15	18.64	10.46	1.62	89345.60
12	11.86	1.86	61.43	0.18	18.89	11.37	1.62	79557.74
13	12.96	1.44	60.56	0.17	19.04	11.13	1.61	81383.64
14	11.19	2.45	66.61	0.12	16.63	12.45	1.60	71621.38
15	12.57	3.15	64.49	0.14	17.76	12.16	1.60	72988.56
16	11.99	1.71	59.09	0.15	17.52	11.90	1.60	75965.87
17	12.82	1.47	55.65	0.13	17.90	11.55	1.61	79922.48
18	13.21	1.95	43.87	0.12	19.12	10.34	1.60	89819.31
19	13.28	0.42	49.14	0.16	18.48	10.87	1.62	86004.93
20	11.96	5.07	46.80	0.11	17.97	11.10	1.62	84938.29
21	12.70	1.22	47.44	0.12	18.00	11.16	1.62	84837.97
22	13.12	1.32	46.04	0.11	17.83	11.29	1.62	81801.40
23	12.26	1.74	50.90	0.11	18.27	11.02	1.62	83725.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.93	2.80	54.50	0.15	18.18	11.22	1.59	81680.54
最大值	13.38	12.14	68.07	0.28	19.38	12.45	1.62	89851.74
發生時間	8	5	6	9	3	14		10
最小值	6.94	0.42	43.87	0.09	15.81	10.28	1.51	71621.38
發生時間	2	19	18	1	0	3		14
零點偏移(率)	-0.01 %	-0.00 %	-0.02 %	-0.04 %		0.00	0.00	0.00 %
全幅偏移(率)	2.09 %	0.30 %	-0.26 %	0.32 %		0.11	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.68	3.24	55.01	2.32	17.39	9.91	1.85	75569.51
1	11.69	3.29	52.01	2.24	16.40	10.42	1.85	72549.48
2	11.52	0.68	61.71	2.04	18.41	9.91	1.85	71998.84
3	13.22	3.50	46.92	1.96	18.63	9.72	1.85	74498.27
4	12.18	3.65	49.12	2.49	18.80	9.57	1.85	74347.58
5	13.71	10.56	40.67	2.44	17.58	9.93	1.85	71964.62
6	10.86	2.89	52.69	2.10	17.65	11.05	1.85	65304.89
7	8.58	5.22	63.84	1.97	17.95	11.38	1.77	59000.08
8	11.87	8.79	41.80	2.02	19.29	9.67	1.77	81011.02
9	13.63	4.39	42.70	2.20	16.82	9.87	1.81	77582.45
10	10.83	5.97	46.23	2.21	16.39	10.29	1.78	79278.78
11	13.60	1.29	50.28	2.15	17.82	10.38	1.77	74320.53
12	11.45	3.02	45.31	2.14	17.25	10.19	1.80	71933.58
13	11.74	3.16	43.38	2.13	17.67	10.17	1.78	70715.23
14	11.72	1.74	69.68	2.00	16.34	11.99	1.83	58493.76
15	10.85	1.26	69.01	1.90	17.05	11.78	1.84	60728.55
16	11.85	2.45	43.21	2.30	20.42	9.44	1.83	77555.56
17	11.52	7.85	57.96	2.85	19.21	9.38	1.85	78808.50
18	12.18	4.81	48.24	1.88	18.29	9.93	1.80	73765.10
19	14.43	3.89	48.49	2.26	18.97	9.43	1.80	80808.84
20	12.46	2.91	48.39	2.24	17.88	9.85	1.80	75520.23
21	14.30	2.84	50.69	2.34	18.05	10.00	1.81	77057.81
22	13.00	2.71	49.57	1.98	17.66	10.26	1.81	74221.31
23	12.87	2.41	49.20	2.45	17.43	9.92	1.81	73369.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.24	3.86	51.09	2.19	17.89	10.18	1.82	72933.50
最大值	14.43	10.56	69.68	2.85	20.42	11.99	1.87	81011.02
發生時間	19	5	14	17	16	14		8
最小值	8.58	0.68	40.67	1.88	16.34	9.38	1.75	58493.76
發生時間	7	2	5	18	14	17		14
零點偏移(率)	0.00 %	-0.02 %	-0.09 %	-0.02 %		-0.04	0.00	0.00 %
全幅偏移(率)	0.89 %	0.68 %	-0.08 %	0.23 %		0.20	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								