

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	16.20	6.32	46.21	1.90	15.82	11.97	1.51	82176.30
1	14.82	12.74	44.96	2.08	15.57	12.27	1.52	78048.77
2	16.03	4.51	45.19	1.97	15.34	12.11	1.51	79504.29
3	15.91	1.12	59.77	1.15	17.04	11.90	1.53	81923.52
4	15.55	2.79	67.76	0.73	17.60	11.65	1.54	83742.38
5	4.19	7.80	62.53	0.26	17.99	12.19	1.53	89303.36
6	7.22	7.22	68.11	0.25	18.68	11.96	1.56	79847.25
7	14.47	8.11	56.75	0.91	17.89	11.42	1.56	84545.68
8	13.14	4.66	50.69	0.70	18.18	11.64	1.53	80694.22
9	14.68	4.29	49.32	1.04	17.29	11.77	1.57	81371.89
10	13.43	6.07	42.62	1.03	17.09	11.80	1.53	80560.75
11	14.21	1.71	52.87	0.84	17.16	11.86	1.54	80319.71
12	13.16	4.22	46.20	0.78	16.68	11.91	1.57	81246.72
13	12.89	12.35	41.10	0.82	17.15	11.84	1.57	80569.23
14	14.06	18.54	60.24	1.56	16.39	12.14	1.57	78100.32
15	14.09	6.64	57.64	1.03	17.80	11.67	1.57	81847.14
16	14.67	6.70	49.95	1.33	16.51	11.82	1.56	80814.67
17	12.32	7.34	60.44	1.20	16.91	11.92	1.53	80094.93
18	11.88	6.09	67.08	1.16	18.06	11.45	1.56	83919.68
19	13.72	8.65	60.41	1.28	17.18	11.66	1.57	82881.70
20	15.35	9.33	58.78	1.58	16.56	11.83	1.57	81984.78
21	12.85	7.01	61.66	1.51	16.43	11.92	1.57	80804.96
22	12.74	1.61	65.92	0.66	19.53	10.93	1.57	86877.43
23	14.56	1.12	62.13	0.82	18.85	11.15	1.52	85964.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	13.42	6.54	55.76	1.11	17.24	11.78	1.55	81964.35
最大值	16.20	18.54	68.11	2.08	19.53	12.27	1.59	89303.36
發生時間	0	14	6	1	22	1		5
最小值	4.19	1.12	41.10	0.25	15.34	10.93	1.51	78048.77
發生時間	5	3	13	6	2	22		1
零點偏移(率)	-0.16 %	0.00 %	-0.02 %	-0.01 %		-0.04	0.00	0.00 %
全幅偏移(率)	3.30 %	-3.43 %	4.13 %	-1.88 %		0.03	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.84	4.91	54.91	1.02	14.08	11.55	1.42	85628.08
1	13.28	5.31	48.98	0.74	15.65	10.95	1.40	82640.95
2	12.84	5.68	66.34	1.57	14.86	11.23	1.40	83353.29
3	10.60	1.45	64.69	0.80	16.66	11.41	1.40	84793.83
4	13.88	10.16	58.87	0.61	16.53	10.71	1.39	85952.21
5	14.05	3.78	47.67	0.77	16.34	11.23	1.40	84111.94
6	10.99	24.23	43.18	0.36	17.29	10.22	1.40	76780.04
7	12.44	2.31	46.04	0.23	17.17	10.68	1.41	83201.43
8	12.93	15.12	55.93	0.24	17.34	11.10	1.45	81189.36
9	14.12	6.64	56.88	0.19	17.13	10.85	1.46	81121.60
10	14.50	1.01	52.72	0.23	16.33	10.83	1.46	82830.95
11	13.81	0.86	58.58	0.11	16.38	10.99	1.46	83542.18
12	14.05	1.38	51.19	0.53	15.81	11.03	1.44	82167.40
13	12.02	4.82	52.70	0.23	16.26	11.54	1.44	78610.15
14	11.14	4.21	71.79	0.16	16.78	11.27	1.45	82978.62
15	12.20	0.87	59.06	0.18	17.75	10.58	1.45	87781.31
16	13.98	4.37	46.62	0.46	16.17	10.99	1.44	84944.05
17	13.48	3.20	50.18	0.31	17.40	10.88	1.45	86678.37
18	0.86	1.38	68.56	0.10	17.07	11.13	1.46	86639.96
19	11.72	2.52	79.44	0.30	17.05	10.78	1.46	89206.86
20	13.52	0.94	70.89	0.21	17.37	10.98	1.45	85428.20
21	12.38	10.40	51.89	0.30	18.08	10.04	1.44	85169.01
22	12.26	2.27	53.80	0.14	18.55	10.21	1.44	80726.45
23	12.71	0.97	64.99	0.09	18.34	10.22	1.46	88210.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.48	4.95	57.33	0.41	16.77	10.89	1.43	83903.61
最大值	15.84	24.23	79.44	1.57	18.55	11.55	1.49	89206.86
發生時間	0	6	19	2	22	0		19
最小值	0.86	0.86	43.18	0.09	14.08	10.04	1.38	76780.04
發生時間	18	11	6	23	0	21		6
零點偏移(率)	-0.04 %	-0.01 %	-0.01 %	-0.04 %		-0.12	0.00	0.00 %
全幅偏移(率)	-0.01 %	0.04 %	0.02 %	0.04 %		0.27	-0.03	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.67	3.19	57.97	3.07	13.97	11.01	1.39	71998.21
1	14.69	1.28	64.74	2.34	16.68	10.31	1.40	73618.92
2	14.43	5.23	55.76	3.23	14.62	10.37	1.39	70967.60
3	15.26	1.91	47.34	2.80	16.40	9.85	1.39	72563.73
4	13.52	4.32	57.91	2.80	15.64	10.05	1.41	74846.24
5	13.71	2.68	54.86	2.06	16.73	10.10	1.40	72500.80
6	15.61	5.26	50.06	2.10	17.90	9.85	1.41	73582.28
7	14.71	4.94	53.41	2.31	16.58	9.82	1.44	76382.28
8	13.42	2.03	58.42	2.08	16.47	9.97	1.46	71640.65
9	14.18	2.36	58.09	2.13	16.35	9.69	1.46	72198.56
10	12.86	5.08	52.21	1.96	16.17	9.65	1.50	73847.05
11	13.77	10.41	48.40	2.02	15.15	10.07	1.46	72278.78
12	16.80	3.52	52.34	2.28	15.80	10.24	1.43	73573.06
13	12.02	3.85	45.95	1.93	16.42	9.91	1.43	69763.17
14	11.85	4.60	50.11	2.04	16.36	10.16	1.43	70714.86
15	12.58	2.05	54.49	1.99	16.34	10.69	1.43	66776.30
16	10.46	3.65	54.24	1.89	16.31	10.28	1.48	69427.17
17	11.61	7.14	50.38	1.89	16.51	9.78	1.43	74534.75
18	12.13	1.20	56.56	2.17	15.70	10.01	1.43	74001.32
19	12.36	0.92	61.85	2.01	16.26	10.88	1.43	68434.54
20	13.55	5.70	54.61	1.99	16.99	10.11	1.43	72377.10
21	13.40	7.94	52.43	2.20	15.82	10.44	1.45	71727.93
22	12.24	0.55	64.75	1.80	16.95	10.76	1.47	69840.45
23	13.38	0.53	65.46	1.91	17.91	10.27	1.48	71772.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	13.38	3.76	55.10	2.21	16.25	10.18	1.43	72057.02
最大值	16.80	10.41	65.46	3.23	17.91	11.01	1.51	76382.28
發生時間	12	11	23	2	23	0		7
最小值	10.46	0.53	45.95	1.80	13.97	9.65	1.38	66776.30
發生時間	16	23	13	22	0	10		15
零點偏移(率)	-0.25 %	0.00 %	-0.08 %	-0.04 %		-0.02	0.00	0.00 %
全幅偏移(率)	2.83 %	0.35 %	-0.22 %	0.11 %		0.24	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								