

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.60	4.30	57.18	0.07	18.31	11.72	1.42	62225.06
1	14.97	11.18	46.37	0.19	18.00	11.61	1.40	62681.17
2	14.60	15.64	45.95	0.97	15.30	12.07	1.38	62558.65
3	15.62	5.45	49.79	0.98	16.31	11.96	1.38	61987.26
4	12.28	7.67	45.91	0.35	17.38	11.75	1.38	62492.42
5	14.82	5.05	47.44	0.11	17.69	12.03	1.41	63372.47
6	14.24	4.29	49.29	0.08	18.30	11.66	1.42	61528.15
7	14.42	3.50	54.10	0.10	18.69	11.34	1.45	63663.32
8	14.30	4.32	43.05	0.08	18.52	11.54	1.46	62470.27
9	13.07	5.16	50.52	0.10	19.84	11.33	1.46	63502.13
10	14.59	5.25	44.21	0.12	19.38	10.91	1.42	66541.07
11	14.85	5.16	42.61	0.13	17.44	11.58	1.41	62928.71
12	22.32	9.30	47.16	0.16	17.65	12.11	1.41	61172.31
13	12.91	5.24	45.01	0.12	16.96	11.72	1.42	63471.68
14	14.10	4.69	41.89	0.24	17.24	11.59	1.45	64562.46
15	13.51	4.95	46.57	0.22	16.67	12.23	1.45	59256.85
16	14.13	3.51	59.82	0.17	17.66	11.54	1.42	64055.48
17	14.70	4.14	60.28	0.12	18.55	11.81	1.41	61692.56
18	14.90	4.66	52.78	0.07	17.48	11.71	1.41	62989.71
19	13.63	5.06	50.03	0.09	18.47	11.58	1.41	62755.98
20	14.50	7.46	42.48	0.12	18.16	11.42	1.41	64370.83
21	13.88	9.65	60.30	0.08	18.12	12.22	1.41	59096.78
22	14.91	5.22	55.08	0.09	18.74	11.62	1.43	62565.72
23	14.57	3.69	62.72	0.09	18.52	11.87	1.43	60693.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.56	6.02	50.02	0.20	17.89	11.71	1.42	62609.79
最大值	22.32	15.64	62.72	0.98	19.84	12.23	1.48	66541.07
發生時間	12	2	23	3	9	15		10
最小值	12.28	3.50	41.89	0.07	15.30	10.91	1.37	59096.78
發生時間	4	7	14	0	2	10		21
零點偏移(率)	0.00 %	-0.02 %	-0.01 %	-0.01 %		0.01	0.00	0.00 %
全幅偏移(率)	-0.15 %	-0.32 %	0.50 %	0.50 %		-0.02	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.26	3.70	56.17	0.14	19.64	10.52	1.44	67159.72
1	12.67	13.35	62.65	0.15	19.73	10.57	1.41	67182.34
2	14.24	7.34	71.70	0.26	17.32	10.79	1.40	67346.78
3	14.66	2.44	72.30	0.54	16.64	10.74	1.40	68184.30
4	14.70	2.64	68.18	0.29	16.96	10.65	1.42	67283.79
5	13.85	4.18	64.05	0.23	16.37	11.12	1.44	64628.49
6	11.81	2.56	76.88	0.12	17.48	11.70	1.50	59311.81
7	14.57	2.72	66.56	0.17	17.02	11.04	1.52	65071.96
8	11.84	8.97	55.45	0.29	16.33	11.20	1.51	65224.46
9	12.61	5.40	54.52	0.32	16.52	11.34	1.51	61861.85
10	14.62	4.04	54.33	0.10	17.99	10.97	1.48	64667.46
11	13.69	34.30	59.50	0.37	18.25	10.42	1.46	67807.44
12	16.86	2.98	55.54	0.25	17.76	11.05	1.46	66568.27
13	14.24	3.02	56.82	0.24	17.50	10.90	1.47	67651.11
14	13.66	2.37	47.55	0.15	18.84	10.44	1.49	68868.46
15	14.49	1.68	50.29	0.13	19.62	10.12	1.51	69450.93
16	14.94	9.49	63.22	0.12	19.26	10.52	1.49	66779.65
17	13.76	4.08	63.34	0.10	17.52	10.60	1.47	68417.09
18	14.41	2.89	59.76	0.15	18.62	10.69	1.46	66773.79
19	14.66	2.77	57.88	0.12	19.30	10.40	1.47	67433.52
20	14.59	2.51	49.59	0.10	18.75	10.35	1.48	68487.26
21	15.15	2.69	46.46	0.10	17.85	10.56	1.49	67705.37
22	13.43	4.63	44.08	0.13	17.37	11.07	1.51	63466.19
23	9.87	6.63	74.58	0.10	16.43	12.30	1.51	54892.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	13.86	5.72	59.64	0.19	17.88	10.84	1.47	65926.03
最大值	16.86	34.30	76.88	0.54	19.73	12.30	1.54	69450.93
發生時間	12	11	6	3	1	23		15
最小值	9.87	1.68	44.08	0.10	16.33	10.12	1.39	54892.69
發生時間	23	15	22	10	8	15		23
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.02 %		0.01	0.00	0.00 %
全幅偏移(率)	0.33 %	0.01 %	-0.38 %	0.68 %		0.26	-0.03	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.13	3.86	56.79	1.67	17.18	11.01	1.42	67387.25
1	13.53	27.53	57.73	2.22	19.47	10.25	1.39	72290.05
2	14.35	7.53	43.80	3.66	14.70	9.84	1.38	70818.50
3	14.71	5.07	44.15	3.79	13.88	10.11	1.39	70119.09
4	13.96	8.68	47.38	3.46	14.94	10.22	1.41	69492.97
5	14.19	5.51	47.24	2.07	17.28	9.69	1.41	71867.09
6	13.61	3.15	56.76	1.89	16.93	10.84	1.42	65231.39
7	14.29	6.62	40.08	2.19	17.54	9.52	1.41	78268.14
8	14.05	9.55	42.09	2.33	17.60	9.38	1.40	76391.78
9	14.80	3.22	46.41	2.25	17.70	9.75	1.38	74941.09
10	12.61	18.56	42.15	2.12	17.07	9.86	1.38	72744.14
11	2.89	8.10	41.55	1.39	17.29	9.69	1.38	70694.29
12	10.96	9.68	51.10	2.04	18.30	9.26	1.39	76170.78
13	11.82	3.61	49.71	2.33	17.12	9.45	1.38	76913.42
14	15.28	6.61	45.95	2.94	16.96	10.40	1.38	76998.82
15	13.45	3.67	48.34	2.74	17.77	10.55	1.37	75882.82
16	14.57	2.90	51.36	2.86	19.53	9.59	1.36	76908.07
17	10.16	2.90	53.06	2.35	15.49	10.72	1.37	73833.07
18	3.25	3.26	54.54	2.10	15.22	11.79	1.38	73464.20
19	2.64	2.60	48.42	1.60	16.35	11.00	1.38	80798.82
20	2.51	3.87	45.82	1.37	18.19	9.65	1.38	77552.34
21	3.74	3.47	53.24	1.59	17.39	9.96	1.38	76830.69
22	5.38	3.00	53.45	1.75	16.91	10.38	1.38	72797.33
23	2.47	3.19	53.09	1.42	17.51	10.44	1.38	69857.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.51	6.51	48.93	2.26	17.01	10.14	1.39	73677.25
最大值	15.28	27.53	57.73	3.79	19.53	11.79	1.43	80798.82
發生時間	14	1	1	3	16	18		19
最小值	2.47	2.60	40.08	1.37	13.88	9.26	1.34	65231.39
發生時間	23	19	7	20	3	12		6
零點偏移(率)	-0.12 %	0.00 %	0.00 %	-0.02 %		0.01	0.00	0.00 %
全幅偏移(率)	-0.08 %	0.04 %	-0.49 %	0.72 %		0.18	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								