

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.48	8.51	38.79	0.32	18.15	11.25	1.70	80970.57
1	10.57	5.89	63.10	0.10	19.48	11.93	1.69	77846.02
2	12.73	5.51	53.08	0.07	19.23	11.57	1.70	82328.15
3	12.22	10.12	57.70	0.08	18.37	12.41	1.71	76267.66
4	13.53	2.98	48.94	0.26	18.64	11.77	1.70	82345.78
5	15.58	13.84	33.86	0.18	17.54	11.49	1.68	82493.53
6	13.02	6.62	36.50	0.17	18.88	11.16	1.68	86354.84
7	15.30	7.30	36.65	0.44	17.53	11.52	1.69	84062.34
8	12.40	4.01	39.09	0.33	18.37	11.41	1.67	82226.76
9	15.41	1.92	40.15	0.27	18.87	11.05	1.68	85686.28
10	14.14	4.75	38.18	0.42	17.91	11.12	1.65	83924.55
11	14.04	10.33	34.82	0.50	17.58	10.91	1.66	83705.78
12	15.83	4.46	38.92	0.61	18.38	11.00	1.69	82761.82
13	14.38	3.17	38.18	0.20	18.76	11.01	1.70	83952.53
14	14.89	1.32	37.85	0.34	19.26	10.86	1.70	85154.23
15	12.95	8.68	47.16	0.17	19.73	10.60	1.70	85734.98
16	14.43	3.39	44.40	0.29	19.31	10.87	1.70	81807.60
17	13.66	2.46	52.47	0.14	19.01	10.98	1.70	83905.93
18	15.51	3.05	44.27	0.27	17.67	11.33	1.70	82117.29
19	18.14	4.51	39.38	0.45	18.48	10.91	1.67	85728.90
20	12.64	2.45	46.35	0.20	19.39	11.13	1.65	83882.80
21	13.88	1.84	47.92	0.20	19.43	11.39	1.66	83249.14
22	12.51	1.68	63.73	0.08	19.66	11.72	1.70	80371.10
23	14.23	1.20	57.71	0.11	21.20	10.71	1.70	87033.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	13.98	5.00	44.97	0.26	18.78	11.25	1.69	83079.65
最大值	18.14	13.84	63.73	0.61	21.20	12.41	1.76	87033.09
發生時間	19	5	22	12	23	3		23
最小值	10.57	1.20	33.86	0.07	17.53	10.60	1.65	76267.66
發生時間	1	23	5	2	7	15		3
零點偏移(率)	-0.01 %	0.00 %	-0.04 %	-0.01 %		0.03	0.00	0.00 %
全幅偏移(率)	1.21 %	0.06 %	-0.73 %	0.08 %		0.10	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.45	5.58	66.48	0.14	16.81	12.33	1.52	52778.96
1	14.11	2.46	68.49	0.16	19.09	11.76	1.51	55456.76
2	14.35	3.15	57.04	0.15	17.77	10.85	1.51	60920.63
3	13.63	3.01	52.05	0.17	17.25	11.13	1.50	59392.13
4	14.05	8.68	54.72	0.15	17.77	11.08	1.50	61871.45
5	14.01	3.10	56.35	0.12	17.63	11.03	1.50	61837.18
6	13.87	3.05	52.76	0.10	16.56	11.27	1.51	62616.98
7	14.16	2.32	59.25	0.13	16.48	11.16	1.52	62607.97
8	14.01	2.20	60.08	0.12	17.29	11.49	1.56	58323.84
9	14.34	5.04	59.46	0.10	16.83	11.16	1.57	61762.01
10	14.54	3.30	57.59	0.12	16.28	11.18	1.57	61967.25
11	14.03	14.27	70.51	0.16	16.58	11.31	1.56	58793.16
12	14.32	5.13	54.10	0.12	16.26	10.98	1.57	61104.19
13	14.11	2.59	59.86	0.10	16.81	11.42	1.55	56735.46
14	13.79	6.21	54.45	0.11	17.13	11.16	1.56	58615.01
15	13.89	3.57	61.65	0.13	17.43	11.27	1.57	59045.34
16	13.51	2.50	52.37	0.10	17.45	10.89	1.56	59202.43
17	14.12	2.50	57.82	0.15	18.06	11.33	1.56	58727.98
18	15.04	5.19	62.13	0.16	17.98	11.22	1.54	58256.54
19	12.28	5.38	67.01	0.13	17.04	11.58	1.53	56184.11
20	14.50	0.99	49.12	0.13	17.98	10.79	1.55	62146.77
21	14.90	3.29	57.14	0.16	18.24	10.90	1.56	62595.89
22	14.56	2.29	58.45	0.16	18.88	10.93	1.57	62075.32
23	13.15	2.43	54.58	0.14	18.31	10.89	1.57	62890.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.03	4.09	58.48	0.13	17.41	11.21	1.54	59829.49
最大值	15.04	14.27	70.51	0.17	19.09	12.33	1.57	62890.37
發生時間	18	11	11	3	1	0		23
最小值	12.28	0.99	49.12	0.10	16.26	10.79	1.49	52778.96
發生時間	19	20	20	6	12	20		0
零點偏移(率)	-0.19 %	0.00 %	-0.02 %	-0.01 %		-0.11	0.00	-0.10 %
全幅偏移(率)	1.99 %	0.92 %	0.18 %	0.37 %		-0.16	-0.03	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.50	4.98	49.62	1.06	17.43	10.16	1.49	73792.24
1	13.75	10.37	52.85	1.14	18.15	10.01	1.51	74877.81
2	13.38	3.55	49.05	1.40	18.17	9.85	1.51	75775.16
3	11.72	7.80	53.33	1.14	16.58	10.88	1.50	66799.57
4	13.16	3.75	52.32	1.26	16.29	10.94	1.51	65986.68
5	13.92	3.79	49.73	1.47	17.15	9.98	1.51	72910.44
6	14.18	10.16	52.90	1.52	15.95	10.42	1.53	73830.62
7	14.09	4.09	54.87	1.78	15.89	10.65	1.50	72001.84
8	13.29	3.63	52.91	1.29	16.91	10.14	1.51	72359.05
9	14.03	3.46	42.34	1.62	16.15	9.86	1.53	70899.66
10	14.08	6.35	43.64	1.47	15.32	10.14	1.54	70951.31
11	18.62	6.70	53.70	1.78	14.97	10.58	1.52	70502.45
12	14.47	5.93	54.39	1.19	17.07	10.07	1.50	72422.86
13	13.37	4.14	56.23	1.30	17.52	9.72	1.49	74193.17
14	12.62	2.73	52.90	1.01	17.56	9.95	1.50	73599.16
15	13.30	3.02	53.20	0.94	17.59	10.04	1.50	71655.07
16	10.07	3.37	60.15	0.95	19.63	9.30	1.54	75555.23
17	14.29	4.62	63.92	1.22	16.78	9.97	1.54	73846.57
18	14.83	6.07	41.22	0.66	18.40	9.97	1.55	73891.31
19	13.13	8.56	36.90	0.85	17.66	9.87	1.51	72117.45
20	17.09	5.39	39.06	1.14	17.65	9.71	1.50	74690.35
21	12.92	3.88	43.93	1.03	17.68	10.17	1.50	73120.12
22	11.55	11.00	40.72	0.99	16.90	10.41	1.50	79018.35
23	13.98	3.43	53.59	1.09	18.25	10.12	1.52	74733.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	13.68	5.45	50.14	1.22	17.15	10.12	1.51	72897.09
最大值	18.62	11.00	63.92	1.78	19.63	10.94	1.56	79018.35
發生時間	11	22	17	7	16	4		22
最小值	10.07	2.73	36.90	0.66	14.97	9.30	1.49	65986.68
發生時間	16	14	19	18	11	16		4
零點偏移(率)	-0.01 %	0.00 %	-0.11 %	-0.01 %		-0.03	0.00	0.00 %
全幅偏移(率)	-0.06 %	0.02 %	-0.10 %	0.02 %		0.29	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								