

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.31	3.15	49.52	0.09	19.39	11.19	1.67	66926.97
1	11.72	4.08	47.43	0.10	18.80	11.51	1.66	65139.96
2	12.55	5.36	64.41	0.10	18.66	12.21	1.70	59812.85
3	12.24	10.16	64.32	0.08	17.90	12.80	1.69	56717.94
4	12.51	3.10	54.32	0.09	19.73	11.35	1.69	66076.57
5	2.88	5.05	65.75	0.05	18.19	12.40	1.65	65670.01
6	12.30	4.48	58.12	0.33	18.30	11.67	1.65	64890.42
7	12.53	3.60	54.96	0.23	19.18	11.40	1.64	66153.19
8	13.86	1.63	56.68	0.23	18.65	11.50	1.64	65477.74
9	13.25	1.59	49.91	0.40	19.06	10.97	1.66	68856.94
10	12.73	3.41	50.72	0.37	18.14	11.32	1.65	66649.56
11	12.07	4.62	51.76	0.73	17.42	11.67	1.65	64024.99
12	13.66	1.01	48.41	0.58	17.67	11.43	1.65	65287.55
13	11.66	1.45	47.98	0.69	17.12	11.56	1.67	65104.55
14	13.35	1.06	53.62	0.66	17.68	11.54	1.70	64569.28
15	11.35	1.26	52.29	0.25	18.07	11.48	1.68	64746.46
16	13.19	0.81	48.24	0.24	18.38	11.42	1.66	65355.21
17	12.68	0.90	56.80	0.16	19.05	11.46	1.68	65013.64
18	12.58	4.67	72.14	0.09	17.70	12.78	1.67	56588.93
19	13.49	4.97	62.23	0.33	18.11	12.20	1.66	60314.77
20	11.87	5.10	56.24	0.06	19.08	11.74	1.66	64003.12
21	12.56	4.05	46.29	0.24	19.10	11.04	1.66	68510.68
22	12.57	2.23	50.71	0.18	18.54	11.59	1.67	64779.93
23	10.96	4.72	68.92	0.08	18.37	12.36	1.68	60194.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.16	3.44	55.49	0.27	18.43	11.69	1.67	64202.73
最大值	13.86	10.16	72.14	0.73	19.73	12.80	1.70	68856.94
發生時間	8	3	18	11	4	3		9
最小值	2.88	0.81	46.29	0.05	17.12	10.97	1.62	56588.93
發生時間	5	16	21	5	13	9		18
零點偏移(率)	-0.03 %	-0.01 %	-0.03 %	-0.01 %		-0.01	0.00	0.00 %
全幅偏移(率)	-3.65 %	0.63 %	0.04 %	0.44 %		0.01	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.98	3.38	51.47	0.09	17.22	10.82	1.57	86650.74
1	11.09	2.14	62.62	0.18	18.73	11.74	1.57	77424.65
2	11.75	4.74	67.59	0.13	16.43	12.83	1.57	69124.92
3	11.16	7.55	50.31	0.10	15.72	12.58	1.57	71207.46
4	12.13	3.23	38.95	0.11	16.44	12.07	1.57	75990.84
5	10.59	9.66	61.49	0.21	15.63	12.64	1.57	71802.01
6	10.31	3.80	71.02	0.07	15.05	12.52	1.61	82161.08
7	12.75	6.00	48.90	0.15	16.02	11.85	1.65	79507.23
8	12.70	2.22	43.41	0.15	17.42	10.91	1.64	85500.10
9	12.73	1.18	39.10	0.11	16.71	10.89	1.66	87097.40
10	13.17	3.03	42.77	0.08	16.79	11.21	1.65	83990.77
11	13.32	7.48	38.84	0.29	15.52	11.21	1.67	82178.03
12	12.77	2.80	38.36	0.51	15.91	11.14	1.67	82836.50
13	12.27	1.37	44.40	0.25	15.96	11.40	1.67	81237.47
14	13.05	0.90	47.77	0.11	18.10	10.77	1.67	86694.30
15	13.62	3.08	45.11	0.13	16.94	11.07	1.68	84685.00
16	11.37	4.87	70.05	0.08	15.99	12.61	1.65	71377.00
17	13.30	3.59	55.23	0.14	18.21	10.98	1.63	85018.18
18	12.92	4.15	53.23	0.10	17.11	11.12	1.64	85060.61
19	12.52	5.29	57.36	0.12	17.64	11.12	1.64	84468.24
20	13.42	4.60	51.07	0.16	16.46	11.08	1.64	87115.47
21	12.57	7.09	59.30	0.16	17.29	10.96	1.64	86738.60
22	13.51	1.03	65.44	0.13	18.33	10.62	1.65	88800.36
23	12.64	4.90	57.97	0.13	16.47	11.25	1.65	85384.22
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.44	4.09	52.57	0.15	16.75	11.47	1.63	81752.13
最大值	13.62	9.66	71.02	0.51	18.73	12.83	1.74	88800.36
發生時間	15	5	6	12	1	2		22
最小值	10.31	0.90	38.36	0.07	15.05	10.62	1.52	69124.92
發生時間	6	14	12	6	6	22		2
零點偏移(率)	-0.02 %	-0.05 %	-0.02 %	-0.04 %		-0.02	0.00	0.00 %
全幅偏移(率)	2.41 %	1.22 %	-0.62 %	0.29 %		-0.11	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.00	4.89	44.13	2.02	15.46	10.58	1.81	68011.10
1	12.44	3.32	59.16	2.13	16.06	11.36	1.79	63999.28
2	11.70	1.57	61.02	2.04	16.11	11.66	1.80	61471.70
3	12.06	1.88	62.38	2.19	15.87	11.71	1.80	60803.40
4	13.24	1.62	49.53	2.26	16.78	10.53	1.80	68508.39
5	12.48	4.05	39.95	2.13	16.21	9.97	1.80	71574.65
6	12.97	8.44	40.69	2.08	16.05	10.49	1.82	69533.79
7	18.42	14.75	41.33	3.24	15.66	9.97	1.77	71180.49
8	12.91	2.84	40.20	2.33	16.36	9.90	1.77	71885.87
9	12.73	1.85	41.46	2.23	16.56	9.89	1.78	73159.29
10	13.20	11.39	44.48	2.20	17.43	9.76	1.82	74655.26
11	13.11	9.03	37.40	4.25	14.75	9.97	1.82	69487.48
12	9.83	6.50	41.19	5.50	16.11	9.97	1.82	72745.08
13	14.09	4.70	41.93	3.31	14.97	10.19	1.82	70456.20
14	13.21	3.24	43.55	3.59	15.52	10.07	1.82	73180.55
15	11.92	6.97	45.35	2.51	16.06	10.11	1.83	74417.46
16	13.12	1.79	42.93	2.13	16.42	10.20	1.80	70478.74
17	11.87	3.35	53.28	2.83	15.15	11.33	1.83	64837.90
18	11.91	9.42	72.29	3.16	14.63	12.15	1.81	62838.24
19	13.98	8.57	60.87	2.88	17.16	10.23	1.80	79005.49
20	13.54	6.12	52.96	3.31	15.39	10.56	1.80	80379.46
21	12.75	10.04	51.01	3.18	15.25	10.67	1.80	77917.55
22	12.81	5.16	54.16	2.57	16.40	10.43	1.82	79607.08
23	12.30	4.56	56.53	2.48	15.74	10.65	1.82	75238.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.90	5.67	49.07	2.77	15.92	10.51	1.81	71057.20
最大值	18.42	14.75	72.29	5.50	17.43	12.15	1.85	80379.46
發生時間	7	7	18	12	10	18		20
最小值	9.83	1.57	37.40	2.02	14.63	9.76	1.73	60803.40
發生時間	12	2	11	0	18	10		3
零點偏移(率)	0.00 %	-0.00 %	-0.02 %	-0.03 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.04 %	0.37 %	-0.80 %	0.20 %		0.41	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								