

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月26日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.51	22.10	55.23	0.16	20.71	9.67	1.43	98821.56
1	14.06	5.90	46.15	0.12	19.36	10.24	1.43	96261.18
2	14.27	2.35	48.72	0.12	18.04	10.49	1.43	96101.65
3	13.37	11.58	49.37	0.11	18.88	10.21	1.43	95866.88
4	13.13	5.04	41.27	0.13	18.94	10.15	1.43	94567.30
5	14.54	11.49	46.94	0.11	18.98	10.07	1.45	95850.86
6	15.69	6.68	36.53	0.25	18.94	10.41	1.46	93347.43
7	15.20	7.85	37.45	0.12	19.49	10.15	1.46	93897.16
8	13.76	7.67	60.78	0.16	20.21	10.18	1.48	93931.25
9	14.37	1.70	60.06	0.15	19.15	10.35	1.50	94918.47
10	15.25	2.48	50.76	0.15	19.31	10.27	1.49	96613.94
11	14.29	1.67	40.50	0.16	20.38	9.85	無效	保養
12	13.86	2.74	43.08	0.17	19.49	10.18	1.40	91996.42
13	13.17	1.67	52.89	0.18	19.90	10.77	1.38	90060.51
14	12.72	6.16	35.67	0.16	21.26	9.98	1.40	95405.62
15	13.98	9.23	45.11	0.17	21.12	10.24	1.41	94009.06
16	14.38	3.70	53.95	0.16	21.70	9.92	1.42	95758.11
17	14.59	2.30	54.10	0.16	21.17	9.65	1.42	99703.88
18	14.87	1.87	55.52	0.16	19.77	10.14	1.39	97396.22
19	12.82	2.32	47.18	0.17	19.88	10.50	1.40	93035.36
20	14.62	9.97	49.23	0.17	20.37	9.97	1.43	98063.47
21	14.19	2.54	57.27	0.16	20.66	9.96	1.42	97810.88
22	15.10	2.14	56.97	0.15	20.78	9.79	1.43	99453.35
23	14.15	6.33	55.61	0.16	20.66	9.99	1.42	96642.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	23	23
平均值	14.16	5.73	49.18	0.15	19.96	10.13	1.43	95631.02
最大值	15.69	22.10	60.78	0.25	21.70	10.77	1.51	99703.88
發生時間	6	0	8	6	16	13		17
最小值	12.72	1.67	35.67	0.11	18.04	9.65	1.37	90060.51
發生時間	14	11	14	3	2	17		13
零點偏移(率)	-0.10 %	0.00 %	-0.10 %	-0.12 %		-0.20	0.00	0.00 %
全幅偏移(率)	2.69 %	-0.02 %	0.13 %	0.04 %		-0.09	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	95.83 %	95.83 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月26日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.86	6.36	51.53	1.37	16.20	10.58	1.44	70778.86
1	13.22	3.70	46.46	1.49	16.90	9.97	1.41	72469.03
2	15.39	10.18	49.91	1.36	17.13	10.37	1.42	72165.51
3	13.77	5.65	43.07	1.29	18.92	9.93	1.41	71073.74
4	14.49	7.34	39.11	1.85	16.42	9.67	1.42	72083.44
5	14.19	5.79	45.94	2.00	15.95	10.24	1.43	69371.90
6	13.70	16.41	50.00	2.00	18.23	9.23	1.41	75956.57
7	13.90	9.80	40.10	0.95	16.76	9.94	1.39	73095.30
8	12.80	6.61	51.01	0.62	16.84	10.49	1.38	65613.78
9	15.46	9.40	51.26	2.13	17.82	8.89	1.39	71418.37
10	13.84	2.85	67.28	1.65	18.05	9.12	1.40	78754.41
11	13.68	5.55	58.13	0.81	19.60	9.04	無效	保養
12	14.56	12.03	45.12	0.73	18.15	9.59	1.38	76025.16
13	12.45	4.63	40.86	0.35	18.89	9.93	1.38	74534.38
14	13.23	5.97	38.14	0.45	17.60	10.28	1.38	73399.10
15	14.41	2.07	38.59	0.62	18.50	9.91	1.38	74693.83
16	12.50	3.97	42.38	0.66	17.98	10.12	1.38	74228.99
17	13.27	3.03	51.38	0.79	18.08	10.27	1.38	72675.73
18	14.63	4.17	48.08	0.59	17.24	10.48	1.37	70761.47
19	13.91	3.70	49.48	0.87	17.66	10.26	1.38	71803.69
20	13.66	3.32	51.58	0.66	17.82	10.26	1.38	69315.10
21	14.06	13.37	45.05	1.12	15.88	10.29	1.40	72979.98
22	13.31	6.79	46.54	0.83	16.49	10.70	1.39	69565.61
23	13.56	4.52	44.53	0.80	16.88	10.25	1.38	72150.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	23	23
平均值	13.83	6.55	47.31	1.08	17.50	9.99	1.40	72387.60
最大值	15.46	16.41	67.28	2.13	19.60	10.70	1.50	78754.41
發生時間	9	6	10	9	11	22		10
最小值	12.45	2.07	38.14	0.35	15.88	8.89	1.35	65613.78
發生時間	13	15	14	13	21	9		8
零點偏移(率)	-0.02 %	-0.03 %	-0.34 %	-0.16 %		-0.04	0.00	0.00 %
全幅偏移(率)	-0.07 %	0.04 %	0.66 %	0.08 %		-0.10	0.02	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	95.83 %	95.83 %
備註								