

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.63	10.54	55.25	0.93	15.78	11.85	1.51	59854.31
1	11.36	25.88	52.13	0.35	17.16	11.80	1.50	61729.77
2	14.68	11.87	71.51	0.59	16.64	12.90	1.50	56049.99
3	13.42	4.87	54.69	0.43	17.95	11.63	1.50	63830.87
4	14.79	9.78	47.27	0.66	16.81	11.77	1.49	63481.56
5	15.53	17.12	51.81	1.01	16.04	12.18	1.50	57588.85
6	14.56	3.94	50.41	0.72	17.17	11.66	1.50	64316.60
7	14.23	13.67	53.33	0.88	16.35	12.04	1.51	62233.73
8	14.83	7.28	58.86	0.64	17.83	11.97	1.51	60889.31
9	13.85	6.43	59.94	0.38	18.10	11.68	1.51	63289.51
10	14.47	6.47	48.69	0.51	17.90	11.46	1.51	64280.56
11	13.76	5.38	64.64	0.32	17.85	12.13	1.47	59702.71
12	14.48	2.95	60.58	0.29	18.50	11.15	1.51	64896.60
13	14.29	3.62	55.96	0.39	18.18	11.24	1.53	65156.09
14	13.82	8.39	48.09	0.69	16.86	11.63	1.51	63649.48
15	15.13	6.45	55.01	0.41	17.67	11.78	1.52	62054.70
16	14.10	12.04	48.79	0.58	17.54	11.29	1.53	64522.77
17	13.99	13.04	51.84	0.81	16.41	11.82	1.51	62148.11
18	14.38	8.87	55.27	0.79	16.51	11.75	1.50	63081.07
19	15.34	6.58	54.85	0.67	16.88	11.70	1.46	63492.63
20	13.40	5.55	55.80	0.48	17.14	11.64	1.46	63889.80
21	13.54	3.17	59.47	0.52	17.24	11.48	1.46	64653.62
22	15.77	4.53	57.69	0.64	17.04	11.53	1.48	64328.16
23	12.85	6.15	56.40	0.41	17.49	11.63	1.50	63487.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	13.97	8.52	55.34	0.59	17.21	11.74	1.50	62608.66
最大值	15.77	25.88	71.51	1.01	18.50	12.90	1.54	65156.09
發生時間	22	1	2	5	12	2		13
最小值	8.63	2.95	47.27	0.29	15.78	11.15	1.46	56049.99
發生時間	0	12	4	12	0	12		2
零點偏移(率)	0.00 %	-0.03 %	-0.00 %	0.00 %		-0.39	0.00	0.00 %
全幅偏移(率)	1.53 %	0.14 %	-0.31 %	0.76 %		0.08	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.40	3.02	62.55	0.12	18.82	10.85	1.52	64547.76
1	14.11	2.62	50.55	0.13	19.39	10.66	1.53	65925.31
2	13.75	17.61	49.61	0.29	16.95	10.97	1.53	66078.52
3	14.87	7.37	49.63	0.35	17.00	10.82	1.52	65999.31
4	13.86	10.05	53.38	0.66	16.38	10.86	1.54	66791.56
5	14.73	14.99	60.00	0.38	17.77	10.60	1.57	67767.70
6	11.92	10.28	61.71	0.12	18.89	10.31	1.52	65142.24
7	13.47	1.69	59.15	0.19	17.51	10.70	1.51	67529.63
8	13.52	1.67	57.64	0.12	18.45	10.98	1.50	64372.13
9	14.96	2.13	52.54	0.35	17.59	10.55	1.49	68560.57
10	14.34	4.45	49.45	0.53	16.84	10.80	1.46	67250.44
11	14.33	2.37	55.58	0.18	18.55	10.61	1.48	66508.19
12	13.72	4.37	53.07	0.27	17.66	10.71	1.51	67346.80
13	14.01	8.98	53.09	0.28	18.14	10.60	1.47	66420.97
14	14.54	2.57	58.58	0.31	18.02	10.48	1.46	68324.20
15	14.13	1.65	56.52	0.18	18.31	10.40	1.46	68113.18
16	14.66	3.38	53.33	0.35	17.23	10.52	1.48	68125.94
17	14.53	3.67	53.54	0.51	16.55	10.83	1.51	66629.24
18	14.03	5.37	63.19	0.22	17.54	10.38	1.51	68778.02
19	14.52	10.00	59.81	0.21	17.87	10.51	1.51	68216.75
20	14.49	2.92	64.18	0.38	17.19	10.46	1.50	69007.03
21	13.36	2.29	55.65	0.33	17.70	10.47	1.47	68364.59
22	15.13	7.52	66.44	0.35	17.76	9.99	1.46	70785.44
23	12.03	2.26	56.36	0.30	16.99	10.63	1.46	65561.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.02	5.55	56.48	0.30	17.71	10.61	1.50	67172.81
最大值	15.13	17.61	66.44	0.66	19.39	10.98	1.63	70785.44
發生時間	22	2	22	4	1	8		22
最小值	11.92	1.65	49.45	0.12	16.38	9.99	1.45	64372.13
發生時間	6	15	10	0	4	22		8
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	0.00 %		-0.14	0.00	0.00 %
全幅偏移(率)	0.97 %	-0.01 %	-0.38 %	0.77 %		0.01	-0.03	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.30	5.19	60.79	2.05	16.98	11.16	1.36	65703.21
1	13.63	5.53	52.53	2.27	17.61	10.66	1.36	67978.01
2	13.88	6.08	59.41	2.39	15.91	11.17	1.37	66176.30
3	14.32	3.44	55.60	2.74	16.12	10.03	1.37	72845.03
4	13.76	7.40	60.34	2.97	15.05	11.08	1.36	64897.58
5	13.93	4.83	59.04	2.81	16.07	10.73	1.36	68354.53
6	14.23	3.61	62.73	2.33	16.52	10.62	1.35	68498.08
7	14.65	11.74	42.82	2.24	17.64	9.44	1.37	77528.20
8	14.42	11.03	48.07	2.53	18.47	9.51	1.38	74108.32
9	14.24	4.46	46.15	3.08	16.86	9.67	1.37	71667.52
10	14.39	4.44	43.86	2.89	17.38	9.61	1.37	70956.47
11	14.24	7.41	43.46	2.60	17.74	9.60	1.37	71617.41
12	14.14	4.38	46.80	2.64	18.09	9.65	1.36	72144.85
13	13.42	2.84	54.60	2.57	18.62	9.41	1.38	73840.83
14	14.60	13.48	57.75	2.79	18.38	8.97	1.37	74193.05
15	15.06	3.21	54.94	2.99	16.64	8.97	1.38	73646.19
16	13.21	16.21	55.06	2.79	16.05	9.77	1.38	77506.35
17	14.68	5.84	56.90	2.70	16.72	10.05	1.38	75129.78
18	14.94	4.11	59.41	3.00	15.74	10.13	1.37	74410.83
19	13.59	17.83	58.62	2.50	17.18	10.07	1.36	72791.03
20	14.63	9.04	58.75	2.90	16.06	10.14	1.34	76668.19
21	14.89	4.20	54.49	2.90	17.24	9.63	1.36	79479.94
22	14.91	8.10	54.11	2.91	16.07	10.35	1.37	73149.53
23	13.93	2.61	64.53	2.47	17.05	10.27	1.38	73011.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.17	6.96	54.61	2.67	16.92	10.03	1.37	72345.95
最大值	15.06	17.83	64.53	3.08	18.62	11.17	1.38	79479.94
發生時間	15	19	23	9	13	2		21
最小值	12.30	2.61	42.82	2.05	15.05	8.97	1.32	64897.58
發生時間	0	23	7	0	4	14		4
零點偏移(率)	0.00 %	0.00 %	-0.00 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.04 %	-0.08 %	-0.32 %	0.71 %		0.06	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								