

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.82	4.10	66.12	0.67	19.58	10.99	1.44	65236.75
1	13.98	3.61	70.40	0.57	19.87	11.03	1.43	64594.21
2	14.81	6.49	47.84	1.41	17.25	11.42	1.46	63822.04
3	14.64	8.78	46.68	1.57	17.15	11.47	1.47	64325.10
4	15.34	5.58	50.25	1.38	18.00	11.29	1.49	64969.41
5	14.73	8.73	48.99	1.37	17.84	11.53	1.49	62119.97
6	14.41	8.65	52.19	1.30	18.11	11.26	1.48	64279.71
7	13.17	16.43	58.73	1.37	17.09	11.64	1.49	62511.70
8	14.52	7.40	61.32	0.94	18.68	10.90	1.44	66250.18
9	15.45	6.06	54.40	1.23	17.40	11.20	1.44	64464.14
10	15.31	15.07	55.89	1.19	18.09	11.07	1.49	64901.42
11	14.43	7.04	58.87	0.96	19.03	10.68	1.47	66356.42
12	14.51	9.19	53.79	1.59	16.79	11.46	1.46	62714.57
13	14.27	13.10	57.26	1.28	17.82	11.58	1.47	62024.75
14	13.63	4.41	74.51	0.94	18.29	10.99	1.47	65782.73
15	15.61	4.67	60.98	1.29	17.14	11.36	1.46	63759.24
16	14.76	7.18	55.40	1.23	17.94	11.12	1.47	64347.96
17	12.75	6.58	59.13	1.02	18.45	11.43	1.46	62237.20
18	12.97	4.90	54.46	0.82	18.11	11.20	1.47	64163.22
19	13.67	6.45	55.30	0.96	18.24	11.42	1.50	62886.36
20	13.42	9.16	51.55	1.22	17.32	11.48	1.51	62768.00
21	14.60	6.98	47.23	0.87	19.12	11.06	1.46	65042.10
22	14.43	8.20	49.91	0.79	18.85	11.17	1.41	64614.03
23	13.85	6.35	46.65	1.04	17.85	11.25	1.45	64094.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.30	7.71	55.74	1.13	18.08	11.25	1.47	64094.41
最大值	15.61	16.43	74.51	1.59	19.87	11.64	1.51	66356.42
發生時間	15	7	14	12	1	7		11
最小值	12.75	3.61	46.65	0.57	16.79	10.68	1.41	62024.75
發生時間	17	1	23	1	12	11		13
零點偏移(率)	-0.06 %	0.00 %	0.00 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	2.16 %	0.02 %	-0.71 %	0.00 %		-0.04	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月24日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.33	7.06	49.78	0.22	17.85	10.39	1.41	67400.50
1	13.88	3.11	56.24	0.17	19.68	10.76	1.39	64405.02
2	14.44	3.49	56.27	0.30	19.00	10.43	1.42	68246.55
3	13.76	4.19	58.53	0.40	17.56	10.55	1.44	69094.27
4	13.96	2.63	62.86	0.19	19.16	10.61	1.46	67003.32
5	14.69	2.57	61.87	0.33	18.56	10.27	1.46	70023.94
6	12.19	3.24	60.93	0.43	17.11	10.91	1.44	69173.00
7	13.74	2.88	56.14	0.44	17.39	10.54	1.42	67962.37
8	13.81	3.30	52.04	0.34	17.75	10.67	1.41	65938.84
9	14.24	6.38	55.60	0.37	17.61	10.85	1.46	65794.01
10	12.22	7.93	55.23	0.17	18.18	10.68	1.41	67198.01
11	13.39	7.79	62.62	0.25	17.55	11.05	1.43	64915.69
12	14.03	23.46	58.08	0.47	17.43	10.87	1.45	65887.09
13	14.36	10.01	61.59	0.51	17.26	10.80	1.45	65861.10
14	13.98	3.33	49.14	0.60	18.26	10.40	1.44	66566.86
15	14.67	7.29	47.25	0.58	18.17	10.32	1.42	66081.18
16	13.94	13.08	54.96	0.45	18.89	10.18	1.41	66344.87
17	14.38	3.58	49.97	0.20	19.49	10.04	1.41	69030.51
18	14.43	18.10	60.28	0.19	19.99	9.97	1.39	70027.84
19	13.87	2.78	57.30	0.15	18.45	10.57	1.40	64754.71
20	13.89	4.53	48.44	0.13	19.95	10.07	1.44	65727.54
21	14.53	4.55	46.12	0.17	19.00	10.00	1.44	67017.02
22	14.44	15.05	52.76	0.49	17.88	10.22	1.42	68211.33
23	14.11	7.33	50.62	0.85	17.10	10.62	1.39	63751.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	13.97	6.99	55.19	0.35	18.30	10.49	1.42	66934.03
最大值	14.69	23.46	62.86	0.85	19.99	11.05	1.47	70027.84
發生時間	5	12	4	23	18	11		18
最小值	12.19	2.57	46.12	0.13	17.10	9.97	1.38	63751.08
發生時間	6	5	21	20	23	18		23
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.02 %		0.00	0.00	-0.20 %
全幅偏移(率)	1.21 %	0.18 %	-0.03 %	0.06 %		-0.02	-0.06	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.20	17.49	48.47	2.68	18.89	9.36	1.43	73708.15
1	14.60	3.93	51.55	2.21	21.78	9.69	1.43	71832.90
2	14.81	7.97	59.05	3.42	16.68	9.75	1.43	71604.79
3	14.44	10.00	54.99	3.17	15.95	10.04	1.43	70505.20
4	14.65	9.15	56.56	2.80	17.45	9.91	1.43	73061.57
5	14.97	3.19	58.48	3.02	17.38	9.76	1.43	75738.87
6	14.58	4.99	54.06	3.19	16.51	9.80	1.45	74239.44
7	11.49	6.27	52.44	2.24	17.17	9.92	1.48	67635.81
8	14.86	7.35	59.45	2.70	17.30	9.89	1.50	73742.71
9	15.25	36.52	55.57	3.22	15.40	10.36	1.49	78734.95
10	13.68	10.53	63.38	2.92	15.76	10.51	1.49	72574.60
11	14.60	4.28	71.47	2.73	17.43	10.59	1.48	69806.59
12	14.42	4.75	59.48	2.83	16.21	10.40	1.49	72060.10
13	15.13	4.95	62.58	2.98	16.35	10.45	1.49	72188.74
14	13.69	3.16	65.09	2.74	17.85	10.12	1.47	74117.15
15	14.41	2.80	57.98	2.67	18.23	9.82	1.45	74297.37
16	14.84	5.36	58.53	2.94	17.99	9.87	1.46	75776.65
17	14.68	4.88	55.83	2.72	16.03	10.54	1.48	73259.18
18	13.94	3.05	61.65	2.50	17.31	10.22	1.46	74143.58
19	14.54	3.52	60.92	2.54	17.22	10.29	1.46	72953.00
20	14.38	2.77	57.38	2.56	18.45	9.82	1.49	75243.47
21	14.21	4.15	55.61	2.33	18.50	9.72	1.46	76608.40
22	14.40	5.28	54.36	2.51	17.98	9.89	1.47	76067.49
23	14.45	10.75	57.18	2.56	17.82	10.03	1.46	70957.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.38	7.38	58.00	2.76	17.40	10.03	1.46	73369.09
最大值	15.25	36.52	71.47	3.42	21.78	10.59	1.51	78734.95
發生時間	9	9	11	2	1	11		9
最小值	11.49	2.77	48.47	2.21	15.40	9.36	1.43	67635.81
發生時間	7	20	0	1	9	0		7
零點偏移(率)	0.00 %	-0.01 %	-0.05 %	-0.04 %		-0.03	0.00	0.00 %
全幅偏移(率)	-0.63 %	0.41 %	-1.46 %	-0.35 %		-0.15	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								