

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.62	5.83	63.27	0.21	19.29	11.62	1.69	81021.71
1	10.42	4.46	64.04	0.16	19.92	11.62	1.70	80281.12
2	14.36	7.70	59.18	0.45	18.58	11.54	1.70	82717.97
3	13.10	8.22	44.87	1.19	17.22	11.19	1.70	83857.06
4	13.46	16.53	43.24	1.77	15.88	11.41	1.70	80427.64
5	12.01	8.04	41.78	1.08	17.60	11.12	1.70	75449.20
6	14.44	3.13	52.90	0.77	19.94	10.77	1.70	83933.85
7	13.18	3.26	50.80	0.93	18.87	11.08	1.69	83589.20
8	12.51	2.93	47.10	0.80	18.44	11.09	1.66	84422.73
9	12.74	1.29	49.45	0.64	19.56	10.65	1.69	87835.05
10	13.73	1.68	49.35	0.68	19.06	11.14	1.70	83532.67
11	13.02	1.45	53.47	0.45	19.05	10.95	1.68	86116.83
12	13.77	9.26	40.00	1.13	17.54	11.22	1.68	83700.01
13	12.98	3.86	44.95	0.76	17.89	11.29	1.70	80534.09
14	14.11	1.19	61.53	0.57	19.43	10.45	1.70	87337.09
15	15.41	11.86	58.38	1.25	16.46	11.32	1.69	81103.88
16	11.37	4.40	51.10	0.71	17.55	11.30	1.68	83186.15
17	12.82	1.15	54.62	0.45	18.85	10.74	1.70	88677.15
18	10.80	2.34	59.46	0.54	17.92	12.06	1.69	78228.48
19	13.89	1.71	54.30	0.31	19.68	11.09	1.70	84612.09
20	12.34	5.98	49.15	0.35	19.22	10.87	1.71	87206.77
21	12.17	6.61	50.07	0.36	19.10	10.76	1.73	87555.59
22	11.44	2.26	47.71	0.44	18.61	11.13	1.72	83843.92
23	11.87	5.20	54.63	0.34	19.15	11.00	1.74	85328.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.77	5.01	51.89	0.68	18.53	11.14	1.70	83520.76
最大值	15.41	16.53	64.04	1.77	19.94	12.06	1.75	88677.15
發生時間	15	4	1	4	6	18		17
最小值	10.42	1.15	40.00	0.16	15.88	10.45	1.65	75449.20
發生時間	1	17	12	1	4	14		5
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	0.03 %	0.04 %	-0.48 %	-0.02 %		0.20	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.87	4.03	55.18	0.16	17.86	12.03	1.50	55761.47
1	12.76	4.36	60.36	0.17	18.80	11.97	1.50	55285.59
2	15.09	7.27	62.15	0.14	17.95	11.70	1.50	56720.18
3	13.18	5.58	58.54	0.42	16.98	10.54	1.50	64742.50
4	14.34	3.08	57.23	0.91	16.11	10.65	1.51	61970.30
5	16.03	11.07	58.29	1.18	15.19	11.19	1.51	60128.73
6	15.02	0.98	57.43	1.05	18.51	10.95	1.49	59444.28
7	14.46	1.07	62.27	0.19	19.04	10.41	1.49	62545.47
8	13.78	0.42	72.42	0.14	19.05	10.61	1.49	61388.07
9	12.87	1.80	64.87	0.10	18.45	10.62	1.49	61852.22
10	13.27	2.10	57.89	0.15	17.47	10.60	1.49	60275.88
11	13.92	2.19	53.85	0.12	17.80	10.62	1.50	64558.41
12	13.65	2.17	63.86	0.35	16.96	10.70	1.52	64553.86
13	12.31	0.86	60.79	0.09	17.13	10.83	1.51	63018.29
14	12.62	2.41	53.70	0.23	15.98	11.28	1.51	59693.44
15	13.63	5.20	62.19	0.26	16.81	11.34	1.51	57939.72
16	13.04	4.03	62.10	0.37	16.73	10.65	1.51	62909.97
17	13.78	2.89	57.76	0.31	16.69	10.96	1.50	63382.22
18	13.91	11.28	55.62	0.27	16.14	11.45	1.46	59119.71
19	6.75	4.93	48.37	0.15	17.09	10.88	1.48	60882.05
20	12.14	3.06	50.15	0.13	19.04	10.42	1.49	63928.29
21	11.85	5.78	57.83	0.24	17.07	10.60	1.50	65430.92
22	11.93	2.61	51.54	0.30	17.58	11.01	1.50	62019.88
23	11.02	2.28	65.13	0.14	18.80	10.99	1.49	61638.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	13.05	3.81	58.73	0.32	17.47	10.96	1.50	61216.26
最大值	16.03	11.28	72.42	1.18	19.05	12.03	1.53	65430.92
發生時間	5	18	8	5	8	0		21
最小值	6.75	0.42	48.37	0.09	15.19	10.41	1.46	55285.59
發生時間	19	8	19	13	5	7		1
零點偏移(率)	-0.05 %	0.00 %	-0.00 %	0.00 %		-0.02	0.00	-0.10 %
全幅偏移(率)	0.72 %	0.74 %	0.17 %	0.25 %		0.02	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.85	4.54	50.05	1.99	17.71	10.55	1.67	69130.51
1	8.11	8.23	54.75	1.82	19.60	10.91	1.66	66889.77
2	11.40	6.49	53.71	2.12	18.85	10.26	1.66	71197.27
3	13.27	6.25	46.81	2.54	19.42	9.38	1.67	75090.29
4	17.13	12.61	48.57	2.99	16.57	9.71	1.67	77161.76
5	13.30	7.44	54.75	3.07	16.30	10.08	1.67	75820.61
6	13.29	12.41	56.08	3.08	16.74	9.57	1.67	73473.10
7	10.01	6.95	55.33	2.31	19.06	9.87	1.63	74406.42
8	12.18	7.17	48.03	2.18	19.39	9.69	1.65	74664.51
9	12.65	4.72	45.16	2.24	18.21	9.76	1.65	76992.45
10	12.68	6.01	44.09	2.13	18.95	9.54	1.67	76271.27
11	13.29	12.42	46.74	2.36	16.96	9.83	1.67	76409.76
12	12.87	7.19	54.13	2.60	16.90	9.90	1.64	74982.01
13	13.01	3.65	53.23	2.59	15.20	10.34	1.61	73188.35
14	13.30	5.89	57.77	2.60	16.02	10.49	1.62	68717.26
15	11.56	6.82	61.01	2.80	15.22	10.30	1.62	70911.17
16	12.96	3.92	58.92	2.55	15.94	10.16	1.64	73080.54
17	12.44	1.99	57.98	2.23	17.07	10.10	1.65	73183.06
18	11.11	2.14	57.86	2.20	16.69	10.51	1.62	68086.00
19	12.60	3.00	49.83	2.35	18.39	9.59	1.62	74326.47
20	13.38	10.18	52.35	2.18	18.12	9.68	1.63	79323.67
21	11.45	3.53	52.46	2.19	17.32	9.69	1.64	79480.39
22	13.31	6.82	54.52	2.45	17.93	9.90	1.63	75509.43
23	11.82	5.45	55.65	2.39	18.60	9.96	1.63	72619.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.42	6.49	52.91	2.41	17.55	9.99	1.65	73788.15
最大值	17.13	12.61	61.01	3.08	19.60	10.91	1.69	79480.39
發生時間	4	4	15	6	1	1		21
最小值	8.11	1.99	44.09	1.82	15.20	9.38	1.59	66889.77
發生時間	1	17	10	1	13	3		1
零點偏移(率)	0.00 %	-0.04 %	-0.00 %	-0.04 %		0.04	0.00	0.00 %
全幅偏移(率)	0.08 %	0.04 %	-0.31 %	0.04 %		0.37	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								