

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.61	5.83	67.66	0.04	18.30	11.70	1.67	74180.86
1	0.19	6.04	42.78	0.04	18.31	11.68	1.68	74303.48
2	4.44	4.46	51.19	0.05	19.94	10.69	1.67	80959.68
3	5.04	7.51	55.29	0.10	21.11	10.06	1.68	84836.30
4	5.35	1.67	62.53	0.08	19.15	11.25	1.67	77108.61
5	6.45	6.11	63.27	0.03	19.98	11.57	1.60	76246.37
6	5.63	4.13	67.52	0.04	19.82	11.50	1.57	74455.18
7	7.16	4.38	54.25	0.12	19.29	10.82	1.58	80230.73
8	10.94	13.03	52.06	0.11	20.73	10.30	1.59	82504.56
9	10.65	6.54	47.77	0.13	20.69	10.22	1.57	83565.13
10	10.43	3.53	38.66	0.13	20.05	10.33	1.58	82370.87
11	10.68	1.25	39.63	0.18	19.72	10.47	1.55	80288.81
12	13.83	14.35	32.07	1.39	20.44	9.50	1.54	80414.36
13	10.44	2.97	36.74	0.52	17.25	10.89	1.57	80342.66
14	10.48	3.72	37.86	0.16	18.93	10.40	1.58	78821.98
15	12.52	1.73	40.66	0.30	19.07	10.53	1.56	80137.89
16	8.33	0.37	54.93	0.11	19.91	10.61	1.56	80008.34
17	9.71	0.56	52.29	0.09	20.35	10.42	1.59	80799.53
18	9.55	1.40	42.70	0.22	18.98	10.79	1.58	79176.08
19	8.61	1.07	53.28	0.08	19.94	10.64	1.57	78777.97
20	9.68	6.88	42.19	0.26	18.43	11.09	1.57	79293.52
21	9.98	4.48	55.97	0.44	18.10	11.81	1.57	73398.85
22	15.08	3.62	51.57	0.20	19.14	10.95	1.56	79758.06
23	9.93	2.86	45.13	0.12	19.90	10.64	1.53	81723.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.61	4.52	49.50	0.21	19.48	10.79	1.59	79320.98
最大值	15.08	14.35	67.66	1.39	21.11	11.81	1.70	84836.30
發生時間	22	12	0	12	3	21		3
最小值	0.19	0.37	32.07	0.03	17.25	9.50	1.51	73398.85
發生時間	1	16	12	5	13	12		21
零點偏移(率)	-0.07 %	-0.00 %	-0.01 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	1.19 %	0.83 %	-0.94 %	0.26 %		0.11	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								



P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.64	9.19	54.58	1.83	15.21	10.78	1.28	75960.96
1	6.98	1.67	47.77	1.26	17.23	9.87	1.28	82900.45
2	7.87	1.95	44.74	2.89	16.44	9.99	1.27	81482.55
3	6.83	0.71	48.38	1.94	15.93	10.22	1.29	83280.75
4	7.72	2.35	50.94	1.81	17.73	10.16	1.30	82338.49
5	5.18	5.66	46.59	1.46	18.94	9.73	1.29	82844.83
6	9.29	8.87	41.24	1.73	17.31	10.04	1.28	80648.80
7	12.10	6.32	42.91	4.75	18.50	9.08	1.31	81234.48
8	10.98	0.31	45.09	4.29	15.66	10.38	1.30	76511.20
9	12.70	1.85	58.07	3.48	15.21	11.27	1.30	80696.48
10	9.79	4.44	56.77	2.58	15.01	11.38	1.30	83174.65
11	6.22	16.88	58.85	4.71	13.12	11.61	1.30	78015.67
12	1.60	8.11	60.38	2.60	13.69	11.55	1.28	76283.77
13	12.59	9.27	55.42	4.26	13.51	11.11	1.29	77074.43
14	11.40	13.31	50.78	4.53	13.69	11.02	1.29	77839.14
15	13.79	10.46	55.60	6.56	14.33	10.68	1.27	77502.22
16	18.01	9.28	53.03	6.27	15.91	10.39	1.26	78191.94
17	11.46	4.11	53.98	3.99	14.68	10.75	1.28	77291.29
18	12.51	4.97	50.25	3.42	14.03	10.67	1.29	77558.60
19	8.55	3.81	54.86	2.22	15.40	10.32	1.28	76237.29
20	7.26	2.46	51.89	1.49	16.53	10.32	1.30	82528.70
21	8.57	8.81	46.46	1.86	15.01	10.35	1.30	81035.11
22	8.10	6.79	49.96	2.14	15.12	10.41	1.27	76439.03
23	10.37	5.12	54.29	1.87	16.59	9.84	1.30	81815.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.48	6.11	51.37	3.08	15.62	10.50	1.29	79536.94
最大值	18.01	16.88	60.38	6.56	18.94	11.61	1.33	83280.75
發生時間	16	11	12	15	5	11		3
最小值	1.60	0.31	41.24	1.26	13.12	9.08	1.25	75960.96
發生時間	12	8	6	1	11	7		0
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.03 %	0.03 %	-0.27 %	0.03 %		0.16	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								