

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月26日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.32	4.87	64.23	0.05	18.82	12.12	1.65	61543.61
1	12.85	4.07	52.22	0.08	18.98	11.98	1.66	62575.16
2	12.26	5.17	52.85	0.08	18.56	12.24	1.66	60952.65
3	11.00	4.17	47.34	0.11	21.19	10.44	1.67	70591.13
4	12.92	4.38	32.84	0.14	19.49	10.72	1.68	70191.22
5	2.92	5.07	38.78	0.07	18.11	11.44	1.66	70401.12
6	13.14	5.27	41.09	0.30	18.37	11.22	1.68	68117.34
7	11.72	4.42	52.85	0.10	20.36	10.69	1.70	70192.02
8	13.24	2.51	41.44	0.24	18.79	11.15	1.66	66267.49
9	13.35	1.21	50.12	0.16	19.39	11.01	1.66	66820.35
10	13.68	1.50	51.84	0.37	19.04	10.90	1.69	67028.00
11	12.56	4.69	29.95	0.41	18.43	11.08	1.68	66969.82
12	12.06	11.18	44.21	0.34	17.40	11.29	1.66	64927.26
13	13.02	2.39	52.96	0.28	18.04	11.46	1.69	63478.24
14	12.86	1.54	63.53	0.35	17.79	11.38	1.70	64849.88
15	12.11	1.11	61.95	0.16	18.90	11.69	1.70	62942.66
16	10.35	1.78	64.29	0.09	19.52	11.47	1.70	65937.76
17	13.58	2.06	49.78	0.12	19.15	11.14	1.71	68046.14
18	13.23	1.80	44.86	0.20	19.21	11.25	1.70	67644.24
19	12.53	1.58	41.47	0.34	19.42	11.26	1.70	66862.77
20	13.26	2.96	36.57	0.53	18.05	11.46	1.70	66005.97
21	13.93	1.92	39.56	0.43	18.34	11.57	1.71	65367.67
22	12.10	1.53	49.94	0.52	18.02	11.50	1.71	66178.83
23	12.01	3.07	57.98	0.30	17.84	12.29	1.70	60901.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.17	3.34	48.44	0.24	18.80	11.36	1.68	66033.02
最大值	13.93	11.18	64.29	0.53	21.19	12.29	1.72	70591.13
發生時間	21	12	16	20	3	23		3
最小值	2.92	1.11	29.95	0.05	17.40	10.44	1.65	60901.08
發生時間	5	15	11	0	12	3		23
零點偏移(率)	-0.09 %	0.00 %	-0.03 %	-0.01 %		0.02	0.00	0.00 %
全幅偏移(率)	2.94 %	0.97 %	-0.51 %	0.36 %		0.00	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月26日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.70	7.50	63.92	0.14	15.69	12.46	1.41	71718.82
1	10.35	3.82	無效	0.13	16.84	12.62	1.41	70688.75
2	11.55	2.19	無效	0.11	17.03	11.87	1.41	77723.86
3	11.96	3.97	54.45	0.19	18.76	10.55	1.41	88814.88
4	14.06	3.87	54.32	0.64	16.94	10.76	1.41	88445.07
5	12.68	7.88	45.66	0.68	16.65	10.87	1.42	85361.29
6	15.73	0.59	59.65	0.49	17.56	10.59	1.47	88816.11
7	12.23	1.03	55.75	0.57	16.87	10.96	1.50	85106.88
8	12.81	0.77	55.43	0.21	17.41	10.98	1.49	84997.54
9	12.48	1.79	60.77	0.14	16.48	11.75	1.49	79802.13
10	13.11	8.36	57.64	0.09	16.98	11.11	1.49	84113.43
11	13.12	1.54	67.89	0.31	16.73	11.16	1.53	84744.76
12	12.97	4.34	53.84	0.23	15.88	11.38	1.52	83301.38
13	13.13	1.95	55.28	0.38	15.49	11.49	1.51	83480.60
14	13.38	5.87	53.30	0.83	14.44	11.62	1.52	83239.93
15	12.50	3.36	62.09	0.18	16.97	11.49	1.51	80902.15
16	12.82	2.27	61.11	0.15	17.05	11.58	1.51	79515.92
17	13.46	2.42	56.93	0.25	16.91	11.47	1.51	81170.47
18	13.29	4.74	56.08	0.80	17.38	11.05	1.52	85193.03
19	12.17	0.64	66.63	0.24	18.13	10.83	1.51	86085.80
20	14.80	7.16	56.25	0.96	16.10	11.00	1.49	84803.56
21	11.48	2.32	55.56	0.38	17.33	11.16	1.49	83559.75
22	12.99	5.00	47.64	0.42	17.32	11.03	1.49	84193.89
23	12.60	1.83	62.50	0.12	17.30	11.79	1.49	77156.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	22	24	24	24	24	24
平均值	12.64	3.55	57.40	0.36	16.84	11.32	1.48	82622.37
最大值	15.73	8.36	67.89	0.96	18.76	12.62	1.55	88816.11
發生時間	6	10	11	20	3	1		6
最小值	7.70	0.59	45.66	0.09	14.44	10.55	1.40	70688.75
發生時間	0	6	5	10	14	3		1
零點偏移(率)	-0.01 %	0.00 %	-0.03 %	-0.03 %		0.03	0.00	0.00 %
全幅偏移(率)	1.71 %	0.94 %	-0.07 %	0.39 %		0.16	0.00	0.10 %
有效比率	100.00 %	100.00 %	91.67 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月26日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.84	11.74	46.36	2.31	19.45	9.22	1.79	77892.20
1	12.86	4.98	44.61	2.16	18.05	9.71	1.80	76761.68
2	11.46	2.05	48.20	2.22	18.16	10.09	1.80	73470.98
3	12.74	2.13	51.69	2.44	20.18	9.59	1.80	80427.84
4	12.83	4.81	43.17	2.66	18.33	9.96	1.80	72994.22
5	13.10	2.55	44.04	2.96	16.92	10.02	1.82	71666.26
6	13.36	4.45	48.55	3.42	17.09	10.05	1.85	73265.04
7	11.72	3.84	51.53	3.59	16.28	10.35	1.81	70631.52
8	11.18	5.98	50.44	2.23	17.98	10.02	1.83	72140.21
9	12.87	6.73	50.06	2.46	18.07	9.74	1.80	76345.68
10	14.07	6.47	48.68	2.28	17.44	9.94	1.82	77524.14
11	11.49	6.16	41.42	1.68	16.93	10.34	1.86	76813.10
12	13.02	3.49	52.55	2.46	15.75	10.31	1.84	74369.76
13	11.08	3.38	43.39	2.40	14.83	10.68	1.81	70502.35
14	13.06	2.20	52.52	2.99	14.88	10.80	1.81	70082.82
15	11.52	1.35	58.86	1.99	17.18	10.83	1.82	66726.78
16	14.90	1.15	56.99	2.98	18.26	9.64	1.84	77137.15
17	14.03	2.46	51.95	2.28	16.68	10.25	1.84	74267.59
18	11.67	2.72	46.30	2.24	16.16	10.52	1.82	72593.29
19	12.69	1.39	46.31	2.20	15.92	10.40	1.87	72994.20
20	12.78	0.74	49.07	2.53	16.38	10.28	1.87	71036.05
21	13.10	2.06	50.17	2.68	16.43	10.43	1.83	70391.55
22	12.36	1.49	52.84	2.26	16.91	10.59	1.89	70073.87
23	11.98	4.22	46.89	1.77	18.20	9.80	1.89	75015.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.65	3.69	49.02	2.47	17.19	10.15	1.83	73546.83
最大值	14.90	11.74	58.86	3.59	20.18	10.83	1.91	80427.84
發生時間	16	0	15	7	3	15		3
最小值	11.08	0.74	41.42	1.68	14.83	9.22	1.77	66726.78
發生時間	13	20	11	11	13	0		15
零點偏移(率)	-0.03 %	0.00 %	-0.19 %	-0.04 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.29 %	0.58 %	-0.27 %	0.19 %		0.39	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								