

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.56	7.34	69.34	1.17	16.68	11.24	1.41	65051.68
1	15.02	3.40	69.52	1.19	18.14	11.43	1.41	62651.46
2	14.84	6.71	58.06	2.26	14.93	11.86	1.41	61748.91
3	13.43	14.40	57.92	1.69	15.84	11.82	1.41	61768.97
4	13.94	8.93	63.64	1.51	16.08	11.87	1.41	62455.81
5	14.85	7.61	63.86	1.11	17.59	11.60	1.37	61561.79
6	15.08	7.41	51.65	1.17	17.21	11.35	1.37	64346.82
7	12.63	9.81	71.22	1.35	16.13	12.20	1.38	59237.07
8	13.83	10.13	58.82	1.28	16.91	11.76	1.40	61189.72
9	14.09	7.25	59.30	1.49	16.15	11.70	1.42	62575.71
10	13.23	9.10	56.13	0.94	17.72	11.58	1.44	62228.70
11	13.93	5.68	58.20	1.07	17.24	11.43	1.41	63757.23
12	14.21	5.86	63.45	0.93	17.49	11.73	1.42	62257.11
13	11.84	5.58	66.11	0.85	17.65	11.76	1.41	61413.59
14	14.51	16.93	67.87	0.73	17.88	11.89	1.41	59069.12
15	14.06	6.21	61.80	0.81	17.80	11.57	1.41	61613.87
16	14.57	4.85	62.19	1.02	17.25	11.35	1.42	63646.18
17	13.85	8.18	57.11	0.80	17.92	11.51	1.43	62243.87
18	14.39	4.38	65.19	0.71	18.52	11.45	1.43	62688.86
19	13.70	4.50	56.80	0.78	17.92	11.48	1.45	62086.07
20	13.21	7.06	55.09	0.54	19.41	11.17	1.43	63692.13
21	14.65	7.14	44.74	0.86	18.68	11.19	1.41	63181.06
22	14.42	7.14	58.49	0.74	18.26	11.59	1.41	60981.23
23	13.96	5.77	68.23	0.54	18.87	11.77	1.40	60113.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.03	7.56	61.03	1.06	17.43	11.60	1.41	62148.35
最大值	15.08	16.93	71.22	2.26	19.41	12.20	1.46	65051.68
發生時間	6	14	7	2	20	7		0
最小值	11.84	3.40	44.74	0.54	14.93	11.17	1.36	59069.12
發生時間	13	1	21	20	2	20		14
零點偏移(率)	0.00 %	0.00 %	-0.06 %	-0.01 %		-0.07	0.00	0.00 %
全幅偏移(率)	0.80 %	-0.24 %	-0.32 %	0.72 %		-0.01	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.53	2.57	63.37	0.27	17.40	10.46	1.38	67748.04
1	13.69	9.55	52.11	0.43	16.90	10.88	1.38	65585.93
2	14.53	19.17	59.23	0.52	17.08	10.46	1.38	69220.10
3	14.49	3.31	62.80	0.51	16.84	10.91	1.38	66173.27
4	15.00	12.04	62.35	0.17	18.16	10.49	1.38	67890.06
5	14.65	11.31	57.15	0.19	17.61	10.71	1.38	66183.78
6	14.26	2.61	62.11	0.26	17.66	10.50	1.38	69108.56
7	13.41	2.66	57.34	0.42	16.79	10.63	1.38	65437.31
8	14.08	4.37	60.11	0.44	16.27	11.03	1.39	63659.58
9	14.26	4.67	57.17	0.80	15.84	11.08	1.40	64532.73
10	14.44	12.18	57.35	0.54	16.44	10.95	1.37	67068.89
11	14.25	7.82	65.43	0.16	17.41	10.75	1.41	66829.39
12	13.27	4.12	59.14	0.22	16.55	10.87	1.38	67106.25
13	14.95	20.71	59.19	0.21	16.92	11.11	1.38	64207.60
14	14.00	6.73	62.20	0.16	17.44	10.62	1.38	67127.94
15	13.89	11.83	55.26	0.21	16.42	10.95	1.39	64147.54
16	13.28	6.57	54.16	0.30	16.88	10.91	1.38	64803.48
17	13.28	16.71	62.04	0.18	18.31	10.44	1.38	66589.53
18	14.76	7.90	57.03	0.11	18.54	10.36	1.36	66998.52
19	13.53	5.36	45.00	0.10	18.37	10.37	1.36	66523.77
20	12.59	11.94	51.75	0.27	17.42	10.67	1.36	66649.92
21	14.00	6.53	54.84	0.12	17.45	10.66	1.37	66846.98
22	14.54	2.54	55.57	0.10	18.44	10.75	1.38	65919.87
23	14.88	3.29	58.11	0.11	19.31	10.41	1.39	67518.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.11	8.19	57.95	0.28	17.35	10.71	1.38	66411.55
最大值	15.00	20.71	65.43	0.80	19.31	11.11	1.43	69220.10
發生時間	4	13	11	9	23	13		2
最小值	12.59	2.54	45.00	0.10	15.84	10.36	1.34	63659.58
發生時間	20	22	19	19	9	18		8
零點偏移(率)	0.00 %	-0.02 %	-0.04 %	-0.02 %		0.03	0.00	-0.20 %
全幅偏移(率)	1.68 %	0.56 %	-0.19 %	0.84 %		0.06	-0.03	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.26	13.53	57.94	3.19	17.04	9.77	1.43	81703.80
1	14.71	8.91	58.59	3.30	18.89	9.92	1.44	82839.36
2	14.17	14.53	57.39	3.44	15.93	10.45	1.44	77936.66
3	14.54	9.76	62.96	3.74	17.26	9.97	1.44	80043.38
4	13.89	4.40	64.07	3.86	16.19	10.75	1.43	72606.92
5	13.53	3.91	78.16	3.41	16.75	10.75	1.43	67136.51
6	14.32	5.02	71.46	3.67	16.36	9.98	1.43	74641.48
7	12.97	5.07	53.39	3.13	17.28	9.73	1.43	81107.61
8	12.69	10.73	60.96	2.58	17.65	10.12	1.43	65899.00
9	14.89	14.87	49.54	3.21	19.05	8.52	1.43	71316.74
10	14.31	31.55	39.21	3.18	17.80	8.87	1.43	73472.04
11	15.03	15.19	37.27	2.84	16.88	9.06	1.43	69755.36
12	14.42	6.71	38.58	2.73	16.01	9.51	1.43	68708.64
13	14.41	20.25	41.57	2.59	17.29	9.25	1.43	70329.13
14	13.99	11.18	37.74	2.87	16.97	9.31	1.42	70263.86
15	14.04	7.72	37.99	2.69	16.06	9.96	1.41	70688.03
16	14.58	12.23	45.67	2.76	17.68	9.93	1.43	72416.63
17	14.62	5.13	45.94	2.68	17.30	9.78	1.43	76211.11
18	13.37	2.86	55.04	2.50	17.31	10.34	1.43	71157.17
19	14.67	4.79	63.98	2.87	17.26	10.32	1.43	73129.03
20	15.36	12.45	58.48	2.87	17.55	9.97	1.42	74502.24
21	14.06	14.76	50.57	3.62	14.58	9.92	1.43	71300.38
22	14.63	4.85	48.57	3.13	17.07	9.60	1.43	72625.01
23	14.19	12.12	46.85	3.33	17.27	9.45	1.43	72918.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	14.24	10.52	52.58	3.09	17.06	9.80	1.43	73446.19
最大值	15.36	31.55	78.16	3.86	19.05	10.75	1.46	82839.36
發生時間	20	10	5	4	9	4		1
最小值	12.69	2.86	37.27	2.50	14.58	8.52	1.39	65899.00
發生時間	8	18	11	18	21	9		8
零點偏移(率)	-0.01 %	-0.01 %	-0.12 %	0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	0.84 %	-0.44 %	-0.48 %	0.65 %		0.15	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								