

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.19	8.27	46.95	0.11	21.53	10.24	1.52	83079.51
1	8.80	2.04	47.47	0.07	20.00	10.83	1.51	79993.35
2	4.64	1.77	62.66	0.08	20.17	11.85	1.52	71811.04
3	6.48	1.32	70.36	0.18	20.05	11.60	1.55	74088.76
4	7.48	13.01	46.71	0.17	22.64	9.97	1.54	84562.61
5	7.10	3.79	45.47	0.29	19.69	10.67	1.51	82271.16
6	7.59	4.18	48.31	0.25	19.22	11.11	1.51	78036.73
7	2.14	3.74	69.53	0.03	19.39	12.05	1.51	68706.48
8	3.14	9.17	48.16	0.10	21.75	10.21	1.50	81455.01
9	9.14	3.32	38.04	0.09	21.04	10.25	1.50	83078.00
10	9.47	4.85	42.92	0.13	22.37	9.99	1.50	83317.85
11	7.93	0.87	54.94	0.12	21.90	10.41	1.50	81310.90
12	1.60	1.19	66.20	0.07	20.67	11.47	1.52	73492.04
13	3.25	1.16	49.02	0.15	22.57	9.80	1.52	84888.49
14	5.61	3.52	51.56	0.11	22.08	10.41	1.50	81276.68
15	7.75	1.59	39.25	0.15	23.15	9.80	1.48	84665.25
16	2.13	8.00	45.77	0.06	20.39	11.70	1.49	72743.28
17	3.87	7.08	54.98	0.06	20.48	11.58	1.48	73683.12
18	15.87	10.64	45.31	0.28	19.66	10.86	1.49	80025.27
19	8.51	5.58	56.20	0.22	20.43	11.16	1.48	76819.88
20	3.10	3.21	55.11	0.07	20.14	12.05	1.46	70224.40
21	2.60	2.99	56.70	0.11	21.36	11.59	1.46	72619.46
22	1.60	2.32	55.67	0.12	21.75	11.08	1.47	76432.42
23	4.21	2.20	51.69	0.10	21.41	10.80	1.46	78810.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.76	4.41	52.04	0.13	20.99	10.90	1.50	78224.69
最大值	15.87	13.01	70.36	0.29	23.15	12.05	1.57	84888.49
發生時間	18	4	3	5	15	7		13
最小值	1.60	0.87	38.04	0.03	19.22	9.80	1.46	68706.48
發生時間	12	11	9	7	6	13		7
零點偏移(率)	0.00 %	0.00 %	-0.01 %	-0.01 %		0.03	0.00	0.00 %
全幅偏移(率)	-0.30 %	0.53 %	-0.51 %	0.39 %		0.19	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.72	6.23	61.68	3.35	12.32	12.89	1.20	84569.46
1	11.64	2.38	47.50	1.95	15.17	12.19	1.18	89519.84
2	9.71	1.54	52.31	1.09	16.19	12.06	1.18	88562.90
3	11.35	3.92	63.33	2.13	15.43	11.86	1.19	91689.81
4	10.62	3.37	65.30	1.87	15.64	11.82	1.19	92071.55
5	10.92	2.87	70.23	1.77	15.23	11.98	1.18	90323.41
6	8.05	9.92	69.21	1.09	15.18	12.16	1.23	88386.87
7	10.88	7.92	73.13	1.49	15.39	11.64	1.24	92063.18
8	11.01	11.97	70.88	1.52	14.91	12.71	1.22	81848.33
9	7.64	4.21	60.76	0.23	17.81	11.28	1.21	89917.96
10	10.28	1.91	55.56	0.14	17.33	11.16	1.20	90244.90
11	8.10	6.98	56.28	3.40	18.01	10.74	1.20	93077.91
12	10.80	5.27	43.99	0.48	17.31	11.21	1.22	89610.98
13	11.20	3.04	62.34	1.05	18.35	10.56	1.23	95918.84
14	10.16	9.56	41.18	1.01	17.00	11.38	1.22	88962.44
15	10.02	8.02	51.61	0.56	16.85	11.84	1.20	85296.31
16	11.26	2.20	57.01	0.55	17.90	10.85	1.20	92647.68
17	10.91	5.10	61.32	0.90	15.67	11.54	1.20	88174.84
18	10.83	5.07	64.46	1.36	15.29	11.62	1.20	88136.11
19	10.21	7.56	63.61	0.84	16.14	11.94	1.20	83702.86
20	10.98	6.55	54.90	0.42	17.04	12.03	1.20	81586.94
21	11.35	3.00	54.58	0.32	18.22	10.89	1.20	90803.31
22	10.52	3.02	50.81	0.33	18.09	10.72	1.20	91951.24
23	10.60	1.67	52.83	0.23	17.88	10.88	1.20	91054.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.41	5.14	58.53	1.17	16.43	11.58	1.20	89171.75
最大值	11.64	11.97	73.13	3.40	18.35	12.89	1.25	95918.84
發生時間	1	8	7	11	13	0		13
最小值	7.64	1.54	41.18	0.14	12.32	10.56	1.17	81586.94
發生時間	9	2	14	10	0	13		20
零點偏移(率)	-0.02 %	0.00 %	-0.03 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	1.20 %	1.17 %	-0.32 %	0.24 %		-0.07	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.54	1.41	63.06	1.51	16.97	10.42	1.30	78500.77
1	7.95	1.85	53.60	1.40	16.43	10.59	1.30	77043.27
2	6.45	1.90	53.27	1.39	17.44	10.72	1.30	77520.88
3	8.42	2.04	52.10	1.83	16.72	10.52	1.30	79681.94
4	10.11	1.27	51.54	1.86	17.10	10.36	1.30	80455.23
5	7.82	1.05	63.61	1.85	18.09	10.09	1.30	82438.66
6	12.06	1.69	60.59	2.09	16.73	10.54	1.30	80825.18
7	8.37	5.13	53.44	2.17	18.26	10.38	1.27	86663.05
8	9.67	3.19	59.66	2.30	18.38	10.32	1.25	79188.22
9	7.52	5.02	55.64	1.82	19.25	9.76	1.25	85024.27
10	6.65	6.68	56.62	2.08	18.60	9.32	1.25	82037.61
11	5.80	1.03	51.72	1.75	17.73	10.12	1.25	76653.67
12	10.33	2.84	54.78	2.57	19.04	9.32	1.27	84825.27
13	8.26	3.70	55.82	2.01	17.94	9.84	1.28	82530.58
14	9.24	5.95	48.10	1.97	18.28	10.00	1.26	81491.21
15	3.85	13.26	35.03	8.26	21.75	8.21	1.25	84916.84
16	0.86	13.77	26.15	2.07	21.27	7.18	1.24	81735.86
17	5.34	2.87	58.15	2.29	16.66	9.61	1.25	77898.42
18	9.81	6.31	42.02	2.26	17.71	9.40	1.25	76767.68
19	6.19	6.42	33.90	3.84	18.53	8.84	1.24	76381.92
20	7.72	4.17	37.45	2.18	19.44	9.02	1.25	79040.07
21	6.57	3.94	49.03	1.70	18.85	9.67	1.26	78955.06
22	9.22	5.30	42.42	2.13	19.00	9.42	1.25	78476.64
23	9.80	5.55	39.78	1.76	17.84	9.88	1.25	77237.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.69	4.43	49.90	2.30	18.25	9.73	1.27	80262.07
最大值	12.06	13.77	63.61	8.26	21.75	10.72	1.30	86663.05
發生時間	6	16	5	15	15	2		7
最小值	0.86	1.03	26.15	1.39	16.43	7.18	1.23	76381.92
發生時間	16	11	16	2	1	16		19
零點偏移(率)	0.00 %	-0.02 %	-0.02 %	0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	0.89 %	0.03 %	-0.32 %	0.03 %		0.26	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								