

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.07	6.10	50.63	1.38	17.35	11.27	1.75	83117.25
1	14.50	5.39	47.98	1.49	17.52	11.35	1.72	81303.21
2	14.01	3.86	60.53	1.22	17.31	11.20	1.72	82690.78
3	15.06	7.41	55.51	1.59	16.42	11.61	1.73	79301.54
4	13.35	4.97	51.52	1.07	17.62	11.30	1.75	79860.78
5	18.01	10.48	46.87	1.55	16.77	11.42	1.71	82343.83
6	12.38	14.54	53.41	1.11	17.12	11.94	1.70	79093.56
7	13.06	4.45	61.62	0.82	18.51	11.49	1.70	83540.74
8	11.32	4.17	57.50	0.89	17.67	11.37	1.71	84524.03
9	12.92	6.46	56.27	0.93	18.46	11.26	1.71	85429.04
10	15.74	7.12	52.98	1.19	17.60	11.60	1.69	81659.27
11	12.15	14.03	52.04	1.07	17.65	11.54	1.72	83034.15
12	14.89	8.91	56.91	1.17	18.10	11.36	1.71	84886.60
13	13.73	9.37	54.78	0.61	19.32	10.91	1.70	87926.46
14	13.96	7.72	61.24	0.74	18.72	11.62	1.70	81701.92
15	12.35	9.95	61.84	0.69	18.28	12.44	1.68	74201.17
16	12.67	8.11	52.56	0.67	20.25	11.04	1.70	85116.83
17	14.81	9.66	57.04	2.25	19.85	10.90	1.70	86576.79
18	12.95	6.54	54.61	1.10	19.25	11.10	1.70	85582.72
19	14.13	5.79	61.54	0.82	19.98	10.96	1.69	85876.77
20	13.73	11.36	62.23	0.92	18.53	11.93	1.67	79007.43
21	11.81	1.71	63.30	0.42	20.11	11.11	1.65	84808.87
22	12.70	1.74	59.26	0.58	19.74	11.36	1.67	82841.29
23	11.73	3.24	67.63	0.60	18.87	12.11	1.68	77460.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	13.50	7.21	56.66	1.04	18.38	11.42	1.70	82578.55
最大值	18.01	14.54	67.63	2.25	20.25	12.44	1.75	87926.46
發生時間	5	6	23	17	16	15		13
最小值	11.32	1.71	46.87	0.42	16.42	10.90	1.65	74201.17
發生時間	8	21	5	21	3	17		15
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	4.11 %	0.34 %	-0.68 %	0.25 %		0.18	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.72	0.59	65.25	0.22	19.16	10.26	1.46	88395.92
1	14.31	2.96	60.28	0.14	20.37	10.17	1.47	88153.91
2	14.22	3.67	58.46	0.24	19.97	10.06	1.46	88012.81
3	13.24	3.60	54.61	0.16	19.19	10.29	1.46	87417.20
4	15.02	4.02	51.11	0.16	19.69	10.22	1.47	89214.66
5	12.32	4.55	51.28	0.15	20.52	10.49	1.46	84432.76
6	16.65	6.43	50.59	0.10	19.61	10.36	1.42	83456.21
7	11.84	9.79	46.93	0.15	19.03	10.36	1.43	86038.52
8	11.71	11.61	55.74	0.23	19.07	10.27	1.44	87049.60
9	15.11	7.39	50.65	0.22	18.10	10.34	1.44	83960.29
10	12.88	5.82	55.74	0.37	17.16	10.74	1.44	84181.26
11	14.13	1.52	68.02	0.34	16.79	10.84	1.45	84300.55
12	14.07	8.41	61.14	0.17	17.20	10.71	1.45	84800.43
13	16.16	6.62	57.89	0.27	17.86	10.53	1.43	85878.35
14	13.38	8.06	45.74	0.28	17.34	10.78	1.42	79102.58
15	12.28	2.37	62.31	0.20	17.21	11.63	1.42	74314.72
16	11.99	12.37	53.33	0.12	19.17	10.62	1.44	82713.65
17	11.42	2.13	52.31	0.14	18.28	10.44	1.43	87607.17
18	15.60	11.07	47.88	1.12	17.95	10.37	1.42	85953.80
19	12.22	6.39	62.63	0.32	17.85	11.23	1.42	77381.96
20	13.93	1.34	58.75	0.10	18.95	10.11	1.43	90016.19
21	13.59	10.79	52.83	0.28	17.79	10.69	1.43	84046.01
22	13.77	3.65	48.30	0.18	19.03	10.31	1.42	83833.77
23	10.26	2.35	56.41	0.14	16.76	11.48	1.41	75713.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	13.49	5.73	55.34	0.24	18.50	10.55	1.44	84415.65
最大值	16.65	12.37	68.02	1.12	20.52	11.63	1.48	90016.19
發生時間	6	16	11	18	5	15		20
最小值	10.26	0.59	45.74	0.10	16.76	10.06	1.40	74314.72
發生時間	23	0	14	6	23	2		15
零點偏移(率)	-0.03 %	0.00 %	-0.04 %	-0.03 %		-0.09	0.00	0.00 %
全幅偏移(率)	3.37 %	0.21 %	-0.44 %	0.41 %		0.29	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.61	3.02	51.13	2.58	18.80	9.08	1.55	75922.67
1	15.47	1.90	63.46	3.00	17.67	8.98	1.57	76841.26
2	13.58	1.45	66.84	2.95	17.90	9.84	1.55	73182.61
3	12.49	4.70	56.42	2.85	17.20	9.93	1.54	72313.83
4	14.63	11.52	48.20	2.72	18.06	9.71	1.55	72078.39
5	11.48	11.73	49.75	2.98	16.83	9.74	1.56	73217.51
6	14.02	12.37	50.15	2.81	18.07	9.56	1.57	72571.21
7	4.85	3.79	55.79	2.27	17.27	10.15	1.57	65806.98
8	11.59	3.34	63.28	2.50	17.29	10.12	1.58	69202.30
9	11.37	2.66	65.81	2.51	17.76	9.49	1.61	74743.70
10	12.48	5.24	57.02	2.47	17.46	9.52	1.57	75276.25
11	11.56	9.53	46.97	2.38	17.22	9.38	1.54	75973.66
12	10.77	6.37	47.33	2.54	15.55	10.33	1.61	72711.35
13	10.87	9.54	63.04	2.68	16.01	10.92	1.60	74803.36
14	10.77	6.72	61.20	2.93	14.94	11.38	1.55	72124.50
15	10.42	10.68	65.00	2.59	16.62	11.56	1.56	62176.98
16	10.43	3.55	62.62	2.55	17.10	10.50	1.55	67946.92
17	10.74	4.74	66.20	2.57	18.75	9.50	1.55	72756.42
18	12.54	4.35	63.59	2.95	17.41	9.50	1.56	75119.34
19	10.66	5.18	54.55	2.43	17.02	10.45	1.58	70349.05
20	12.06	14.55	50.50	2.66	16.89	10.07	1.59	72371.12
21	11.57	0.81	52.31	2.57	17.77	9.62	1.60	73643.98
22	12.64	3.67	47.20	2.64	17.60	9.63	1.58	74962.25
23	14.63	1.44	52.25	2.77	18.21	9.95	1.57	71017.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.80	5.95	56.69	2.66	17.31	9.95	1.57	72379.73
最大值	15.47	14.55	66.84	3.00	18.80	11.56	1.63	76841.26
發生時間	1	20	2	1	0	15		1
最小值	4.85	0.81	46.97	2.27	14.94	8.98	1.53	62176.98
發生時間	7	21	11	7	14	1		15
零點偏移(率)	-0.01 %	0.00 %	-0.17 %	-0.04 %		-0.04	0.00	0.00 %
全幅偏移(率)	0.88 %	3.67 %	1.40 %	1.95 %		0.18	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								